

BEITOSTOLEN II, Norway

WMO: 013650

Lat: 61.251N

Lon: 8.923E

Elev: 3166

StdP: 13.09

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.1	3.2	-7.0	4.2	2.8	-3.9	5.0	5.3	29.1	26.4	25.0	28.5	4.5	0	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	69.6	55.2	66.2	53.9	62.6	52.4	57.7	65.0	55.8	62.4	54.2	60.2	7.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.9	72.0	58.8	53.2	67.8	57.7	51.5	63.5	56.2	26.2	64.7	25.0	62.7	23.9	60.2	62.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.4	20.2	17.1	DB	-3.6	73.1	4.6	4.0	-7.0	75.9	-9.6	78.3	-12.2	80.5	-15.6	83.4
			WB	-3.9	60.2	4.7	1.6	-7.3	61.3	-10.0	62.3	-12.7	63.2	-16.1	64.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.9	18.9	21.1	24.9	31.8	41.3	49.0	53.7	50.4	44.3	34.6	26.0	22.0	(6)
	DBStd	13.87	8.20	8.30	7.88	7.15	8.23	4.95	6.07	4.07	5.36	6.09	7.45	8.34	(7)
	HDD50	5793	964	810	779	547	293	76	28	45	184	478	721	868	(8)
	HDD65	10991	1429	1230	1244	997	736	481	354	454	620	942	1171	1333	(9)
	CDD50	280	0	0	0	0	22	45	141	56	15	1	0	0	(10)
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0	(11)
	CDH74	9	0	0	0	0	0	1	8	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
	WSAvg	7.3	7.0	7.9	9.4	8.2	7.8	7.3	6.7	6.0	7.0	6.6	6.6	7.7	(14)
	PrecAvg	31.0	2.4	1.5	1.5	1.6	2.1	3.1	3.9	4.1	2.8	2.9	2.8	2.1	(15)
(16) Precipitation	PrecMax	42.6	5.0	3.3	2.9	3.5	6.6	7.2	7.8	7.6	5.0	6.5	7.1	4.0	(16)
	PrecMin	22.5	0.7	0.5	0.3	0.5	0.1	0.2	1.2	0.6	1.0	0.7	0.8	0.4	(17)
	PrecStd	4.1	1.1	0.7	0.7	0.9	1.3	1.5	1.7	1.7	1.0	1.4	1.3	0.8	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.5	41.4	46.6	54.4	69.0	70.9	75.0	68.0	63.3	55.3	45.7	42.2	(19)
		MCWB	35.5	36.6	39.2	42.7	50.8	53.1	58.8	54.5	52.8	51.1	39.9	38.8	(20)
	2%	DB	36.7	38.5	41.8	49.5	63.2	66.1	71.6	63.6	59.4	49.3	41.5	39.2	(21)
		MCWB	33.2	34.5	36.5	41.0	50.1	51.3	57.3	53.6	51.0	43.7	38.1	36.2	(22)
	5%	DB	33.1	35.1	39.0	45.3	58.1	61.8	68.3	60.5	55.6	45.8	38.6	36.2	(23)
		MCWB	30.4	31.2	34.5	37.9	47.3	49.2	56.0	52.1	48.8	40.6	36.5	33.4	(24)
	10%	DB	30.0	32.2	36.3	41.9	53.8	58.1	64.8	57.7	52.4	42.7	35.5	33.0	(25)
		MCWB	27.9	29.1	32.1	36.3	45.9	47.9	54.7	51.0	47.3	38.3	33.5	30.6	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.2	37.4	39.6	44.7	54.2	55.9	60.8	57.6	54.9	51.8	41.1	39.5	(27)
		MCDB	38.7	40.7	45.1	53.2	64.3	60.8	71.6	61.8	59.5	54.3	44.5	41.9	(28)
	2%	WB	33.2	35.0	36.8	41.2	51.2	54.0	59.0	55.5	52.2	45.5	38.5	36.2	(29)
		MCDB	35.7	38.3	41.3	48.2	59.6	60.7	67.6	60.0	56.7	48.8	40.5	38.6	(30)
	5%	WB	30.6	31.8	34.8	38.7	48.8	52.3	57.4	54.0	50.3	42.0	36.6	33.5	(31)
		MCDB	33.1	34.6	38.7	44.4	56.9	58.0	65.1	58.9	54.5	44.3	38.7	36.0	(32)
	10%	WB	28.3	29.2	32.4	36.4	46.4	50.3	55.7	52.3	48.4	39.3	33.6	30.7	(33)
		MCDB	29.8	31.7	35.7	41.7	53.2	56.7	62.8	56.4	52.1	42.2	35.0	32.5	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	7.9	8.5	10.5	11.6	12.9	14.7	14.3	12.7	11.2	9.0	7.5	8.0	(35)
		MCDBR	10.1	10.0	11.3	14.9	18.8	20.7	19.4	16.5	16.1	13.6	9.6	11.2	(36)
		MCWBR	8.5	7.8	8.4	8.8	9.7	11.1	9.2	8.5	9.1	9.3	8.1	9.8	(37)
	5% WB	MCDBR	9.2	9.2	11.1	13.6	16.5	15.0	16.5	14.0	14.0	11.2	9.1	10.9	(38)
		MCWBR	8.1	7.4	8.7	8.3	9.2	9.6	8.4	8.5	8.7	8.7	8.0	10.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.192	0.235	0.265	0.296	0.305	0.305	0.317	0.309	0.281	0.263	0.204	0.159	(40)
	taud		2.159	2.297	2.295	2.318	2.447	2.533	2.510	2.518	2.585	2.496	2.206	1.999	(41)
	Ebn at Noon		190	249	276	286	292	294	287	280	272	238	180	144	(42)
	Edh at Noon		11	19	27	32	31	29	29	27	21	16	10	7	(43)
(44) All-Sky Solar Radiation	RadAvg		95	308	787	1359	1580	1613	1479	1152	744	344	118	55	(44)
	RadStd		16	58	84	154	169	159	173	89	81	51	19	4	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page