

DREVSJO, Norway

WMO: 013930

Lat: 61.890N

Lon: 12.033E

Elev: 2210

StdP: 13.56

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.8	-16.0	-27.4	1.3	-21.8	-20.9	1.9	-15.9	16.5	29.8	14.9	29.0	1.7	290	0.706

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	74.0	57.2	70.5	56.4	66.7	54.6	60.0	69.6	58.1	66.6	56.3	64.3	6.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.2	72.9	63.0	54.3	68.1	61.2	52.6	63.9	59.4	27.3	69.7	26.0	66.4	24.8	64.3	65.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	13.3	11.6	DB	-27.8	78.9	4.8	3.2	-31.2	81.3	-34.1	83.2	-36.8	85.0	-40.3	87.3	(4)
(5)			WB	-28.1	61.6	4.6	2.7	-31.4	63.5	-34.1	65.1	-36.7	66.6	-40.0	68.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.7	14.1	16.2	22.0	31.9	41.7	48.8	54.6	51.1	44.6	34.3	25.9	17.9		
	DBStd	16.36	13.23	11.29	10.90	7.34	7.35	6.07	5.49	4.91	5.69	6.99	8.13	12.25		
	HDD50	6289	1112	948	869	544	275	94	19	46	176	488	722	996		
	HDD65	11431	1577	1368	1334	994	721	485	324	431	612	952	1172	1461		
	CDD50	335	0	0	0	0	19	59	161	81	14	1	0	0		
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH74	97	0	0	0	0	4	22	69	2	0	0	0	0		
	CDH80	5	0	0	0	0	0	1	4	0	0	0	0	0		
(14) Wind	WSAvg	4.8	4.1	4.3	5.0	5.0	5.7	5.8	5.1	4.7	5.0	4.7	4.2	4.0		
(15) Precipitation	PrecAvg	25.6	1.7	1.2	1.2	1.5	2.3	2.7	3.2	3.5	2.3	2.4	2.0	1.5		
	PrecMax	34.3	3.2	2.2	2.3	3.9	4.6	5.9	5.5	5.2	4.4	5.1	5.3	3.2		
	PrecMin	20.5	0.5	0.2	0.3	0.2	0.4	0.3	0.8	1.3	0.5	0.6	0.9	0.2		
	PrecStd	3.4	0.8	0.5	0.5	0.9	1.2	1.2	1.2	1.3	1.0	1.4	0.9	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.3	41.3	48.5	57.9	73.6	77.0	79.6	72.5	65.9	56.7	47.1	41.3		
		MCWB	35.2	35.5	39.7	45.6	54.2	56.1	61.0	57.4	54.1	50.7	44.0	38.0		
	2%	DB	36.5	38.1	43.8	53.4	68.4	72.5	75.7	68.1	61.6	50.9	43.3	38.5		
		MCWB	33.6	33.8	36.7	42.4	52.8	55.0	59.8	55.7	51.9	46.0	40.7	35.6		
	5%	DB	33.8	34.9	40.1	49.5	63.0	67.2	71.9	65.0	58.3	47.8	39.9	36.3		
		MCWB	31.5	31.8	34.6	40.1	50.0	53.0	58.0	55.1	51.3	43.8	37.8	33.8		
	10%	DB	31.4	32.2	37.0	45.4	57.1	62.9	68.2	61.8	55.2	45.4	37.1	33.5		
		MCWB	29.5	29.9	32.5	37.8	47.3	51.6	56.4	54.0	49.9	42.2	34.9	31.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.8	37.1	40.1	46.8	56.7	59.1	63.7	60.3	55.8	51.3	44.3	38.4		
		MCDB	38.5	40.7	46.5	54.6	68.0	68.6	74.0	67.5	61.5	55.4	46.9	40.6		
	2%	WB	34.0	34.2	37.3	43.4	53.9	56.6	61.4	58.3	53.9	47.0	40.8	35.9		
		MCDB	36.3	37.3	42.7	52.0	66.1	67.6	72.0	64.2	59.1	50.2	42.9	38.4		
	5%	WB	31.8	32.0	35.0	40.7	51.5	54.7	59.4	56.6	52.0	44.3	38.1	33.8		
		MCDB	33.9	34.9	39.5	48.6	61.7	65.8	69.7	62.3	57.2	47.1	39.9	36.0		
	10%	WB	29.5	29.9	32.9	38.5	48.3	52.6	57.6	54.8	50.1	42.5	35.0	31.4		
		MCDB	31.3	32.2	36.8	44.7	57.0	61.7	66.6	60.6	54.7	45.3	36.8	33.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.6	18.9	21.4	19.8	19.7	19.7	19.7	18.2	16.8	13.6	12.5	15.2		
		MCDBR	12.6	17.2	21.0	27.0	31.7	29.9	28.4	24.9	23.4	17.6	13.5	13.6		
		MCWBR	11.3	14.1	14.7	16.9	17.1	15.0	14.4	14.5	15.1	13.4	11.7	12.2		
	5% WB	MCDBR	12.4	15.5	19.1	24.5	27.5	25.4	25.4	19.1	19.3	14.4	13.0	13.5		
		MCWBR	11.4	12.8	13.7	15.6	15.3	13.1	13.3	11.8	13.3	11.7	11.6	12.4		
(40) Clear-Sky Solar Irradiance	taub		0.201	0.253	0.282	0.316	0.327	0.322	0.337	0.328	0.298	0.282	0.215	0.171		
	taud		2.097	2.255	2.257	2.297	2.458	2.510	2.475	2.490	2.556	2.486	2.171	1.979		
	Ebn at Noon		169	233	265	278	284	287	279	272	263	224	159	117		
	Edh at Noon		10	19	28	33	31	30	30	27	21	16	10	6		
(44) All-Sky Solar Radiation	RadAvg		84	292	783	1336	1511	1626	1488	1151	741	330	103	45		
	RadStd		11	51	69	116	126	144	182	105	85	52	22	4		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page