

WMO: 014000

Annual Heating, Humidification, and Ventilation Design Conditions															
Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.7	0.5	-6.7	2.2	1.1	-5.1	2.5	1.8	25.3	4.4	23.4	4.4	11.9	110	0.930

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.3	(c) 19.8	(d) 18.0	(e) 18.6	(f) 16.9	(g) 17.8	(h) 16.2	(i) 18.3	(j) 19.4	(k) 17.2	(l) 18.3	(m) 16.5	(n) 17.5	(o) 6.1	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	12.9	19.0	16.8	12.0	18.0	16.0	11.4	17.3	51.7	19.3	48.6	18.2	46.3	17.5	21.2

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
21.2	19.0	17.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-1.5	20.8	2.0	2.3	-3.0	22.4	-4.1	23.8	-5.3	25.1	-6.7	26.8
			-2.9	18.3	1.8	1.7	-4.3	19.5	-5.3	20.5	-6.4	21.4	-7.7	22.6

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	5.5	4.8	5.2	6.6	9.3	12.1	14.8	15.8	14.0	11.2	8.3	6.5
	DBStd	4.25	1.95	2.28	2.08	1.68	1.96	1.69	1.95	1.76	1.62	1.80	1.94	2.08
	HDD10.0	745	139	144	149	101	36	2	0	0	0	9	54	109
	HDD18.3	3211	397	378	408	351	279	188	110	82	129	221	300	368
	CDD10.0	581	0	0	0	1	16	64	150	179	121	47	4	0
	CDD18.3	4	0	0	0	0	0	0	2	3	0	0	0	0
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.7	10.7	10.2	9.3	7.9	7.5	7.1	6.7	7.1	8.3	9.5	9.9	9.9
Precipitation	PrecAvg	1134	139	111	95	56	45	62	70	88	100	110	130	129
	PrecMax	1404	244	185	166	99	69	108	101	145	165	158	205	251
	PrecMin	918	49	49	33	24	23	24	33	37	46	44	81	63
	PrecStd	113	48	38	31	17	13	18	20	24	28	31	31	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	9.4	9.5	11.3	15.4	17.0	21.0	21.2	18.7	15.6	13.1	10.8
		MCWB	8.8	8.4	7.8	8.9	12.5	14.7	18.7	18.9	16.6	14.2	12.1	9.5
	2%	DB	9.1	8.8	8.6	10.1	13.8	15.9	19.3	20.1	17.5	14.8	12.0	10.0
		MCWB	8.1	8.1	7.5	8.6	11.8	14.2	17.5	18.4	15.8	13.6	11.0	9.1
	5%	DB	8.5	8.1	8.1	9.3	12.7	15.1	18.2	19.0	16.8	14.1	11.2	9.4
		MCWB	7.4	7.3	7.1	8.3	11.1	13.6	16.6	17.4	15.4	13.0	10.2	8.5
	10%	DB	8.0	7.5	7.6	8.8	11.8	14.2	17.4	18.1	16.2	13.5	10.8	9.0
		MCWB	6.9	6.7	6.7	8.0	10.4	12.9	16.0	16.6	14.7	12.2	9.7	8.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	9.0	8.4	9.8	13.3	15.4	19.5	20.0	17.1	14.7	12.4	10.0
		MCDB	9.5	9.1	8.9	10.6	14.4	16.4	20.7	20.7	18.1	15.2	12.9	10.3
	2%	WB	8.3	8.1	7.8	9.0	12.2	14.6	17.9	18.7	16.4	14.1	11.3	9.3
		MCDB	8.7	8.4	8.3	9.6	13.3	15.5	18.9	19.7	17.2	14.7	11.8	9.6
	5%	WB	7.7	7.4	7.3	8.5	11.4	14.0	17.0	17.7	15.8	13.4	10.6	8.8
		MCDB	8.2	7.8	7.7	9.1	12.4	14.9	18.1	18.9	16.6	14.0	11.1	9.2
	10%	WB	7.1	6.9	6.9	8.0	10.7	13.3	16.2	16.8	15.1	12.7	10.0	8.2
		MCDB	7.6	7.3	7.4	8.6	11.6	14.1	17.3	17.9	16.0	13.3	10.5	8.8
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.4	2.3	2.3	2.5	2.3	2.3	2.3	2.1	2.1	2.2	2.3
		MCDBR	2.6	2.5	2.6	2.8	3.8	3.3	3.3	3.1	2.6	2.3	2.4	2.3
		MCWBR	3.2	2.6	2.3	2.2	2.6	2.4	2.4	2.5	2.5	2.6	2.9	2.8
	5% WB	MCDBR	2.4	2.3	2.3	2.6	3.4	3.0	2.9	2.8	2.4	2.2	2.2	2.2
		MCWBR	3.1	2.7	2.4	2								

[illegible]