

SLATTEROY FYR, Norway

WMO: 014060

Lat: 59.908N

Lon: 5.068E

Elev: 16

StdP: 101.13

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.4	-2.3	-11.1	1.5	-1.3	-9.1	1.7	-0.1	18.7	4.8	17.0	4.8	4.4	140	0.745

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.2	21.4	16.2	19.9	15.8	18.6	15.3	17.6	20.0	16.8	18.9	15.9	17.9	5.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.6	11.8	18.8	15.7	11.2	18.1	14.9	10.6	17.2	49.7	20.1	47.2	18.9	44.6	17.9	20.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.8	13.2	-4.8	25.6	2.2	2.5	-6.3	27.5	-7.6	28.9	-8.8	30.3	-10.4	32.2		
(5)			-5.9	18.3	2.4	1.3	-7.6	19.2	-9.0	19.9	-10.4	20.6	-12.1	21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	3.3	2.8	3.8	6.4	9.3	12.0	14.6	15.4	13.3	9.9	6.6	4.2
	DBStd	5.04	2.52	2.63	2.22	2.43	2.61	2.23	2.47	2.32	2.18	2.45	2.65	2.95
	HDD10.0	1077	207	202	191	112	44	4	0	0	2	32	104	179
	HDD18.3	3597	466	435	449	357	281	191	119	96	151	262	352	437
	CDD10.0	533	0	0	0	4	22	64	143	168	101	27	2	0
	CDD18.3	12	0	0	0	0	0	1	4	6	1	0	0	0
	CDH23.3	18	0	0	0	0	0	1	10	8	0	0	0	0
	CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	6.1	7.2	6.5	6.1	5.6	5.7	5.5	4.9	5.4	5.8	6.6	6.7	6.8
Precipitation	PrecAvg	1889	184	145	146	109	87	109	122	153	189	219	217	209
	PrecMax	2311	381	340	263	208	184	243	198	239	326	411	400	367
	PrecMin	1294	12	15	4	45	7	27	45	51	48	70	40	55
	PrecStd	292	93	82	67	37	40	52	43	48	82	84	94	97
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	8.4	10.2	16.8	20.2	21.6	24.2	24.5	20.6	17.4	13.1	10.2
		MCWB	7.1	6.8	6.8	10.6	13.0	14.2	17.2	16.8	15.6	13.6	10.8	9.1
	2%	DB	8.0	7.5	7.9	13.2	16.9	18.3	21.2	21.5	18.5	15.1	11.7	9.2
		MCWB	6.7	6.5	5.6	8.2	11.5	14.0	16.7	16.5	14.4	12.2	10.0	8.3
	5%	DB	7.4	7.0	7.1	11.1	14.7	16.2	19.5	20.1	17.2	13.8	10.8	8.7
		MCWB	6.2	6.1	5.7	7.6	11.1	13.3	16.0	16.3	14.2	11.6	9.2	7.6
	10%	DB	6.8	6.4	6.5	9.6	12.9	14.9	18.0	18.8	16.3	13.0	10.1	8.1
		MCWB	5.7	5.5	5.3	7.2	10.4	12.7	15.3	16.0	13.7	11.0	8.5	6.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	7.6	7.6	11.7	14.2	16.0	18.7	18.7	16.8	14.2	11.7	9.5
		MCDB	8.4	7.8	8.4	14.6	18.1	18.8	21.7	21.2	18.5	16.1	12.4	9.8
	2%	WB	7.2	6.9	6.7	9.3	12.5	14.5	17.6	17.8	15.7	13.1	10.5	8.7
		MCDB	7.7	7.2	7.3	11.6	15.4	16.9	20.1	20.3	17.4	14.5	11.4	9.1
	5%	WB	6.6	6.3	6.1	8.3	11.4	13.7	16.6	17.1	14.9	12.2	9.6	7.9
		MCDB	7.2	6.9	6.9	10.1	14.0	15.8	18.8	19.2	16.6	13.5	10.6	8.6
	10%	WB	5.8	5.6	5.5	7.6	10.4	12.9	15.7	16.3	14.1	11.5	8.7	7.0
		MCDB	6.6	6.3	6.3	9.2	12.6	14.6	17.6	18.2	15.7	12.8	9.8	7.8
Mean Daily Temperature Range	5% DB	MDBR	2.7	2.7	2.9	3.4	3.3	3.0	2.9	3.2	2.9	2.9	2.7	2.8
		MCDBR	3.4	2.9	3.3	6.1	6.6	5.3	5.6	5.4	4.1	3.6	3.1	3.1
		MCWBR	3.3	2.8	2.5	3.2	3.2	3.0	3.1	2.7	2.7	2.7	3.3	3.3
	5% WB	MCDBR	3.1	2.6	2.9	4.8	5.7	4.5	4.8	4.2	3.5	3.4	3.2	3.1
		MCWBR	3.4	2.8	2.5	3.0	3.3	3.0	2.9	2.6	2.8	3.0	3.7	3.5
Clear-Sky Solar Irradiance	taub	0.303	0.330	0.350	0.378	0.365	0.361	0.375	0.373	0.358	0.335	0.306	0.407	
	taud	2.161	2.285	2.345	2.315	2.427	2.473	2.452	2.455	2.481	2.417	2.234	2.606	
	Ebn at Noon	453	665	778	819	863	872	848	820	770	660	452	326	
	Edh at Noon	45	68	87	106	102	99	99	92	76	60	41	32	
All-Sky Solar Radiation	RadAvg	0.25	0.79	1.92	3.58	5.05	5.39	4.73	3.64	2.27	1.10	0.36	0.15	
	RadStd	0.04	0.14	0.28	0.34	0.52	0.65	0.45	0.35	0.24	0.15	0.05	0.02	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-117	N/A	N/A

Nomenclature: See separate page