

EIK HOVE, Norway

WMO: 014250

Lat: 58.508N

Lon: 6.511E

Elev: 217

StdP: 14.58

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.4	11.8	1.7	6.1	7.3	7.2	8.0	15.4	20.7	38.8	18.5	39.5	2.2	350	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	77.2	63.3	73.5	61.8	70.0	60.0	65.3	73.7	63.5	70.8	61.7	67.8	6.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.2	84.3	67.8	60.5	79.4	65.7	59.1	75.3	64.3	30.2	73.8	28.9	70.6	27.7	68.0	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	14.5	12.4	1.2	82.0	7.0	2.4	-3.8	83.7	-7.9	85.1	-11.9	86.5	-17.0	88.3
			0.8	68.1	6.9	2.0	-4.2	69.5	-8.2	70.7	-12.1	71.9	-17.2	73.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.4	31.8	31.2	35.3	42.3	49.3	55.0	59.2	58.1	53.3	45.0	38.2	33.2	(6)
	DBStd	11.82	8.27	7.84	6.44	5.34	5.99	4.56	4.64	4.34	4.54	5.79	6.58	8.68	(7)
	HDD50	2947	565	526	456	237	87	8	0	1	19	172	355	521	(8)
	HDD65	7532	1030	946	920	680	488	301	188	218	351	620	804	986	(9)
	CDD50	904	0	0	0	7	64	158	287	252	118	17	1	0	(10)
	CDD65	16	0	0	0	0	1	1	10	4	0	0	0	0	(11)
	CDH74	257	0	0	0	0	22	38	149	47	1	0	0	0	(12)
	CDH80	20	0	0	0	0	1	2	15	2	0	0	0	0	(13)
	WSAvg	5.0	5.3	5.0	5.2	5.3	5.6	5.6	4.9	4.5	4.5	4.8	5.0	5.0	(14)
	PrecAvg	94.9	12.0	8.5	7.0	5.0	4.4	4.6	5.6	7.3	7.7	10.9	10.4	11.7	(15)
(16) Precipitation	PrecMax	129.6	22.3	21.0	16.5	8.5	8.7	8.5	12.4	11.8	15.9	21.7	22.7	25.7	(16)
	PrecMin	53.4	0.7	0.5	1.1	2.4	0.6	0.6	1.3	1.3	1.7	1.2	2.7	0.3	(17)
	PrecStd	17.1	5.7	5.4	3.9	1.7	2.3	2.1	2.5	2.4	3.3	5.4	5.2	7.0	(18)
	PrecStd	17.1	5.7	5.4	3.9	1.7	2.3	2.1	2.5	2.4	3.3	5.4	5.2	7.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	47.9	57.4	66.0	77.5	78.2	81.9	79.0	71.2	60.2	53.6	50.0	(19)
		MCWB	45.6	44.7	46.1	52.9	61.4	61.8	66.0	64.8	62.4	55.1	51.1	47.7	(20)
	2%	DB	45.7	44.8	49.6	61.5	70.8	73.7	78.4	74.3	66.1	57.3	51.6	48.3	(21)
		MCWB	43.4	42.2	43.8	50.2	56.7	60.4	64.7	63.6	59.0	53.6	49.5	46.6	(22)
	5%	DB	43.8	42.9	46.4	56.5	66.5	69.5	74.5	70.2	63.5	55.4	49.6	46.5	(23)
		MCWB	41.7	40.9	41.7	47.3	54.6	58.0	63.3	61.5	57.7	52.7	47.6	44.7	(24)
	10%	DB	41.9	41.1	44.0	52.6	62.1	65.9	70.5	67.0	61.1	53.6	47.9	44.6	(25)
		MCWB	40.0	39.3	40.6	45.4	53.0	56.6	61.6	60.0	56.6	51.4	46.1	42.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.9	45.6	47.4	55.6	62.4	64.3	68.4	66.6	63.6	56.7	52.0	48.4	(27)
		MCDB	47.9	47.0	53.4	62.0	75.2	73.7	78.2	75.0	68.1	58.2	53.1	49.3	(28)
	2%	WB	43.8	43.0	44.8	51.1	58.5	61.7	66.2	64.6	61.0	54.7	49.9	46.8	(29)
		MCDB	45.4	44.0	49.1	58.5	67.4	70.0	75.5	71.4	64.7	56.2	51.3	48.0	(30)
	5%	WB	42.1	41.3	42.8	48.6	56.0	59.6	64.3	62.7	59.0	53.4	48.1	45.0	(31)
		MCDB	43.5	42.6	45.5	54.9	64.1	67.0	72.6	68.3	62.0	54.8	49.4	46.4	(32)
	10%	WB	40.3	39.4	41.0	46.4	53.7	57.6	62.4	61.0	57.5	51.7	46.4	42.8	(33)
		MCDB	41.7	41.0	43.5	51.3	61.2	64.2	69.2	65.3	60.5	53.4	47.8	44.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	10.5	13.1	15.5	17.9	17.0	16.3	15.5	13.2	11.8	9.8	9.2	(35)
		MCDBR	10.3	10.4	17.8	24.8	27.6	26.2	25.6	21.1	17.9	13.0	10.5	9.7	(36)
		MCWBR	9.3	8.2	12.0	14.8	15.1	14.1	14.2	11.7	11.1	9.3	9.5	8.9	(37)
	5% WB	MCDBR	9.9	8.9	15.3	21.5	24.2	22.1	22.9	18.2	14.1	8.9	10.3	9.9	(38)
		MCWBR	9.1	7.9	11.2	13.3	14.1	12.9	13.5	10.8	9.8	7.7	9.5	9.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.294	0.320	0.343	0.378	0.369	0.360	0.375	0.376	0.354	0.336	0.305	0.274	(40)
	taud		2.188	2.267	2.310	2.301	2.390	2.437	2.413	2.407	2.467	2.420	2.282	2.148	(41)
	Ebn at Noon		165	222	252	262	274	278	270	261	249	217	163	131	(42)
	Edh at Noon		15	23	29	35	34	33	33	31	25	20	14	11	(43)
(44) All-Sky Solar Radiation	RadAvg		106	304	720	1177	1564	1771	1568	1190	771	373	145	73	(44)
	RadStd		21	62	86	137	211	174	190	102	88	66	29	11	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-220	N/A	N/A

Nomenclature: See separate page