

EIGEROYA, Norway

WMO: 014260

Lat: 58.4352N

Lon: 5.8718E

Elev: 161

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.4	24.0	N/A	N/A	N/A	N/A	N/A	N/A	51.9	37.5	48.0	38.7	12.8	50	0.896

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	69.6	N/A	66.8	N/A	64.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	16.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 46.5	41.0	36.9	DB	20.6	76.1	4.6	3.8	17.2	78.9	14.5	81.1	11.9	83.3	8.6	86.1	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	36.7	36.1	38.3	43.4	49.7	53.8	57.8	59.4	55.9	49.4	43.1	39.6
	DBStd	9.49	5.39	5.47	4.49	4.78	6.15	3.78	4.42	3.15	3.71	4.13	5.81	6.25
	HDD50	2054	413	391	362	208	79	7	0	0	2	59	211	322
	HDD65	6580	878	810	827	647	476	335	229	176	273	485	657	787
	CDD50	963	0	0	0	11	70	122	243	293	181	40	3	0
	CDD65	13	0	0	0	0	2	0	7	3	1	0	0	0
	CDH74	21	0	0	0	0	4	0	17	0	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	18.0	21.8	20.2	17.3	16.1	16.5	16.0	15.5	15.6	17.5	19.0	18.4	21.8
Precipitation	PrecAvg	58.5	5.3	3.8	4.4	3.0	3.3	3.3	4.0	5.2	6.5	7.2	7.2	5.7
	PrecMax	81.9	13.7	10.3	9.2	7.1	8.3	6.7	11.8	10.5	11.3	12.0	12.5	10.7
	PrecMin	44.6	0.3	0.0	0.1	0.1	0.1	0.6	0.9	0.2	2.0	2.4	2.4	0.4
	PrecStd	9.1	3.0	2.4	2.6	1.5	1.9	1.3	2.4	2.9	2.3	2.8	2.7	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.7	45.5	48.2	61.0	71.7	68.1	76.2	70.9	68.6	59.5	54.2	50.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	45.8	44.0	45.4	57.0	66.8	64.3	70.6	68.1	64.7	57.5	52.6	48.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	45.0	43.4	44.1	53.6	62.6	61.3	66.5	65.7	62.5	56.0	51.4	47.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	44.1	42.7	43.4	50.4	58.9	59.3	64.0	64.1	61.0	54.7	50.2	46.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.4	5.3	5.5	7.0	6.8	6.3	6.2	6.0	6.0	5.9	5.4	5.6
		MCDBR	6.3	4.9	5.5	11.0	12.7	10.0	10.1	7.6	7.2	6.1	5.1	5.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.311	0.333	0.352	0.383	0.370	0.363	0.377	0.380	0.361	0.342	0.315	0.289	
	taud	2.180	2.273	2.323	2.298	2.402	2.449	2.429	2.419	2.461	2.397	2.254	2.139	
	Ebn at Noon	158	217	250	261	274	277	270	260	247	214	157	125	
	Edh at Noon	16	23	29	35	34	33	33	31	25	20	15	12	
All-Sky Solar Radiation	RadAvg	101	298	700	1215	1640	1789	1602	1233	797	381	140	67	
	RadStd	17	51	71	119	182	183	167	100	75	48	23	8	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-220	N/A	N/A

Nomenclature: See separate page