

OKSOY FYR, Norway

WMO: 014480

Lat: 58.073N

Lon: 8.053E

Elev: 8

StdP: 101.23

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.1	-6.1	-12.1	1.3	-5.5	-10.2	1.6	-3.8	17.6	1.3	16.3	0.3	6.7	0	0.757

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	22.4	18.2	21.2	17.4	20.0	16.6	19.1	21.5	18.1	20.5	17.2	19.3	5.9	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.0	21.0	17.0	12.1	19.5	16.1	11.5	18.7	54.3	21.6	51.0	20.6	48.3	19.4	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	14.2	12.7	DB	-9.6	23.7	2.5	1.6	-11.4	24.8	-12.8	25.8	-14.2	26.7	-16.0	27.9	(4)
(5)			WB	-10.2	19.8	2.3	1.3	-11.9	20.7	-13.3	21.4	-14.6	22.1	-16.2	23.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	1.7	1.3	2.9	6.0	10.1	13.8	16.5	16.6	13.6	9.5	5.7	2.9		
	DBStd	6.19	3.60	3.61	2.86	2.34	2.62	2.17	2.06	2.04	1.96	2.58	3.26	4.08		
	HDD10.0	1269	258	243	222	122	29	1	0	0	1	40	132	220		
	HDD18.3	3639	517	477	480	371	256	138	64	62	143	274	380	478		
	CDD10.0	691	0	0	0	2	33	114	202	206	108	24	2	0		
	CDD18.3	18	0	0	0	0	0	1	8	9	0	0	0	0		
	CDH23.3	9	0	0	0	0	0	1	4	4	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	6.3	7.5	6.8	6.5	5.8	5.8	5.3	5.5	5.6	6.3	6.8	7.1	7.0		
(15) Precipitation	PrecAvg	1382	153	100	78	71	77	83	83	126	136	165	164	138		
	PrecMax	1940	410	287	153	180	175	206	221	255	300	317	443	292		
	PrecMin	776	25	12	9	11	5	3	2	10	36	55	40	34		
	PrecStd	276	82	64	39	41	44	52	52	59	65	72	89	65		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	8.7	11.0	14.1	20.3	22.1	23.8	24.0	19.4	15.4	12.7	10.4		
		MCWB	7.3	6.7	7.1	10.2	15.6	16.1	19.2	19.8	15.4	13.1	11.2	9.2		
	2%	DB	7.9	7.4	8.3	12.1	17.6	20.3	22.5	22.5	18.1	14.3	11.8	9.7		
		MCWB	6.5	5.9	5.2	8.6	13.2	15.4	18.3	18.6	15.1	12.7	10.5	8.5		
	5%	DB	7.2	6.7	7.2	10.7	15.7	18.7	21.2	21.3	17.3	13.7	10.9	9.0		
		MCWB	6.0	5.6	4.9	7.6	12.1	14.5	17.5	17.9	14.9	12.2	9.6	7.8		
	10%	DB	6.5	6.0	6.2	9.5	14.1	17.3	20.1	20.1	16.7	13.1	10.1	8.2		
		MCWB	5.4	5.0	4.6	6.8	11.1	13.8	16.7	17.1	14.5	11.7	8.9	7.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	7.4	7.6	11.2	15.8	17.5	20.2	20.7	17.3	14.1	11.7	9.7		
		MCDB	8.5	8.0	9.9	13.3	19.5	20.7	23.0	22.9	18.1	14.7	12.4	10.1		
	2%	WB	6.9	6.6	6.2	9.1	13.8	16.1	19.0	19.6	16.3	13.3	10.7	8.8		
		MCDB	7.5	7.1	7.4	11.3	16.4	18.9	21.5	21.9	17.3	13.9	11.5	9.4		
	5%	WB	6.3	5.8	5.6	8.2	12.6	15.2	18.0	18.5	15.5	12.7	9.9	8.0		
		MCDB	7.0	6.4	6.6	10.0	14.9	17.8	20.7	20.7	16.7	13.4	10.6	8.8		
	10%	WB	5.6	5.1	5.0	7.4	11.5	14.4	17.2	17.5	14.9	12.0	9.1	7.2		
		MCDB	6.4	5.8	6.0	8.8	13.4	16.7	19.5	19.6	16.2	12.9	10.0	8.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.5	3.9	4.3	4.5	4.7	4.5	4.5	4.0	3.6	3.5	3.5		
		MCDBR	3.7	3.6	5.1	5.9	6.4	6.5	6.0	5.7	4.7	3.5	3.7	3.2		
	5% WB	MCWBR	3.9	3.2	3.6	3.8	4.0	4.2	3.9	3.8	3.6	3.2	4.1	3.6		
		MCWBR	3.4	3.1	4.2	4.7	5.4	5.3	5.1	5.0	3.7	3.1	3.6	3.3		
(40) Clear-Sky Solar Irradiance	taub		0.301	0.327	0.344	0.386	0.375	0.362	0.380	0.382	0.360	0.338	0.310	0.279		
		taud	2.240	2.320	2.366	2.299	2.406	2.468	2.435	2.425	2.475	2.443	2.301	2.193		
	Ebn at Noon		536	704	803	820	859	877	850	819	783	689	523	437		
		Edh at Noon	48	71	88	110	106	101	102	97	79	62	45	37		
(44) All-Sky Solar Radiation	RadAvg		0.34	0.91	2.31	3.90	5.27	5.93	5.39	4.15	2.69	1.26	0.46	0.24		
	RadStd		0.07	0.19	0.22	0.47	0.58	0.48	0.54	0.29	0.29	0.19	0.10	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-120	-161	N/A	N/A

Nomenclature: See separate page