

LYNGOR FYR, Norway

WMO: 014670

Lat: 58.636N

Lon: 9.148E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.1	18.5	5.7	7.4	22.4	9.4	8.9	24.5	34.1	34.0	31.6	35.7	9.6	10	0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	73.3	63.9	71.2	62.7	69.3	61.4	66.2	71.1	64.6	69.3	62.9	67.5	9.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.1	89.5	69.5	62.4	84.3	67.6	60.8	79.7	66.0	30.9	71.3	29.6	69.5	28.5	67.6	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
29.5	26.4	23.2	DB	13.1	77.2	4.1	3.4	10.1	79.6	7.7	81.6	5.3	83.4	2.3	85.9
			WB	12.2	67.5	4.0	1.8	9.4	68.8	7.1	69.9	4.8	70.9	2.0	72.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	33.5	32.9	36.7	43.2	51.5	58.3	63.0	62.4	56.5	48.3	41.1	35.4
	DBStd	12.18	7.04	7.28	6.04	4.85	5.36	4.17	3.84	3.67	3.80	4.96	6.21	7.84
	HDD50	2475	513	478	413	212	42	0	0	0	3	90	270	454
	HDD65	6629	978	898	877	655	420	206	87	100	255	518	716	919
	CDD50	1371	0	0	1	7	88	249	404	384	198	37	3	0
	CDD65	51	0	0	0	0	1	5	26	19	0	0	0	0
	CDH74	48	0	0	0	0	1	6	33	8	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.7	12.3	11.5	11.0	9.6	9.8	9.8	9.4	9.9	11.0	11.5	12.0	11.1
Precipitation	PrecAvg	45.8	4.4	3.0	1.9	2.5	2.9	3.1	3.5	5.0	4.6	5.4	5.4	3.9
	PrecMax	62.8	11.3	8.9	5.0	7.0	6.9	6.9	7.6	8.6	11.6	13.4	18.3	7.2
	PrecMin	31.1	0.5	0.3	0.0	0.2	0.3	0.3	0.7	0.9	1.8	0.8	1.4	1.4
	PrecStd	8.3	2.7	1.9	1.5	1.6	1.6	1.6	1.8	2.3	2.7	2.9	3.6	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.1	50.0	56.0	60.6	70.8	73.9	77.7	75.0	68.3	60.3	55.4	51.3
		MCWB	44.1	42.7	45.9	50.5	58.4	60.0	65.2	64.6	58.8	53.6	51.5	48.5
	2%	DB	45.8	46.6	49.9	55.9	65.9	70.1	73.9	72.7	65.7	58.2	53.3	48.9
		MCWB	42.1	40.8	42.0	47.5	55.9	58.5	64.1	64.8	57.9	53.6	50.1	46.3
	5%	DB	44.1	44.0	46.5	52.9	62.2	67.2	71.7	70.8	63.9	56.6	51.3	47.3
		MCWB	41.3	40.3	39.8	45.3	53.7	57.4	62.9	63.5	57.8	52.8	48.4	44.8
	10%	DB	42.5	42.3	44.0	50.5	59.3	64.8	69.7	68.9	62.5	55.3	49.5	45.4
		MCWB	39.9	39.5	38.9	44.3	51.8	56.3	62.1	61.9	57.5	52.1	46.7	42.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.1	44.3	46.9	52.5	60.2	63.6	68.0	68.6	63.1	56.9	52.9	49.3
		MCDB	46.9	47.0	54.8	58.5	67.7	69.5	73.5	72.5	65.4	58.6	54.3	50.2
	2%	WB	43.4	42.6	43.2	48.6	57.7	61.0	66.2	66.7	61.1	55.2	50.8	47.2
		MCDB	45.1	44.6	47.7	53.6	63.7	66.7	71.6	71.0	63.5	56.9	52.5	48.6
	5%	WB	41.9	41.3	41.5	47.0	55.3	59.5	64.7	65.0	59.8	54.0	49.0	45.1
		MCDB	43.6	43.5	44.6	51.2	60.5	64.7	69.8	69.5	62.4	55.8	51.0	46.8
	10%	WB	40.4	39.6	40.2	45.3	53.2	58.1	63.2	63.3	58.5	52.8	47.2	43.2
		MCDB	42.2	41.8	43.0	48.9	57.8	62.9	68.1	67.6	61.3	54.9	49.3	45.0
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.2	8.3	8.4	8.6	8.6	8.7	8.5	8.2	7.3	6.7	6.7
		MCDBR	8.3	9.5	12.5	12.3	12.3	12.1	11.6	9.6	9.9	8.4	8.4	7.7
		MCWBR	7.6	6.7	7.7	7.2	7.1	7.6	7.0	6.7	7.0	6.7	7.9	7.5
	5% WB	MCDBR	7.1	7.7	10.8	9.8	10.2	9.2	9.1	8.3	7.7	6.6	7.8	7.2
		MCWBR	7.0	6.5	7.2	6.5	6.7	7.0	6.4	6.9	6.7	6.6	7.9	7.4
Clear-Sky Solar Irradiance	taub	0.288	0.321	0.340	0.379	0.372	0.357	0.378	0.377	0.351	0.336	0.304	0.266	
	taud	2.242	2.320	2.366	2.325	2.417	2.481	2.441	2.439	2.503	2.447	2.302	2.181	
	Ebn at Noon	170	223	255	262	273	279	270	261	251	217	163	136	
	Edh at Noon	15	22	28	34	33	31	32	30	24	19	14	11	
All-Sky Solar Radiation	RadAvg	106	289	745	1238	1651	1885	1711	1320	852	388	142	74	
	RadStd	23	61	67	175	188	136	174	84	103	63	36	10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+2.88	N/A	N/A	-1.89	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page