

AURSKOG, Norway

WMO: 014840

Lat: 59.9119N

Lon: 11.5800E

Elev: 420

StdP: 14.47

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.8	(c) -2.7	(d) -14.0	(e) 2.6	(f) -9.9	(g) -6.6	(h) 3.9	(i) -2.8	(j) 21.0	(k) 35.8	(l) 18.8	(m) 35.9	(n) 3.4	(o) 0	(p) 0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	80.2	61.7	76.7	61.0	72.8	59.3	64.8	74.7	63.0	72.3	61.3	69.4	6.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.3	82.2	67.8	59.5	77.0	65.7	57.9	72.8	64.3	30.0	74.9	28.7	72.2	27.5	70.0	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.1	(b) 15.9	(c) 13.9	(e) -14.2	(f) 84.0	(g) 6.9	(h) 4.4	(i) -19.2	(j) 87.2	(k) -23.3	(l) 89.8	(m) -27.1	(n) 92.3	(o) -32.2	(p) 95.5		
(4) 18.1	(5) 15.9	(6) 13.9	(7) -14.6	(8) 67.2	(9) 6.9	(10) 2.2	(11) -19.5	(12) 68.8	(13) -23.6	(14) 70.1	(15) -27.4	(16) 71.3	(17) -32.4	(18) 72.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.2	21.8	23.8	31.0	40.5	49.9	55.9	60.4	57.6	51.2	41.3	33.5	26.8		
	DBStd	15.31	11.66	10.64	8.44	6.21	7.58	5.03	4.85	4.14	6.05	6.66	8.30	10.18		
	HDD50	4150	874	734	590	291	97	8	1	1	57	281	497	719		
	HDD65	8692	1339	1154	1055	734	468	277	156	230	414	735	946	1184		
	CDD50	953	0	0	0	8	95	184	324	238	93	11	0	0		
	CDD65	21	0	0	0	0	1	3	15	2	0	0	0	0		
	CDH74	603	0	0	0	0	73	137	352	40	1	0	0	0		
	CDH80	103	0	0	0	0	5	19	79	0	0	0	0	0		
	WSAvg	5.9	5.6	5.6	6.0	6.1	6.5	6.4	5.7	5.6	6.0	5.8	5.9	5.9		
	PrecAvg	30.3	2.2	1.5	1.4	1.7	2.0	3.0	3.3	3.5	3.0	3.1	3.0	2.4		
	PrecMax	41.4	5.4	3.6	4.4	3.1	3.5	5.5	7.0	6.3	6.5	8.2	8.3	4.7		
(15) Precipitation	PrecMin	22.4	0.2	0.4	0.0	0.2	0.3	0.7	0.4	1.0	0.9	0.9	0.7	0.5		
	PrecStd	4.8	1.3	0.9	0.9	0.8	1.0	1.2	1.6	1.4	1.3	1.6	1.9	1.3		
	DB	42.9	44.0	59.2	67.5	80.2	82.5	86.4	78.2	71.7	60.5	51.9	48.2			
	MCWB	40.7	38.9	46.2	51.3	58.2	61.0	64.4	61.9	60.0	54.6	49.8	45.9			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	40.3	40.6	51.1	64.3	75.6	78.2	82.1	74.4	68.3	56.7	48.9	45.3			
	2% MCWB	38.5	37.7	42.1	50.4	57.6	59.8	63.9	60.6	57.3	52.0	46.8	43.2			
	5% DB	38.2	38.6	45.6	59.3	70.7	72.9	78.0	70.8	64.8	54.8	46.8	42.6			
	5% MCWB	36.5	36.6	38.6	47.7	55.7	57.8	63.0	59.2	55.9	51.3	44.7	40.6			
	10% DB	35.8	36.8	42.3	54.5	66.1	68.8	74.1	67.9	62.0	52.4	44.7	39.9			
	10% MCWB	34.1	35.3	37.5	45.0	54.6	55.7	61.5	58.3	55.5	49.2	42.9	38.3			
	0.4% WB	41.4	40.8	47.9	53.8	62.6	63.7	68.2	65.4	62.5	55.7	50.3	46.6			
	0.4% MCDB	42.7	42.0	58.3	64.2	71.7	74.9	77.5	70.3	68.5	59.1	52.0	48.0			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	38.7	38.3	42.8	51.2	60.1	61.6	66.0	63.3	59.6	53.7	47.3	43.5			
	2% MCDB	39.7	39.8	49.5	62.0	70.7	73.4	77.6	70.1	64.2	55.7	48.7	45.2			
	5% WB	36.7	36.9	40.2	48.6	57.5	59.5	64.3	61.6	57.7	51.7	45.1	41.0			
	5% MCDB	38.0	38.3	44.0	57.4	67.7	70.3	75.3	67.7	62.9	54.0	46.5	42.3			
	10% WB	34.4	35.2	38.2	45.8	55.1	57.5	62.3	59.8	56.0	49.5	43.1	38.4			
	10% MCDB	35.6	36.7	41.8	53.6	64.5	66.6	71.9	65.2	61.1	52.1	44.8	39.8			
	MDBR	12.0	14.2	18.1	21.1	21.3	21.1	21.6	19.3	19.2	14.3	9.7	11.2			
	5% DB	10.2	13.2	22.8	30.1	30.7	31.0	31.1	26.0	23.2	16.0	11.7	11.7			
(36) Mean Daily Temperature Range	MCWBR	9.4	10.5	14.7	17.7	15.4	15.0	15.1	14.2	14.5	11.8	10.5	10.9			
	5% WB	9.5	10.6	19.9	27.2	24.2	25.1	26.9	19.8	17.9	13.0	11.1	11.0			
	MCWBR	8.9	8.8	13.5	16.5	12.8	13.6	14.4	11.9	11.8	11.0	10.4	10.4			
	MCWBR	8.9	8.8	13.5	16.5	12.8	13.6	14.4	11.9	11.8	11.0	10.4	10.4			
(40) Clear-Sky Solar Irradiance	taub	0.262	0.303	0.327	0.368	0.365	0.355	0.376	0.368	0.336	0.324	0.281	0.236			
	taud	2.213	2.296	2.352	2.331	2.406	2.456	2.416	2.433	2.512	2.454	2.291	2.127			
	Ebn at Noon	167	223	256	263	274	279	269	261	253	215	159	128			
	Edh at Noon	13	21	27	33	33	32	33	30	23	18	12	9			
(44) All-Sky Solar Radiation	RadAvg	91	284	756	1196	1554	1779	1589	1250	830	367	122	60			
	RadStd	17	52	81	162	158	130	205	101	96	71	33	6			

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (58 neighbors)		N/A	N/A	+2.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page