

OSEBERG PLATFORM, Norway

WMO: 014843

Lat: 60.491N

Lon: 2.826E

Elev: 49

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.1	31.9	13.8	11.1	32.9	17.5	13.3	35.2	68.4	38.8	64.5	38.4	22.7	140	1.119

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	65.9	59.2	62.6	58.3	60.7	57.3	60.5	63.5	59.3	61.6	58.1	60.2	14.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.2	75.3	61.6	57.6	71.0	59.8	57.1	69.7	59.3	26.8	63.8	25.8	60.9	24.9	60.0	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 60.0	53.1	47.9	DB	28.0	70.2	3.4	4.3	25.6	73.3	23.6	75.8	21.7	78.2	19.3	81.3	(4)
(5)			WB	24.8	62.3	3.7	2.6	22.1	64.2	19.9	65.7	17.8	67.1	15.1	69.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	40.3	40.3	41.2	43.8	47.2	51.7	55.9	57.0	54.3	49.5	45.2	42.2		
	DBStd	6.90	3.72	3.72	3.51	3.52	4.28	2.73	3.74	2.61	2.97	3.23	3.94	4.22		
	HDD50	1592	302	273	272	190	106	12	0	0	4	44	146	243		
	HDD65	6423	767	693	737	638	550	400	287	249	320	481	594	707		
	CDD50	648	0	0	0	2	20	63	183	216	133	29	2	0		
	CDD65	4	0	0	0	0	0	0	4	0	0	0	0	0		
	CDH74	3	0	0	0	0	0	0	3	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	24.2	29.5	28.5	24.7	21.7	20.8	20.3	19.5	20.1	23.5	26.0	26.5	29.3		
(15) Precipitation	PrecAvg	73.1	8.0	6.7	6.2	4.3	3.3	3.9	4.4	5.6	6.5	7.8	7.8	8.8		
	PrecMax	96.5	14.3	13.5	12.6	8.4	5.1	8.7	6.9	10.0	11.4	14.1	14.4	15.7		
	PrecMin	51.8	1.5	0.6	1.3	1.1	0.8	0.5	1.0	2.2	2.2	2.4	1.8	2.2		
	PrecStd	11.3	3.4	3.1	2.7	1.5	1.1	1.8	1.4	1.8	2.9	2.7	3.3	3.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	48.2	49.8	55.4	66.2	63.0	73.2	66.3	62.8	57.4	52.2	50.4		
		MCWB	47.6	46.7	46.2	46.7	56.4	56.9	63.2	57.7	56.7	53.3	49.5	48.7		
	2%	DB	47.9	46.7	47.9	51.9	59.1	58.6	68.1	63.0	60.8	55.5	51.9	49.7		
		MCWB	47.3	45.6	45.9	46.4	51.8	54.3	62.0	58.6	55.9	52.1	49.3	48.3		
	5%	DB	46.6	46.3	46.5	49.8	55.4	55.7	64.0	62.2	59.2	54.0	50.4	48.4		
		MCWB	45.5	45.2	45.0	45.5	50.0	52.8	59.1	58.4	55.8	50.7	48.5	47.2		
	10%	DB	46.0	44.9	45.0	48.1	52.0	55.1	60.7	60.7	58.6	53.6	50.0	47.9		
		MCWB	44.6	43.3	43.2	45.5	49.0	52.3	57.9	57.7	55.5	50.3	48.3	46.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.7	46.8	47.3	48.8	57.5	58.6	64.9	61.5	59.2	55.0	51.9	49.9		
		MCDB	47.8	47.0	47.8	50.6	65.1	62.7	69.4	63.6	60.8	56.2	52.2	50.2		
	2%	WB	46.8	45.9	46.2	47.6	53.2	55.4	62.2	60.0	57.8	53.6	50.3	48.4		
		MCDB	47.0	46.2	46.8	49.2	57.5	57.4	67.6	61.9	59.3	55.0	50.7	48.7		
	5%	WB	45.6	45.0	45.1	46.6	51.3	54.1	59.9	59.2	56.9	52.4	49.5	47.5		
		MCDB	46.1	45.5	45.8	48.2	53.9	55.7	63.3	60.8	58.5	53.9	50.1	48.0		
	10%	WB	44.1	43.8	44.0	45.7	49.5	53.1	58.1	58.2	55.9	51.4	48.4	46.3		
		MCDB	45.1	44.5	44.8	47.3	51.2	54.6	60.4	60.1	57.8	53.0	49.3	47.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	4.8	4.7	4.9	5.0	4.1	4.2	4.3	4.1	4.2	4.4	5.1		
		MCDBR	4.8	5.1	5.1	6.2	9.6	5.5	8.0	5.7	5.0	4.6	4.6	5.1		
	5% WB	MCWBR	6.0	6.0	5.3	4.3	5.4	4.3	5.1	4.2	4.1	5.0	5.3	6.2		
		MCWBR	4.6	4.8	4.5	5.2	8.1	5.1	6.8	4.7	4.2	4.7	4.6	4.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.330	0.351	0.365	0.382	0.369	0.364	0.380	0.375	0.366	0.347	0.322	0.404		
		taud	2.091	2.216	2.289	2.305	2.414	2.467	2.440	2.451	2.433	2.327	2.157	2.413		
	Edn at Noon	Edn at Noon	121	196	238	258	272	275	267	259	239	197	124	81		
		Edh at Noon	15	23	29	34	33	31	32	29	25	20	13	10		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	67	235	607	1179	1653	1697	1541	1193	729	345	107	43		
	RadStd	RadStd	9	39	81	119	113	176	116	93	57	41	13	3		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)		N/A	+1.17	N/A	N/A	N/A	N/A	-149	-212	N/A	N/A

Nomenclature: See separate page