

OSEBERG PLATFORM, Norway

WMO: 014843

Lat: 60.491N

Lon: 2.826E

Elev: 15

StdP: 101.14

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.0	0.0	-10.1	1.6	0.5	-8.1	1.9	1.8	30.6	3.8	28.8	3.6	10.2	140	1.119

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	18.8	15.1	17.0	14.6	16.0	14.1	15.8	17.5	15.1	16.4	14.5	15.7	6.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.1	10.8	16.4	14.2	10.1	15.5	14.0	10.0	15.2	44.4	17.7	42.2	16.1	40.1	15.5	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.8	23.8	21.4	DB	-2.2	21.2	1.9	2.4	-3.5	22.9	-4.6	24.3	-5.7	25.7	-7.1	27.4	(4)
(5)			WB	-4.0	16.8	2.1	1.4	-5.5	17.9	-6.7	18.7	-7.9	19.5	-9.4	20.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	4.6	4.6	5.1	6.5	8.5	10.9	13.3	13.9	12.4	9.7	7.3	5.7	(6)	
	DBStd	3.83	2.07	2.07	1.95	1.95	2.38	1.52	2.08	1.45	1.65	1.80	2.19	2.34	(7)	
	HDD10.0	884	168	152	151	106	59	7	0	0	2	24	81	135	(8)	
	HDD18.3	3568	426	385	409	354	306	222	159	138	178	267	330	393	(9)	
	CDD10.0	360	0	0	0	1	11	35	102	120	74	16	1	0	(10)	
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0	(11)	
	CDH23.3	2	0	0	0	0	0	0	2	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	10.8	13.2	12.7	11.1	9.7	9.3	9.1	8.7	9.0	10.5	11.6	11.8	13.1	(14)	
(15) Precipitation	PrecAvg	1857	203	170	158	110	83	98	111	141	165	197	198	223	(15)	
	PrecMax	2451	364	342	321	214	130	220	174	253	289	357	367	398	(16)	
	PrecMin	1315	37	16	34	28	20	12	26	55	56	61	46	55	(17)	
	PrecStd	286	86	78	69	38	28	45	36	46	73	69	84	88	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	9.0	9.9	13.0	19.0	17.2	22.9	19.1	17.1	14.1	11.2	10.2	(19)	
		MCWB	8.7	8.2	7.9	8.2	13.6	13.8	17.3	14.3	13.7	11.8	9.7	9.3	(20)	
	2%	DB	8.8	8.2	8.9	11.0	15.1	14.8	20.0	17.2	16.0	13.1	11.0	9.8	(21)	
		MCWB	8.5	7.5	7.7	8.0	11.0	12.4	16.7	14.8	13.3	11.2	9.6	9.0	(22)	
	5%	DB	8.1	7.9	8.1	9.9	13.0	13.2	17.8	16.8	15.1	12.2	10.2	9.1	(23)	
		MCWB	7.5	7.3	7.2	7.5	10.0	11.6	15.0	14.7	13.2	10.4	9.2	8.5	(24)	
	10%	DB	7.8	7.2	7.2	9.0	11.1	12.8	15.9	15.9	14.8	12.0	10.0	8.8	(25)	
		MCWB	7.0	6.3	6.2	7.5	9.5	11.3	14.4	14.3	13.1	10.2	9.0	8.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	8.2	8.5	9.3	14.2	14.8	18.3	16.4	15.1	12.8	11.1	9.9	(27)	
		MCDB	8.8	8.3	8.8	10.3	18.4	17.1	20.8	17.5	16.0	13.4	11.2	10.1	(28)	
	2%	WB	8.2	7.7	7.9	8.7	11.8	13.0	16.8	15.6	14.4	12.0	10.2	9.1	(29)	
		MCDB	8.3	7.9	8.2	9.6	14.1	14.1	19.8	16.6	15.2	12.8	10.4	9.3	(30)	
	5%	WB	7.6	7.2	7.3	8.1	10.7	12.3	15.5	15.1	13.9	11.3	9.7	8.6	(31)	
		MCDB	7.8	7.5	7.6	9.0	12.2	13.2	17.4	16.0	14.7	12.2	10.0	8.9	(32)	
	10%	WB	6.7	6.5	6.7	7.6	9.7	11.7	14.5	14.6	13.3	10.8	9.1	8.0	(33)	
		MCDB	7.3	6.9	7.1	8.5	10.7	12.5	15.8	15.6	14.3	11.7	9.6	8.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	2.7	2.6	2.7	2.8	2.3	2.3	2.4	2.3	2.3	2.5	2.8	(35)	
		MCDBR	2.7	2.8	2.8	3.5	5.3	3.1	4.4	3.2	2.8	2.6	2.6	2.8	(36)	
	5% WB	MCWBR	3.3	3.3	2.9	2.4	3.0	2.4	2.8	2.4	2.3	2.8	3.0	3.5	(37)	
		MCWBR	2.6	2.7	2.5	2.9	4.5	2.8	3.8	2.6	2.4	2.6	2.5	2.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.330	0.351	0.365	0.382	0.369	0.364	0.380	0.375	0.366	0.347	0.322	0.404	(40)	
		taud	2.091	2.216	2.289	2.305	2.414	2.467	2.440	2.451	2.433	2.327	2.157	2.413	(41)	
	Edn at Noon	Edn at Noon	380	617	750	812	857	867	841	815	752	622	392	256	(42)	
		Edh at Noon	46	72	91	107	103	99	100	92	79	63	42	31	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.21	0.74	1.92	3.72	5.21	5.35	4.86	3.76	2.30	1.09	0.34	0.13	(44)	
	RadStd	RadStd	0.03	0.12	0.25	0.38	0.36	0.56	0.36	0.29	0.18	0.13	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page