

STATFJORD B OIL PLATFORM, Norway

WMO: 014881

Lat: 61.206N

Lon: 1.829E

Elev: 142

StdP: 99.63

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 0.1	(c) 1.1	(d) -8.2	(e) 1.9	(f) 2.2	(g) -6.9	(h) 2.1	(i) 2.5	(j) 37.5	(k) 5.7	(l) 34.5	(m) 5.7	(n) 10.6	(o) 320	(p) 1.161

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.7	(c) 18.2	(d) 15.0	(e) 16.2	(f) 14.2	(g) 15.8	(h) 14.0	(i) 15.7	(j) 17.7	(k) 15.0	(l) 16.2	(m) 14.3	(n) 15.4	(o) 10.0	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.8	16.4	14.2	10.3	15.4	13.9	10.1	15.1	44.6	17.4	42.4	16.3	40.6	15.1	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	24.4	22.0		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	-3.4	16.5	1.6	1.1	-4.5	17.3	-5.4	17.9	-6.3	18.5	-7.5	19.3
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	5.3	5.3	5.6	6.6	8.6	10.7	13.1	13.7	12.0	9.9	7.6	5.9
	DBStd	3.57	1.90	1.79	1.98	2.11	2.22	1.54	2.20	1.35	1.68	1.74	2.10	2.38
	HDD10.0	807	145	132	138	102	53	9	0	0	3	22	74	128
	HDD18.3	3513	403	366	396	351	302	228	163	144	189	262	321	387
	CDD10.0	338	0	0	0	2	10	31	97	114	63	19	3	0
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	11.3	13.6	13.7	11.8	10.3	9.5	9.2	8.6	9.3	11.1	12.1	12.7	14.0
(15) Precipitation	PrecAvg	1341	161	132	127	72	48	65	81	100	117	141	139	156
	PrecMax	1652	252	257	237	123	83	132	153	162	190	216	220	240
	PrecMin	954	76	58	46	26	22	26	40	66	48	58	43	65
	PrecStd	165	48	53	46	23	16	24	22	25	34	41	39	42
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	9.2	9.2	12.9	16.9	15.9	22.2	19.0	16.9	14.2	12.1	10.8
		MCWB	8.7	8.6	8.1	8.6	13.0	13.4	16.5	14.6	14.9	11.8	10.5	9.8
	2%	DB	9.1	8.9	9.1	11.0	14.0	14.1	19.9	17.1	15.9	13.1	11.2	10.1
		MCWB	8.6	8.4	8.1	8.4	10.5	12.0	16.4	14.3	13.6	11.1	9.8	9.5
	5%	DB	8.9	8.2	8.8	9.9	12.1	13.2	17.8	16.1	15.0	12.2	11.0	9.8
		MCWB	8.3	7.5	7.8	8.1	9.6	11.5	15.3	14.1	13.4	10.5	9.7	9.2
	10%	DB	8.1	7.9	8.1	9.1	11.1	12.8	16.0	15.2	14.1	12.0	10.2	9.1
		MCWB	7.2	7.2	6.9	7.7	9.4	11.3	14.5	13.7	12.9	10.4	9.1	8.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	8.8	8.8	9.7	13.2	13.8	17.6	15.7	15.2	12.8	11.2	10.2
		MCDB	9.2	8.8	8.9	10.3	16.0	15.1	20.5	17.5	16.4	13.5	11.7	10.3
	2%	WB	8.7	8.2	8.3	9.1	11.4	12.6	16.5	15.1	14.3	12.0	10.7	9.7
		MCDB	8.9	8.4	8.6	9.8	13.4	13.7	19.5	16.4	15.1	12.8	11.2	9.8
	5%	WB	8.0	7.7	7.9	8.5	10.4	12.1	15.5	14.7	13.8	11.5	10.1	9.1
		MCDB	8.4	7.9	8.3	9.2	11.4	13.0	17.5	15.8	14.6	12.3	10.6	9.3
	10%	WB	7.2	6.9	7.1	7.9	9.9	11.6	14.7	14.2	13.2	11.0	9.6	8.4
		MCDB	7.8	7.5	7.6	8.7	10.6	12.6	16.0	15.3	14.2	11.8	10.2	8.9
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	2.5	2.7	2.8	3.0	2.4	2.8	2.7	2.3	2.4	2.4	2.8
		MCDBR	2.5	2.5	2.7	3.3	4.7	3.4	4.8	3.6	2.9	2.6	2.5	2.9
	5% WB	MCWBR	3.1	3.4	3.2	2.6	3.1	2.4	2.8	2.7	2.3	2.6	2.9	3.9
		MCDWR	2.4	2.4	2.6	2.6	4.2	3.1	4.2	3.1	2.7	2.6	2.3	2.7
(40) Clear-Sky Solar Irradiance	taub		0.323	0.347	0.360	0.373	0.362	0.354	0.372	0.362	0.357	0.338	0.309	0.385
		taud	2.065	2.202	2.290	2.328	2.429	2.487	2.453	2.479	2.450	2.324	2.129	2.351
	Ebn at Noon		355	606	749	818	862	875	846	826	757	618	372	224
		Edh at Noon	44	70	89	103	101	97	98	88	77	61	39	28
(44) All-Sky Solar Radiation	RadAvg		0.19	0.68	1.81	3.53	4.94	5.07	4.59	3.64	2.20	1.03	0.30	0.12
	RadStd		0.02	0.09	0.21	0.31	0.35	0.56	0.40	0.33	0.18	0.13	0.04	0.01

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	+0.69	N/A	N/A	N/A	N/A	-99	-142	N/A	N/A

Nomenclature: See separate page