

STORA SJOFALLET, Sweden

WMO: 020240

Lat: 67.495N

Lon: 18.291E

Elev: 425

StdP: 96.32

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.8	-25.4	-31.1	0.2	-27.8	-28.5	0.3	-25.4	24.5	-0.8	22.3	-1.3	4.9	130	0.967

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	22.1	14.7	19.8	13.7	17.8	13.0	15.7	20.4	14.6	18.5	13.5	16.9	4.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	10.3	17.3	12.7	9.6	16.5	11.7	9.0	15.5	45.4	20.5	42.3	18.6	39.3	17.1	19.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	17.5	15.1	DB	-30.4	24.2	1.9	1.6	-31.8	25.3	-32.9	26.3	-33.9	27.1	-35.3	28.3	(4)
(5)			WB	-31.2	16.8	2.1	0.9	-32.8	17.4	-34.0	17.9	-35.2	18.5	-36.7	19.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.6	-10.9	-10.6	-7.4	-1.6	4.2	9.0	13.3	12.1	7.6	1.5	-3.4	-7.3	(6)	
	DBStd	9.68	7.42	7.40	6.25	4.18	3.45	3.48	3.18	2.85	2.88	3.56	4.62	6.73	(7)	
	HDD10.0	3657	648	576	538	348	184	61	6	11	82	264	402	537	(8)	
	HDD18.3	6478	907	809	796	598	439	281	159	194	323	523	652	796	(9)	
	CDD10.0	226	0	0	0	0	4	30	108	76	9	0	0	0	(10)	
	CDD18.3	4	0	0	0	0	0	0	4	1	0	0	0	0	(11)	
	CDH23.3	23	0	0	0	0	1	2	18	3	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)	
(14) Wind	WSAvg	7.0	7.6	7.8	7.4	6.6	6.8	7.5	6.7	5.9	6.8	7.1	6.7	7.4	(14)	
(15) Precipitation	PrecAvg	755	60	46	44	38	51	75	102	87	68	61	61	61	(15)	
	PrecMax	994	114	80	75	72	97	131	162	157	159	118	132	140	(16)	
	PrecMin	522	7	7	18	11	14	26	26	33	23	16	22	17	(17)	
	PrecStd	116	21	20	16	18	24	27	35	36	30	24	29	24	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.7	4.6	4.8	9.4	19.9	22.4	25.4	23.0	16.3	11.2	6.8	4.7	(19)	
		MCWB	2.9	2.6	2.0	4.7	10.4	13.0	16.4	15.9	12.2	7.9	4.7	2.9	(20)	
	2%	DB	2.9	2.9	3.5	6.9	14.5	18.7	23.1	20.4	14.0	9.3	5.5	3.2	(21)	
		MCWB	1.4	1.4	1.6	3.6	8.5	11.7	15.2	14.5	10.6	6.9	4.1	1.6	(22)	
	5%	DB	1.1	1.6	2.1	5.2	11.6	16.4	21.0	18.2	12.6	7.9	4.1	1.8	(23)	
		MCWB	-0.1	0.3	0.4	2.7	7.0	10.7	14.4	13.8	9.9	5.9	2.8	0.3	(24)	
	10%	DB	-1.1	-0.2	0.7	3.8	9.3	14.7	18.8	16.7	11.6	6.4	2.4	0.6	(25)	
		MCWB	-2.0	-1.1	-0.7	1.7	5.7	9.9	13.5	12.8	9.3	4.7	1.2	-0.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	2.9	2.7	5.3	11.4	14.2	17.6	16.6	12.7	8.3	5.0	3.2	(27)	
		MCDB	4.5	4.4	4.2	8.1	19.3	18.2	22.6	21.6	15.0	10.4	6.3	4.5	(28)	
	2%	WB	1.6	1.6	1.6	4.0	8.9	12.8	16.2	15.2	11.3	7.1	4.2	1.7	(29)	
		MCDB	2.9	2.7	3.2	6.5	13.6	17.1	21.4	19.0	13.4	9.1	5.5	3.0	(30)	
	5%	WB	0.1	0.3	0.6	2.9	7.4	11.5	15.3	14.3	10.4	6.0	2.9	0.5	(31)	
		MCDB	1.3	1.4	2.0	5.2	11.3	15.7	19.8	17.8	12.2	7.8	4.0	1.6	(32)	
	10%	WB	-1.9	-1.2	-0.7	1.8	6.0	10.4	14.2	13.2	9.6	4.8	1.3	-0.6	(33)	
		MCDB	-1.0	-0.1	0.6	3.8	8.9	14.2	18.0	16.1	11.3	6.3	2.3	0.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.2	6.5	6.3	6.0	6.2	6.4	5.7	4.4	3.6	4.3	5.6	(35)	
		MCDBR	6.5	8.1	6.1	6.8	10.6	9.8	10.4	8.9	6.2	4.7	5.2	5.4	(36)	
	5% WB	MCWBR	5.7	7.0	4.8	4.6	5.8	4.7	4.4	4.3	4.0	3.4	4.0	4.8	(37)	
		MCWBR	6.3	8.0	6.1	6.4	9.9	8.9	8.7	8.0	5.1	4.3	5.1	5.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.173	0.235	0.276	0.303	0.320	0.325	0.334	0.320	0.289	0.253	0.177	N/A	(40)	
		taud	1.924	2.128	2.190	2.222	2.339	2.469	2.489	2.508	2.561	2.286	1.960	N/A	(41)	
	Ebn at Noon		167	598	770	849	875	881	860	836	784	575	145	0	(42)	
		Edh at Noon	11	47	79	102	102	93	88	78	57	40	9	0	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.05	0.49	1.92	3.87	4.94	4.99	4.58	3.38	1.80	0.61	0.11	0.00	(44)	
	RadStd		0.00	0.06	0.12	0.20	0.41	0.43	0.48	0.34	0.21	0.09	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page