

TARFALA, Sweden

WMO: 020290

Lat: 67.912N

Lon: 18.610E

Elev: 3760

StdP: 12.81

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.2	(c) -3.4	(d) -21.3	(e) 2.0	(f) 3.1	(g) -16.4	(h) 2.6	(i) 2.4	(j) 38.5	(k) 24.3	(l) 34.7	(m) 24.6	(n) 3.8	(o) 330	(p) 0.909

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	61.2	51.0	57.9	49.8	54.7	47.9	53.0	58.9	51.0	56.3	49.0	53.5	7.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
50.3	62.0	54.3	48.2	57.4	52.3	46.4	53.6	51.1	23.4	58.9	22.1	56.3	20.9	53.6	60.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 34.0	(b) 29.2	(c) 25.1	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 34.0	(b) 29.2	(c) 25.1	(e) -11.9	(f) 53.4	(g) 4.8	(h) 3.0	(i) -15.3	(j) 55.6	(k) -18.1	(l) 57.3	(m) -20.8	(n) 59.0	(o) -24.2	(p) 61.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	12.9	13.5	15.0	22.0	30.8	39.1	47.2	45.1	36.5	26.0	19.5	17.4
	DBStd	14.02	9.73	8.83	8.07	7.29	6.88	6.23	5.69	5.82	6.59	7.51	7.29	8.45
	HDD50	8393	1150	1021	1084	839	596	328	125	174	404	744	916	1012
	HDD65	13804	1615	1441	1549	1289	1061	776	551	616	854	1209	1366	1477
	CDD50	64	0	0	0	0	0	2	38	23	1	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.7	9.0	9.6	9.5	8.3	8.5	8.4	7.4	7.1	8.7	9.0	8.0	11.0
Precipitation	PrecAvg	32.5	3.1	2.6	2.5	1.7	1.9	2.4	3.1	3.0	3.1	3.3	2.6	3.3
	PrecMax	36.7	6.9	5.1	5.4	3.6	3.0	4.5	5.9	5.2	5.5	5.3	5.2	6.4
	PrecMin	26.2	0.4	0.4	0.8	0.7	0.7	0.5	1.0	1.3	1.0	1.3	0.7	1.2
	PrecStd	3.1	1.6	1.0	1.2	0.7	0.6	0.9	1.2	0.9	1.1	1.1	1.2	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.5	35.5	38.1	44.6	50.0	57.4	67.6	63.6	55.0	47.4	40.6	37.8
		MCWB	30.9	29.3	29.6	37.7	42.0	47.4	55.2	51.9	44.1	41.5	34.4	32.8
	2%	DB	32.4	31.9	32.5	39.8	46.7	54.0	63.3	60.0	50.7	42.0	36.0	34.4
		MCWB	29.2	28.9	28.3	34.1	39.4	45.2	52.8	50.8	44.0	36.9	32.8	31.1
	5%	DB	30.5	29.5	30.0	36.1	44.1	51.2	59.8	56.8	48.0	39.1	33.0	31.9
		MCWB	27.4	26.5	26.8	31.8	38.0	43.9	50.9	49.6	42.6	35.5	30.3	29.5
	10%	DB	27.5	27.1	27.1	32.8	40.7	48.4	56.4	54.0	45.5	37.1	30.5	28.8
		MCWB	24.3	24.5	24.4	29.7	36.0	42.5	49.2	48.3	41.4	34.2	27.9	26.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.2	31.9	31.5	37.7	42.6	49.8	56.6	56.1	48.3	42.9	35.7	34.1
		MCDB	34.1	33.1	35.0	43.4	48.7	52.9	63.5	60.8	50.8	47.1	39.5	36.6
	2%	WB	29.6	28.6	28.7	35.1	40.3	47.5	53.9	52.7	45.6	38.4	32.9	31.6
		MCDB	32.0	31.3	32.1	39.0	45.6	51.5	60.9	57.4	48.6	40.6	36.1	33.9
	5%	WB	27.5	26.5	26.8	32.5	38.1	45.1	52.0	50.6	43.5	36.4	30.3	29.4
		MCDB	30.3	29.6	30.0	35.7	42.6	49.9	58.2	55.7	46.3	38.5	32.9	32.1
	10%	WB	24.4	24.4	24.5	30.0	36.2	43.1	50.1	48.6	41.8	34.3	27.9	26.1
		MCDB	27.2	27.3	27.1	32.6	39.9	47.7	55.3	52.8	44.7	36.7	30.3	28.3
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.0	9.3	9.7	8.5	8.9	9.9	8.4	7.3	8.0	9.0	9.7
		MCDBR	11.5	11.7	10.9	11.1	10.8	12.6	14.3	12.6	10.5	9.7	10.7	11.7
		MCWBR	10.3	10.5	9.4	8.6	8.1	7.7	7.9	7.8	7.6	7.7	9.4	10.6
	5% WB	MCDBR	11.0	11.3	10.2	9.8	10.2	11.2	12.4	10.9	8.6	9.5	10.4	10.9
		MCWBR	10.5	10.7	9.2	8.2	8.0	7.7	7.7	7.8	7.3	8.2	9.3	10.2
Clear-Sky Solar Irradiance	taub	0.153	0.210	0.248	0.271	0.287	0.293	0.300	0.289	0.262	0.225	0.157	N/A	
	taud	1.921	2.152	2.242	2.279	2.379	2.500	2.549	2.560	2.589	2.295	1.954	N/A	
	Ebn at Noon	53	202	258	282	289	291	285	277	260	195	45	0	
	Edh at Noon	3	14	23	30	31	28	26	23	17	12	2	0	
All-Sky Solar Radiation	RadAvg	12	146	595	1216	1572	1574	1449	1057	561	187	31	0	
	RadStd	1	16	36	58	120	131	144	98	58	27	3	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page