

SAITTAROVA, Sweden

WMO: 020640

Lat: 67.3363N

Lon: 22.2288E

Elev: 787

StdP: 14.28

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.3	-15.1	-27.9	1.2	-21.0	-21.0	1.8	-14.8	21.0	27.7	18.8	28.1	0.9	350	0.691

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	75.8	61.1	72.3	59.5	68.9	58.0	64.0	72.6	61.7	68.9	59.7	66.1	6.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.8	81.8	66.9	58.6	75.6	64.4	56.8	70.7	62.6	29.7	73.1	27.9	68.7	26.5	66.4	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	15.1	13.2	-26.1	79.3	5.5	4.1	-30.1	82.3	-33.3	84.7	-36.4	87.0	-40.4	90.0
			-26.8	66.4	5.0	2.5	-30.4	68.2	-33.4	69.7	-36.2	71.1	-39.9	72.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	33.5	10.5	11.6	21.4	32.4	43.3	52.7	58.9	54.7	45.7	32.6	20.8	16.3	(6)
(7)		DBStd	19.04	13.36	13.60	9.54	6.78	7.59	6.72	5.96	5.83	5.96	8.00	10.62	12.28	(7)
(8)		HDD50	6640	1225	1075	888	528	238	46	4	21	155	539	877	1044	(8)
(9)		HDD65	11509	1690	1495	1353	978	674	372	206	321	580	1004	1327	1509	(9)
(10)		CDD50	630	0	0	0	0	29	127	281	168	25	0	0	0	(10)
(11)		CDD65	23	0	0	0	0	0	3	17	3	0	0	0	0	(11)
(12)		CDH74	185	0	0	0	0	8	31	126	20	0	0	0	0	(12)
(13)		CDH80	19	0	0	0	0	0	4	15	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.5	4.7	5.1	6.5	6.1	6.2	6.1	5.4	5.2	5.8	5.5	4.5	5.3	(14)
(15)	Precipitation	PrecAvg	22.3	1.4	1.1	1.2	1.1	1.7	2.6	3.3	2.7	2.0	1.9	1.8	1.6	(15)
(16)		PrecMax	28.2	2.3	2.2	2.8	2.9	3.1	4.7	5.5	5.7	4.5	3.1	4.8	(16)	
(17)		PrecMin	15.9	0.2	0.3	0.2	0.2	0.3	0.3	1.2	1.1	0.7	0.7	0.5	0.3	(17)
(18)		PrecStd	3.8	0.6	0.6	0.6	0.7	0.7	1.2	1.1	1.3	0.9	0.8	1.0	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.6	42.1	45.2	58.2	74.6	77.6	81.9	76.7	64.5	52.3	43.9	41.0	(19)
(20)			MCWB	36.8	37.1	37.6	45.6	55.3	63.1	64.7	64.2	55.6	46.7	40.7	37.3	(20)
(21)		2%	DB	34.5	37.1	40.6	50.2	68.6	72.6	77.4	72.2	60.3	48.9	40.2	37.1	(21)
(22)			MCWB	32.1	33.1	34.9	40.8	54.1	57.5	62.4	61.1	53.4	45.6	38.2	34.1	(22)
(23)		5%	DB	31.4	33.2	37.6	46.8	61.4	68.6	73.9	68.7	57.5	46.3	36.5	34.0	(23)
(24)			MCWB	29.9	30.6	33.2	39.0	49.9	54.9	61.1	59.9	52.5	43.6	35.0	31.8	(24)
(25)		10%	DB	28.0	30.2	34.6	43.3	56.2	64.7	70.1	64.5	54.9	43.4	33.2	31.9	(25)
(26)			MCWB	26.7	28.5	30.8	36.8	46.7	53.9	59.7	57.5	50.9	41.2	32.1	30.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.8	37.7	37.8	45.7	58.0	64.6	67.2	66.9	57.2	48.2	41.7	37.4	(27)
(28)			MCDWB	39.6	41.6	44.0	56.0	70.6	76.0	75.1	74.2	60.7	50.2	42.7	40.5	(28)
(29)		2%	WB	32.4	33.2	35.4	41.9	54.5	59.8	64.7	63.0	55.3	45.9	37.9	34.5	(29)
(30)			MCDWB	33.9	36.3	39.9	49.0	66.3	67.3	74.2	69.3	58.9	48.7	40.0	36.8	(30)
(31)		5%	WB	29.9	30.6	33.4	39.4	50.6	57.1	62.7	60.7	53.2	43.8	35.2	32.3	(31)
(32)			MCDWB	31.5	32.8	37.0	45.6	60.3	65.0	70.6	66.6	56.5	46.2	36.6	33.6	(32)
(33)		10%	WB	26.8	28.4	31.3	37.2	47.5	54.9	60.8	58.5	51.7	41.5	32.4	30.6	(33)
(34)			MCDWB	28.1	30.2	34.1	43.0	55.1	62.8	67.8	63.5	54.4	43.5	33.0	32.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.8	13.2	14.4	13.9	14.7	14.4	15.0	14.2	12.0	9.2	10.3	12.4	(35)
(36)			MCDBR	13.4	14.2	14.9	17.8	23.7	20.1	19.9	19.7	15.9	11.5	10.1	11.2	(36)
(37)			MCWBR	12.6	12.1	11.0	10.8	12.2	9.5	9.3	10.2	10.2	9.0	9.0	10.1	(37)
(38)		5% WB	MCDWB	13.4	13.3	13.9	16.5	21.6	17.5	17.4	16.8	13.3	11.0	9.8	10.2	(38)
(39)			MCWBR	12.7	11.5	10.7	10.4	11.9	9.5	9.6	10.0	9.2	8.5	8.9	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.184	0.248	0.283	0.314	0.332	0.337	0.345	0.329	0.299	0.271	0.343	N/A	(40)
(41)		taud		1.933	2.124	2.214	2.258	2.464	2.487	2.479	2.507	2.566	2.372	2.765	N/A	(41)
(42)		Ebn at Noon		52	184	243	266	275	276	269	262	246	181	65	0	(42)
(43)		Edh at Noon		3	15	25	31	29	29	29	25	18	12	4	0	(43)
(44)	All-Sky Solar Radiation	RadAvg		17	176	654	1252	1529	1611	1509	1101	597	205	36	0	(44)
(45)		RadStd		1	22	43	58	148	115	148	86	78	34	4	0	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page