

PARKALOMPOLO, Sweden

WMO: 020720

Lat: 67.7301N

Lon: 22.8219E

Elev: 1027

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.3	-16.9	-28.9	1.1	-21.5	-23.4	1.6	-16.9	14.2	23.3	12.4	22.3	0.2	340	0.710

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	75.0	59.6	71.3	58.5	67.6	56.7	63.0	71.3	60.5	67.7	58.4	64.8	5.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.8	79.7	65.4	57.4	72.9	63.1	55.4	67.9	60.7	29.0	72.0	27.2	67.8	25.7	65.0	70.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.3	11.1	-28.0	78.2	6.0	4.2	-32.3	81.2	-35.8	83.6	-39.1	85.9	-43.4	89.0		
(5)			-28.3	64.7	5.9	2.3	-32.5	66.4	-35.9	67.8	-39.2	69.1	-43.5	70.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	31.1	8.6	8.5	18.1	29.7	41.2	50.7	56.8	52.3	43.3	29.7	18.5	13.6		
	DBStd	19.20	12.43	12.82	9.80	7.39	7.68	6.84	6.19	6.29	6.45	8.81	10.82	12.02		
	HDD50	7391	1282	1162	990	609	296	72	12	48	217	629	944	1130		
	HDD65	12403	1747	1582	1455	1059	738	430	263	394	652	1094	1394	1595		
	CDD50	474	0	0	0	0	23	94	222	120	15	0	0	0		
	CDD65	13	0	0	0	0	0	2	9	2	0	0	0	0		
	CDH74	140	0	0	0	0	8	23	94	15	0	0	0	0		
	CDH80	11	0	0	0	0	0	3	8	0	0	0	0	0		
	WSAvg	4.7	2.8	3.4	5.4	5.5	6.0	6.2	5.6	5.0	5.1	4.7	3.5	3.4		
	PrecAvg	21.1	1.4	1.1	1.1	1.1	1.5	2.4	3.0	2.5	2.0	1.9	1.7	1.5		
(15) Precipitation	PrecMax	28.7	2.7	2.0	2.7	2.7	3.0	4.6	5.0	4.3	5.4	3.9	3.3	3.9		
	PrecMin	14.1	0.2	0.2	0.2	0.3	0.2	0.2	0.9	0.8	0.6	0.6	0.5	0.1		
	PrecStd	3.7	0.5	0.5	0.6	0.6	0.7	1.1	1.2	0.9	1.2	0.8	0.8	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.7	38.5	43.1	55.1	74.6	76.7	81.0	76.2	62.3	50.0	41.3	37.8		
		MCWB	32.9	34.7	36.0	43.3	53.3	61.9	63.7	63.5	54.3	46.3	40.3	34.9		
	2%	DB	31.1	34.0	38.6	48.4	67.6	71.5	76.5	71.1	58.8	46.8	36.6	33.1		
		MCWB	30.4	31.2	33.6	40.1	52.9	56.1	60.8	60.1	52.9	44.8	35.5	32.1		
	5%	DB	28.5	29.5	35.0	44.9	60.5	67.4	73.0	67.5	56.0	44.3	33.4	31.5		
		MCWB	28.0	28.3	31.5	37.9	48.9	53.9	60.0	58.4	51.6	42.7	32.9	30.9		
	10%	DB	25.3	26.5	32.0	41.5	54.4	63.6	68.8	63.5	53.6	41.2	31.9	29.6		
		MCWB	24.7	25.4	29.6	35.6	45.0	52.3	58.6	56.3	50.4	40.0	31.5	28.9		
	0.4%	WB	33.2	35.5	36.6	44.1	56.7	63.6	66.4	65.6	56.6	47.3	40.4	35.1		
		MCDB	34.0	38.1	42.2	52.9	68.8	74.7	74.1	72.0	59.4	48.4	41.0	37.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.6	31.4	34.1	40.7	53.3	58.0	63.6	61.8	54.5	45.0	35.6	32.4		
		MCDB	30.9	33.7	37.7	46.8	66.2	65.7	72.4	68.0	57.1	46.6	36.2	33.1		
	5%	WB	27.8	28.6	31.9	38.3	49.5	55.3	61.6	59.5	52.5	42.7	33.0	31.0		
		MCDB	28.4	29.8	34.5	44.1	59.2	64.0	69.8	65.5	54.9	44.2	33.4	31.4		
	10%	WB	24.8	25.6	29.8	36.1	46.2	53.5	59.6	57.3	50.8	40.1	31.5	29.0		
		MCDB	25.3	26.6	31.9	41.2	53.2	62.1	66.8	62.2	53.2	41.2	31.8	29.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	15.1	17.7	15.8	15.2	15.4	16.4	16.4	14.0	11.1	11.7	13.3		
		MCDBR	12.7	13.4	17.3	18.4	24.8	22.1	22.3	22.1	16.8	12.3	8.6	10.8		
		MCWBR	12.6	12.1	13.3	11.6	13.2	10.7	10.6	12.5	11.5	10.2	8.5	10.4		
		MCDBR	12.4	13.1	15.0	16.9	22.9	18.1	19.2	18.9	13.3	11.6	8.6	10.3		
	5% WB	MCWBR	12.4	12.1	12.1	10.9	13.1	10.1	10.7	11.1	9.6	9.8	8.4	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.182	0.243	0.279	0.309	0.327	0.333	0.340	0.325	0.295	0.264	0.347	N/A		
	taud		1.925	2.109	2.207	2.237	2.446	2.492	2.485	2.509	2.567	2.351	2.788	N/A		
	Ebn at Noon		43	181	242	267	276	277	270	263	245	179	58	0		
	Edh at Noon		3	15	24	32	29	29	28	25	18	12	4	0		
(44) All-Sky Solar Radiation	RadAvg		14	168	653	1268	1538	1597	1496	1085	583	197	32	0		
	RadStd		1	20	39	56	150	108	147	79	72	32	4	0		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page