

PAJALA, Sweden

WMO: 020950

Lat: 67.2036N

Lon: 23.3899E

Elev: 164

StdP: 99.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.5	-29.7	-35.7	0.1	-32.4	-32.5	0.2	-29.6	8.2	-4.2	7.2	-4.4	0.8	340	0.688

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	25.2	16.4	23.1	15.5	21.0	14.5	17.7	22.6	16.6	20.9	15.5	19.5	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	11.6	19.1	14.8	10.7	18.1	13.7	10.0	17.0	50.7	22.6	47.1	21.0	43.9	19.5	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	5.9	5.2	-35.3	27.1	3.0	1.9	-37.5	28.5	-39.3	29.6	-41.0	30.6	-43.2	32.0		
			-35.4	19.4	3.0	1.6	-37.6	20.5	-39.4	21.4	-41.0	22.3	-43.2	23.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.1	-13.3	-12.8	-7.1	-0.7	5.4	11.1	14.5	11.6	6.8	0.0	-7.1	-10.7	(6)
(7)		DBStd	11.11	8.07	8.25	5.99	4.30	4.04	3.52	3.29	3.53	3.70	4.93	6.88	7.89	(7)
(8)		HDD10.0	3990	723	637	529	321	152	28	3	24	110	309	512	641	(8)
(9)		HDD18.3	6741	982	871	788	571	401	219	124	211	346	568	762	899	(9)
(10)		CDD10.0	299	0	0	0	0	10	60	144	72	13	0	0	0	(10)
(11)		CDD18.3	9	0	0	0	0	0	1	6	2	0	0	0	0	(11)
(12)		CDH23.3	155	0	0	0	0	5	28	102	20	0	0	0	0	(12)
(13)		CDH26.7	16	0	0	0	0	0	3	12	1	0	0	0	0	(13)
(14)	Wind	WSAvg	2.2	1.9	2.0	2.5	2.4	2.7	2.7	2.4	2.2	2.2	2.1	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	562	41	31	31	31	37	59	84	69	49	46	49	40	(15)
(16)		PrecMax	720	66	63	62	72	70	97	173	152	114	93	83	95	(16)
(17)		PrecMin	420	6	5	10	6	6	7	27	24	14	20	18	7	(17)
(18)		PrecStd	91	14	16	15	17	17	23	37	31	27	20	21	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	5.0	7.5	14.0	23.7	27.0	28.3	25.6	18.6	11.3	6.1	4.0	(19)
(20)			MCWB	1.2	2.7	3.3	7.5	13.8	16.3	18.1	17.9	12.9	8.9	5.4	2.5	(20)
(21)		2%	DB	0.6	2.1	5.1	10.3	19.8	23.2	25.9	22.9	16.5	9.7	3.7	1.6	(21)
(22)			MCWB	-0.3	0.5	1.8	4.9	11.7	14.4	16.9	16.2	11.8	8.1	2.8	0.8	(22)
(23)		5%	DB	-0.6	0.2	3.1	8.1	16.0	20.7	24.2	20.6	14.8	8.2	2.1	0.6	(23)
(24)			MCWB	-1.1	-0.6	0.5	3.7	9.4	13.1	16.1	15.1	11.4	6.9	1.5	0.0	(24)
(25)		10%	DB	-2.3	-1.2	1.4	6.1	13.5	18.3	22.2	18.4	13.2	6.6	0.9	-0.2	(25)
(26)			MCWB	-2.8	-1.9	-0.6	2.4	8.0	11.8	15.4	14.0	10.8	5.4	0.5	-0.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.5	3.0	3.7	7.7	14.3	17.8	19.7	19.2	14.4	10.0	5.6	2.5	(27)
(28)			MCDWB	2.3	5.1	7.0	13.8	22.0	24.3	24.7	23.8	16.4	10.6	5.8	3.4	(28)
(29)		2%	WB	0.0	0.7	2.1	5.2	12.3	15.8	18.3	17.2	13.0	8.4	3.0	0.9	(29)
(30)			MCDWB	0.5	1.7	4.5	9.5	18.5	20.9	23.4	21.4	15.2	9.3	3.6	1.4	(30)
(31)		5%	WB	-1.1	-0.5	0.9	3.9	10.2	14.1	17.2	15.9	12.1	7.1	1.7	0.2	(31)
(32)			MCDWB	-0.6	0.2	2.7	7.7	14.8	18.5	21.7	19.1	14.0	8.1	2.0	0.5	(32)
(33)		10%	WB	-2.8	-2.0	-0.2	2.7	8.6	12.7	16.2	14.7	11.1	5.6	0.7	-0.7	(33)
(34)			MCDWB	-2.3	-1.2	1.2	5.6	12.7	17.2	20.6	17.6	12.9	6.5	0.9	-0.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	9.2	11.4	10.0	9.9	9.4	10.6	10.5	9.0	6.4	6.9	7.9	(35)
(36)			MCDBR	7.5	7.3	10.5	12.2	15.9	14.1	14.9	14.3	11.9	7.3	5.4	6.2	(36)
(37)			MCWBR	7.2	6.6	8.0	7.7	8.8	6.7	7.2	8.2	7.9	5.8	5.1	5.9	(37)
(38)		5% WB	MCDBR	7.6	7.3	9.1	11.5	14.3	11.5	12.7	12.1	9.3	6.2	4.8	6.2	(38)
(39)			MCWBR	7.3	6.5	7.1	7.4	8.4	6.4	7.2	7.3	6.6	5.3	4.6	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.190	0.254	0.288	0.320	0.336	0.341	0.350	0.334	0.305	0.277	0.345	N/A	(40)	
(41)		taud	1.932	2.112	2.198	2.243	2.450	2.479	2.467	2.495	2.555	2.363	2.723	N/A	(41)	
(42)		Ebn at Noon	165	570	758	833	863	866	843	821	766	563	198	0	(42)	
(43)		Edh at Noon	12	50	80	101	93	93	91	80	59	40	14	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.06	0.56	2.08	3.95	4.80	5.11	4.79	3.50	1.89	0.66	0.12	0.00	(44)	
(45)		RadStd	0.00	0.08	0.16	0.19	0.48	0.36	0.47	0.27	0.25	0.11	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page