

STEKENJOKK, Sweden

WMO: 021020

Lat: 65.0929N

Lon: 14.5055E

Elev: 1036

StdP: 89.48

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.1	-18.6	-24.8	0.5	-20.5	-21.5	0.6	-18.2	33.0	-3.5	29.2	-3.0	8.0	100	1.096

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	18.7	12.5	16.9	11.7	15.2	11.0	13.6	16.7	12.5	15.4	11.5	14.3	5.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	10.1	14.6	11.2	9.4	13.6	10.1	8.7	12.6	41.5	16.6	38.4	15.4	35.8	14.2	19.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.1	21.5	18.7	DB	-23.2	20.6	2.8	2.6	-25.2	22.5	-26.8	24.0	-28.3	25.4	-30.3	27.3	(4)
(5)			WB	-23.1	15.0	2.8	2.1	-25.2	16.5	-26.8	17.7	-28.4	18.8	-30.5	20.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.2	-9.3	-9.4	-7.8	-3.5	1.4	5.6	9.8	8.5	3.9	-1.6	-5.4	-7.3	(6)	
	DBStd	7.78	4.59	4.86	3.95	3.59	4.26	4.09	4.03	3.58	3.19	3.57	4.08	4.30	(7)	
	HDD10.0	4189	598	544	552	405	269	145	54	74	186	359	463	537	(8)	
	HDD18.3	7140	857	778	811	655	525	383	264	306	434	618	713	796	(9)	
	CDD10.0	92	0	0	0	0	3	12	49	27	1	0	0	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	8.5	10.1	9.8	9.6	8.1	7.3	7.3	6.6	6.8	8.2	8.8	9.1	10.7	(14)	
(15) Precipitation	PrecAvg	779	81	74	56	36	35	63	89	79	63	66	59	78	(15)	
	PrecMax	977	157	201	146	79	63	112	192	164	105	118	149	145	(16)	
	PrecMin	582	10	8	9	9	12	16	40	24	18	35	12	24	(17)	
	PrecStd	115	42	51	34	17	16	26	37	38	25	20	36	37	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.2	1.0	2.8	7.5	16.0	19.4	22.3	19.2	14.1	7.5	6.7	0.9	(19)	
		MCWB	-0.7	-0.3	-1.0	3.6	9.4	11.4	14.8	13.1	8.9	6.5	1.5	0.4	(20)	
	2%	DB	-0.7	-0.6	-0.1	5.4	12.1	16.5	19.8	17.4	11.4	5.6	3.4	0.0	(21)	
		MCWB	-1.0	-1.0	-0.7	2.1	7.6	10.2	13.1	12.3	9.1	4.2	2.4	-0.2	(22)	
	5%	DB	-1.9	-1.9	-1.2	2.9	10.2	14.2	17.9	15.7	9.6	4.4	0.9	-1.1	(23)	
		MCWB	-2.2	-2.2	-1.5	0.4	6.2	9.3	12.5	11.6	8.1	3.5	0.5	-1.2	(24)	
	10%	DB	-3.1	-3.2	-2.3	1.4	7.9	11.9	16.1	14.1	8.1	3.4	-0.4	-2.0	(25)	
		MCWB	-3.5	-3.5	-2.5	-0.2	5.4	8.2	11.5	11.3	7.1	2.8	-0.6	-2.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.0	0.2	0.4	4.0	10.1	12.6	15.9	14.4	11.1	6.5	4.0	0.7	(27)	
		MCDB	0.0	0.2	0.8	6.8	14.9	16.1	21.0	16.9	12.0	6.9	4.1	0.8	(28)	
	2%	WB	-0.9	-0.9	-0.7	2.4	8.6	10.7	14.1	13.3	9.5	4.7	1.7	-0.2	(29)	
		MCDB	-0.8	-0.8	-0.5	4.5	11.7	14.9	17.8	15.9	10.7	5.1	3.3	-0.2	(30)	
	5%	WB	-2.2	-2.2	-1.6	1.0	7.0	9.7	13.1	12.3	8.4	3.8	0.4	-1.3	(31)	
		MCDB	-2.0	-2.0	-1.2	2.1	9.3	13.3	16.0	15.0	9.5	4.1	0.9	-1.2	(32)	
	10%	WB	-3.5	-3.5	-2.5	0.1	5.4	8.5	12.0	11.3	7.4	2.8	-0.6	-2.2	(33)	
		MCDB	-3.2	-3.2	-2.1	0.9	8.2	11.4	14.9	13.8	8.2	3.1	-0.3	-2.1	(34)	
(35) Mean Daily Temperature Range	MDBR		3.9	4.3	4.1	4.0	4.7	5.8	5.9	4.9	4.0	3.1	3.3	3.5	(35)	
	5% DB	MCDBR	4.4	4.7	4.4	4.8	6.9	8.0	7.6	6.1	6.0	4.0	3.8	3.8	(36)	
		MCWBR	4.3	4.6	4.3	3.3	4.4	4.3	3.6	3.3	4.2	3.5	3.5	4.0	(37)	
	5% WB	MCDBR	4.2	4.7	4.4	4.1	6.5	7.0	6.6	5.7	5.3	3.6	3.6	3.9	(38)	
		MCWBR	4.3	4.7	4.3	3.2	4.6	4.4	3.8	3.6	4.1	3.4	3.5	4.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.162	0.233	0.262	0.289	0.297	0.300	0.309	0.297	0.277	0.253	N/A	0.165	(40)	
	taud		1.923	2.202	2.252	2.270	2.394	2.531	2.530	2.549	2.590	2.420	N/A	1.933	(41)	
	Ebn at Noon		382	688	828	886	913	919	899	879	830	671	N/A	111	(42)	
	Edh at Noon		22	52	80	101	99	89	87	77	59	42	N/A	7	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.11	0.57	1.94	3.77	4.72	4.94	4.62	3.45	1.89	0.72	0.18	0.03	(44)	
	RadStd		0.01	0.12	0.23	0.31	0.36	0.43	0.56	0.36	0.23	0.09	0.02	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page