

KLIMPFJALL, Sweden

WMO: 021080

Lat: 65.067N

Lon: 14.800E

Elev: 593

StdP: 94.40

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.5	(c) -26.1	(d) -30.4	(e) 0.2	(f) -28.4	(g) -27.9	(h) 0.3	(i) -26.1	(j) 15.3	(k) -3.4	(l) 14.8	(m) -3.6	(n) 0.6	(o) 320	(p) 0.783

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.2	(c) 20.4	(d) 13.0	(e) 18.3	(f) 11.9	(g) 16.4	(h) 11.1	(i) 14.2	(j) 18.5	(k) 12.8	(l) 16.4	(m) 11.9	(n) 15.0	(o) 3.4	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	9.7	14.9	11.2	8.9	13.5	10.3	8.4	12.9	41.7	18.7	38.0	16.5	35.4	15.1	18.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.3	7.4	-31.5	23.7	4.4	1.8	-34.6	25.0	-37.2	26.1	-39.6	27.1	-42.8	28.4
			-31.6	15.5	4.3	1.7	-34.7	16.7	-37.2	17.8	-39.7	18.8	-42.8	20.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.3	-10.0	-9.1	-6.1	-3.0	3.5	8.5	10.6	9.0	4.7	0.0	-5.1	-7.7		
	DBStd	8.72	8.13	6.96	5.08	4.44	3.10	3.17	2.77	2.84	2.80	4.54	5.47	6.78		
	HDD10.0	3868	621	536	500	389	204	66	27	53	160	311	453	549		
	HDD18.3	6818	879	769	758	639	461	294	241	289	409	569	703	807		
	CDD10.0	92	0	0	0	0	2	22	45	22	1	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	6	0	0	0	0	0	2	3	2	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	2.8	2.9	3.0	3.0	2.6	2.7	3.0	2.9	2.4	2.6	2.9	2.6	3.0		
(15) Precipitation	PrecAvg	779	81	74	56	36	35	63	89	79	63	66	59	78		
	PrecMax	977	157	201	146	79	63	112	192	164	105	118	149	145		
	PrecMin	582	10	8	9	9	12	16	40	24	18	35	12	24		
	PrecStd	115	42	51	34	17	16	26	37	38	25	20	36	37		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.6	3.1	4.4	8.9	19.2	22.8	22.9	22.9	15.1	9.5	4.6	3.2		
		MCWB	2.2	2.4	2.5	4.5	10.0	13.9	14.7	14.5	9.8	7.3	3.2	2.2		
	2%	DB	2.3	1.8	2.7	6.6	14.6	19.6	20.5	18.2	12.1	7.9	3.2	2.4		
		MCWB	1.2	1.0	1.1	2.8	7.9	11.7	13.5	12.8	9.1	6.1	2.1	1.6		
	5%	DB	0.8	0.6	1.5	4.8	11.2	17.4	18.7	15.4	10.7	6.7	2.3	1.6		
		MCWB	-0.3	-0.3	0.1	1.8	5.9	10.9	12.7	11.1	8.5	5.1	1.4	1.0		
	10%	DB	-0.6	-0.6	0.4	3.1	8.6	15.1	16.9	14.0	9.4	5.5	1.3	0.4		
		MCWB	-1.4	-1.4	-0.7	1.3	4.4	9.5	11.9	10.8	7.2	4.3	0.5	-0.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.5	2.6	2.7	4.6	10.4	15.0	17.2	15.4	11.1	8.1	3.4	2.5		
		MCDB	3.3	3.1	3.8	7.7	18.3	20.6	18.7	20.6	12.6	8.7	4.1	2.7		
	2%	WB	1.3	1.1	1.5	3.3	8.0	12.7	14.7	13.4	9.9	6.4	2.3	1.7		
		MCDB	2.2	1.6	2.5	5.6	14.1	17.4	19.1	16.6	11.6	7.3	3.0	2.2		
	5%	WB	-0.2	-0.1	0.3	2.4	6.2	11.4	13.4	12.2	8.7	5.2	1.4	0.9		
		MCDB	0.7	0.5	1.3	4.1	10.3	16.3	17.2	14.4	10.3	6.3	2.1	1.6		
	10%	WB	-1.4	-1.4	-0.7	1.5	5.0	10.1	12.3	11.2	7.5	4.3	0.7	-0.2		
		MCDB	-0.7	-0.7	0.3	3.0	7.7	14.4	15.7	13.2	9.1	5.4	1.3	0.4		
(35) Mean Daily Temperature Range	MDBR		7.0	7.1	7.5	8.1	7.3	8.2	8.2	7.3	6.5	5.3	5.4	6.5		
	5% DB	MCDBR	6.2	5.5	5.7	9.0	12.7	13.1	12.5	10.5	8.7	6.3	4.0	5.0		
		MCWBR	6.0	5.5	4.9	6.0	7.5	6.9	6.1	5.7	5.5	5.2	3.8	4.9		
	5% WB	MCDBR	5.9	4.9	5.3	6.4	11.4	11.7	10.1	8.2	6.6	5.2	3.7	5.0		
		MCWBR	5.8	5.0	4.9	4.7	7.0	6.6	5.8	5.2	4.8	4.9	3.6	5.0		
(40) Clear-Sky Solar Irradiance	taub		0.176	0.248	0.280	0.308	0.318	0.318	0.329	0.316	0.293	0.270	N/A	0.178		
	taud		1.926	2.178	2.223	2.239	2.383	2.504	2.498	2.518	2.570	2.406	N/A	1.939		
	Ebn at Noon		352	657	801	861	891	899	876	856	807	642	N/A	97		
	Edh at Noon		22	54	83	105	100	92	90	80	61	44	N/A	7		
(44) All-Sky Solar Radiation	RadAvg		0.11	0.57	1.94	3.77	4.71	4.95	4.63	3.46	1.90	0.72	0.18	0.04		
	RadStd		0.01	0.12	0.23	0.31	0.36	0.43	0.56	0.36	0.23	0.09	0.03	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page