

MIERKENIS, Sweden

WMO: 021210

Lat: 66.6802N

Lon: 16.1053E

Elev: 2018

StdP: 13.66

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.7	-18.0	-28.9	1.2	-22.6	-23.6	1.6	-17.9	26.3	18.3	23.4	20.4	3.8	300	0.783

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	70.9	57.4	67.3	55.7	63.6	54.0	59.7	67.1	57.4	64.3	55.3	61.5	6.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.7	73.8	62.3	54.5	68.0	59.7	52.4	62.9	57.6	27.1	67.3	25.5	64.6	24.1	61.7	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.1	17.4	15.3	DB	-27.7	75.0	6.2	4.6	-32.1	78.3	-35.8	81.0	-39.3	83.6	-43.8	87.0	(4)
(5)			WB	-29.6	62.1	5.4	3.1	-33.5	64.3	-36.7	66.1	-39.7	67.8	-43.7	70.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	30.1	10.1	12.8	17.0	26.6	37.2	46.4	52.9	49.7	41.7	30.1	20.0	15.5	
	DBStd	17.42	13.33	13.74	10.97	8.25	6.40	6.16	5.29	5.48	5.77	8.22	10.90	13.45	
	HDD50	7488	1236	1043	1022	701	400	144	29	73	253	616	900	1071	
	HDD65	12739	1701	1463	1487	1151	862	558	377	473	700	1081	1350	1536	
	CDD50	225	0	0	0	0	3	36	118	65	3	0	0	0	
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH74	33	0	0	0	0	0	6	26	1	0	0	0	0	
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0	
Wind	WSAvg	7.1	7.2	7.5	7.9	7.0	7.3	7.2	6.5	6.0	6.9	7.2	6.6	7.4	
Precipitation	PrecAvg	25.0	2.2	1.8	1.7	1.2	1.4	2.0	3.3	2.8	2.6	2.0	1.9	2.1	
	PrecMax	33.9	5.2	4.6	3.4	2.4	2.2	3.5	5.5	5.9	4.3	3.1	3.7	5.2	
	PrecMin	19.6	0.7	0.7	0.3	0.4	0.3	0.2	1.1	1.0	1.1	0.9	0.4	0.5	
	PrecStd	3.5	1.2	1.0	1.0	0.6	0.6	1.0	1.5	1.5	1.0	0.7	1.0	1.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.2	39.0	39.9	49.3	66.6	73.1	77.4	72.5	61.0	48.8	42.4	40.3	
		MCWB	36.2	35.9	35.6	41.0	50.7	56.0	61.3	58.5	51.0	44.8	40.2	37.2	
	2%	DB	35.2	36.1	36.9	44.5	58.9	67.2	72.4	68.5	55.9	45.6	39.8	36.8	
		MCWB	33.2	33.5	33.8	37.6	47.3	52.9	58.4	57.4	50.0	42.4	37.5	34.5	
	5%	DB	31.8	34.1	34.8	40.8	53.1	63.4	68.8	64.3	53.1	43.4	37.1	33.6	
		MCWB	30.4	31.7	32.1	36.0	44.4	51.0	57.1	56.3	48.6	40.9	35.3	31.6	
	10%	DB	27.8	31.1	32.3	38.2	47.6	59.4	64.9	60.5	50.8	40.9	33.3	31.1	
		MCWB	26.6	29.4	30.1	34.5	41.3	49.8	55.6	54.1	47.3	38.9	32.2	29.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.7	36.2	36.2	41.4	51.5	57.7	63.8	61.6	53.7	45.2	41.0	37.3
			MCDB	38.0	38.5	39.0	48.2	64.7	68.6	72.6	68.1	58.2	47.7	42.2	39.8
2%		WB	32.9	34.0	34.1	38.6	48.0	54.8	61.0	58.8	51.2	42.9	37.8	34.8	
		MCDB	34.3	36.0	36.6	43.4	58.1	63.2	68.9	65.3	54.5	45.1	39.6	36.7	
5%		WB	30.0	31.9	32.2	36.6	44.9	52.7	58.6	56.9	49.3	41.1	35.2	31.9	
		MCDB	31.4	33.7	34.5	40.2	52.1	60.7	66.0	63.1	52.2	43.2	36.9	33.5	
10%		WB	26.3	29.3	30.1	34.6	42.0	50.8	56.4	54.8	47.6	39.1	32.4	29.7	
		MCDB	27.4	31.0	32.2	38.0	47.3	58.4	63.0	59.7	50.1	40.9	33.2	31.0	
Mean Daily Temperature Range		5% DB	MDBR	14.3	15.6	16.9	16.3	13.4	15.6	16.5	15.7	12.8	10.3	12.2	13.7
			MCDBR	11.1	13.4	13.4	17.1	24.0	25.0	25.5	23.1	17.6	10.6	10.9	13.3
	MCWBR		10.7	12.2	11.3	12.1	14.1	12.4	13.0	13.4	11.9	8.3	9.8	12.0	
	5% WB	MCDBR	11.9	13.6	13.0	14.5	22.3	21.3	21.4	20.7	14.3	9.9	10.7	13.8	
		MCWBR	11.4	12.4	11.1	10.3	13.7	11.4	11.9	12.7	10.3	8.1	9.8	12.6	
Clear-Sky Solar Irradiance	taub	0.170	0.236	0.273	0.298	0.310	0.314	0.324	0.311	0.284	0.254	0.175	N/A		
	taud	1.919	2.145	2.199	2.229	2.335	2.478	2.494	2.513	2.562	2.318	1.960	N/A		
	Ebn at Noon	75	198	250	273	282	285	278	270	254	193	68	0		
	Edh at Noon	4	16	25	32	33	29	28	25	18	13	4	0		
All-Sky Solar Radiation	RadAvg	20	153	585	1181	1546	1581	1443	1079	569	198	43	0		
	RadStd	1	27	62	82	117	134	169	114	63	33	4	0		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page