

ARJEPLOG, Sweden

WMO: 021240

Lat: 66.0513N

Lon: 17.8396E

Elev: 1417

StdP: 13.96

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.8	-17.3	-28.5	1.2	-22.8	-22.0	1.7	-17.1	22.8	32.1	17.6	28.9	0.5	100	0.704

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	74.1	59.4	70.7	58.4	67.2	56.8	62.1	70.5	60.1	67.6	58.1	65.1	5.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.8	78.1	65.1	56.7	72.3	63.6	54.8	67.3	61.3	28.5	70.7	27.1	67.3	25.8	65.3	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	13.6	11.7	-27.9	77.9	5.7	4.1	-32.0	80.8	-35.3	83.2	-38.5	85.5	-42.7	88.5		
(5)			-28.3	64.4	5.6	2.9	-32.3	66.5	-35.6	68.1	-38.8	69.8	-42.8	71.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.7	11.1	12.0	19.6	30.4	40.8	51.1	57.4	53.8	45.1	33.2	21.4	15.1		
	DBStd	18.65	13.81	13.90	10.47	7.30	6.81	6.36	5.53	5.62	5.75	6.86	10.30	13.41		
	HDD50	6811	1206	1065	941	589	298	61	3	24	164	520	859	1081		
	HDD65	11799	1671	1485	1406	1039	750	419	245	348	596	985	1309	1546		
	CDD50	498	0	0	0	0	12	93	232	143	18	0	0	0		
	CDD65	12	0	0	0	0	0	1	9	2	0	0	0	0		
	CDH74	101	0	0	0	0	2	16	74	9	0	0	0	0		
	CDH80	10	0	0	0	0	0	1	9	0	0	0	0	0		
	WSAvg	5.0	4.0	4.4	5.4	5.1	5.6	6.1	5.3	5.0	5.5	5.2	4.1	4.1		
	PrecAvg	23.3	1.7	1.3	1.2	1.1	1.5	2.7	3.7	2.9	2.1	1.9	1.7	1.6		
(15) Precipitation	PrecMax	32.6	3.7	2.3	2.3	2.5	2.8	4.8	6.1	5.9	5.4	3.5	4.0	3.6		
	PrecMin	15.3	0.2	0.2	0.4	0.3	0.3	0.7	1.0	0.9	0.5	0.5	0.6	0.5		
	PrecStd	3.9	0.7	0.6	0.6	0.7	0.7	1.1	1.3	1.5	1.1	0.8	0.9	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.2	40.9	43.1	54.4	70.4	76.1	80.4	75.2	63.2	50.4	43.8	40.7		
		MCWB	37.3	37.2	37.1	44.1	53.0	58.4	62.6	60.9	54.8	46.0	40.8	37.4		
	2%	DB	36.9	37.4	40.0	48.4	63.5	71.2	75.6	71.6	59.0	47.4	39.8	37.5		
		MCWB	34.1	34.2	35.5	40.1	50.5	55.9	60.5	59.6	52.7	44.3	38.0	34.5		
	5%	DB	32.6	33.5	37.3	44.4	57.9	66.9	72.1	67.7	56.3	45.2	36.4	34.3		
		MCWB	30.7	31.1	33.5	38.5	47.7	54.2	59.8	58.9	51.1	42.3	34.7	32.6		
	10%	DB	29.1	30.4	34.4	41.4	52.8	62.8	68.5	64.0	54.0	43.0	33.9	31.9		
		MCWB	27.8	28.9	31.3	36.4	44.9	52.5	58.0	56.7	50.0	40.6	32.6	30.9		
	0.4%	WB	37.7	37.5	38.0	44.3	54.8	61.1	66.1	64.1	56.6	47.3	41.3	37.7		
		MCDB	40.6	40.6	42.0	52.7	66.1	72.3	74.0	71.6	60.1	49.0	42.8	40.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.5	34.7	35.7	41.2	51.5	57.8	63.1	61.3	53.9	44.8	38.3	35.0		
		MCDB	37.1	37.3	39.5	46.8	61.5	67.1	72.1	68.1	57.3	47.0	39.8	37.1		
	5%	WB	31.0	31.5	33.8	38.8	48.0	55.6	61.1	59.5	52.2	42.7	34.9	32.8		
		MCDB	32.5	33.3	36.9	43.7	55.9	63.9	69.3	66.0	55.4	44.7	36.1	34.1		
	10%	WB	27.9	29.0	31.6	36.7	45.1	53.5	59.2	57.5	50.5	40.8	32.7	30.9		
		MCDB	29.0	30.6	34.2	41.0	51.7	61.5	66.5	63.3	53.3	42.7	33.6	32.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	14.6	16.7	15.6	15.0	14.4	14.7	14.0	11.9	8.9	10.0	12.5		
		MCDBR	11.7	14.2	14.9	18.9	24.9	20.9	20.7	19.8	15.1	10.8	9.0	11.9		
		MCWBR	10.5	12.7	11.9	12.5	14.0	9.6	9.2	10.4	10.1	8.7	8.3	11.0		
		MCDBR	10.9	13.1	14.2	16.9	22.1	18.2	18.1	17.3	12.9	9.9	8.6	11.8		
	5% WB	MCWBR	10.0	11.9	11.6	11.8	14.0	9.8	10.1	10.6	9.5	8.4	8.0	11.1		
(40) Clear-Sky Solar Irradiance	taub		0.175	0.244	0.279	0.307	0.322	0.324	0.335	0.321	0.293	0.270	N/A	0.178		
	taud		1.939	2.173	2.235	2.297	2.481	2.529	2.507	2.532	2.588	2.414	N/A	1.951		
	Ebn at Noon		90	201	251	272	281	282	275	268	253	196	N/A	13		
	Edh at Noon		5	16	25	31	29	28	28	25	18	13	N/A	1		
(44) All-Sky Solar Radiation	RadAvg		27	189	647	1227	1541	1625	1489	1112	609	224	50	4		
	RadStd		2	32	47	72	148	126	169	115	75	35	7	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page