

ARJEPLOG, Sweden

WMO: 021240

Lat: 66.0513N

Lon: 17.8396E

Elev: 432

StdP: 96.24

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.4	-27.4	-33.6	0.2	-30.4	-30.0	0.2	-27.3	10.2	0.1	7.9	-1.7	0.2	100	0.704

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	23.4	15.2	21.5	14.7	19.6	13.8	16.7	21.4	15.6	19.8	14.5	18.4	2.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	11.2	18.4	13.7	10.3	17.5	12.7	9.6	16.3	48.4	21.5	45.2	19.6	42.0	18.5	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.2	6.1	5.2	-33.3	25.5	3.2	2.3	-35.6	27.1	-37.4	28.4	-39.2	29.7	-41.5	31.4
			-33.5	18.0	3.1	1.6	-35.7	19.1	-37.6	20.1	-39.3	21.0	-41.6	22.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.4	-11.6	-11.1	-6.9	-0.9	4.9	10.6	14.1	12.1	7.3	0.7	-5.9	-9.4		
	DBStd	10.36	7.67	7.72	5.81	4.06	3.78	3.53	3.07	3.12	3.19	3.81	5.72	7.45		
	HDD10.0	3784	670	592	523	327	166	34	2	13	91	289	477	601		
	HDD18.3	6555	928	825	781	577	417	233	136	193	331	547	727	859		
	CDD10.0	277	0	0	0	0	7	52	129	79	10	0	0	0		
	CDD18.3	7	0	0	0	0	0	1	5	1	0	0	0	0		
	CDH23.3	56	0	0	0	0	1	9	41	5	0	0	0	0		
	CDH26.7	6	0	0	0	0	0	1	5	0	0	0	0	0		
(14) Wind	WSAvg	2.2	1.8	2.0	2.4	2.3	2.5	2.7	2.4	2.2	2.4	2.3	1.8	1.8		
(15) Precipitation	PrecAvg	593	43	32	31	29	39	69	95	74	53	48	44	40		
	PrecMax	829	94	59	59	64	71	122	155	150	136	90	101	92		
	PrecMin	388	5	5	9	8	8	19	25	23	13	13	15	12		
	PrecStd	99	19	15	14	17	19	29	33	37	28	21	24	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	5.0	6.2	12.4	21.3	24.5	26.9	24.0	17.3	10.2	6.5	4.9		
		MCWB	3.0	2.9	2.8	6.7	11.7	14.7	17.0	16.0	12.7	7.8	4.9	3.0		
	2%	DB	2.7	3.0	4.4	9.1	17.5	21.8	24.2	22.0	15.0	8.6	4.3	3.0		
		MCWB	1.2	1.2	2.0	4.5	10.3	13.3	15.8	15.3	11.5	6.9	3.3	1.4		
	5%	DB	0.4	0.8	3.0	6.9	14.4	19.4	22.3	19.8	13.5	7.3	2.4	1.3		
		MCWB	-0.7	-0.5	0.9	3.6	8.7	12.3	15.5	14.9	10.6	5.7	1.5	0.3		
	10%	DB	-1.6	-0.9	1.4	5.2	11.6	17.1	20.3	17.8	12.2	6.1	1.0	-0.1		
		MCWB	-2.3	-1.7	-0.4	2.4	7.2	11.4	14.4	13.7	10.0	4.8	0.3	-0.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	3.1	3.4	6.8	12.7	16.2	19.0	17.8	13.7	8.5	5.2	3.2		
		MCDB	4.8	4.8	5.6	11.5	18.9	22.4	23.3	22.0	15.6	9.5	6.0	4.6		
	2%	WB	1.4	1.5	2.1	5.1	10.9	14.3	17.3	16.3	12.2	7.1	3.5	1.7		
		MCDB	2.8	3.0	4.2	8.2	16.4	19.5	22.3	20.0	14.1	8.3	4.3	2.8		
	5%	WB	-0.6	-0.3	1.0	3.8	8.9	13.1	16.2	15.3	11.2	6.0	1.6	0.4		
		MCDB	0.3	0.7	2.7	6.5	13.3	17.7	20.7	18.9	13.0	7.1	2.3	1.2		
	10%	WB	-2.3	-1.6	-0.2	2.6	7.3	11.9	15.1	14.2	10.3	4.9	0.4	-0.6		
		MCDB	-1.7	-0.8	1.2	5.0	11.0	16.4	19.2	17.4	11.8	5.9	0.9	0.0		
(35) Mean Daily Temperature Range	MDBR		7.7	8.1	9.3	8.7	8.3	8.0	8.1	7.8	6.6	4.9	5.6	6.9		
	5% DB	MCDBR	6.5	7.9	8.3	10.5	13.8	11.6	11.5	11.0	8.4	6.0	5.0	6.6		
		MCWBR	5.9	7.1	6.6	6.9	7.8	5.4	5.1	5.8	5.6	4.8	4.6	6.1		
	5% WB	MCDBR	6.1	7.3	7.9	9.4	12.3	10.1	10.1	9.6	7.1	5.5	4.8	6.5		
		MCWBR	5.6	6.6	6.4	6.6	7.8	5.4	5.6	5.9	5.3	4.6	4.5	6.1		
(40) Clear-Sky Solar Irradiance	taub		0.175	0.244	0.279	0.307	0.322	0.324	0.335	0.321	0.293	0.270	N/A	0.178		
	taud		1.939	2.173	2.235	2.297	2.481	2.529	2.507	2.532	2.588	2.414	N/A	1.951		
	Ebn at Noon		284	635	791	858	885	890	866	846	798	618	N/A	42		
	Edh at Noon		17	51	80	97	91	89	88	78	58	41	N/A	4		
(44) All-Sky Solar Radiation	RadAvg		0.09	0.60	2.04	3.87	4.86	5.12	4.70	3.51	1.92	0.71	0.16	0.01		
	RadStd		0.01	0.10	0.15	0.23	0.47	0.40	0.53	0.36	0.24	0.11	0.02	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page