

BURESJON, SwedenWMO: **021350**Lat: **65.558N**Lon: **17.855E**Elev: **393**StdP: **96.69**Time Zone: **1.00 (EUC)**Period: **01-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.1	-28.5	-35.2	0.1	-32.1	-31.3	0.2	-28.5	8.4	-1.3	7.1	-1.6	0.3	120	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	24.1	15.9	22.1	15.0	20.2	14.1	17.3	22.0	16.2	20.3	15.0	18.7	2.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.6	11.6	18.7	14.5	10.8	17.6	13.3	10.0	16.4	50.2	22.3	46.6	20.3	43.3	18.7	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.3	5.4	-35.8	26.1	3.1	2.7	-38.1	28.0	-39.8	29.5	-41.6	31.0	-43.8	33.0		
(5)			-35.8	18.6	3.0	1.6	-38.0	19.8	-39.7	20.7	-41.4	21.6	-43.6	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.4	-12.3	-11.1	-6.7	-0.3	5.9	10.9	14.2	11.9	7.0	0.4	-6.1	-9.5		
	DBStd	10.55	7.87	7.54	5.96	4.02	3.82	3.61	3.06	3.09	3.21	4.34	6.19	7.78		
	HDD10.0	3776	691	592	517	308	137	31	2	14	98	298	483	604		
	HDD18.3	6540	949	825	776	558	385	223	134	199	339	556	733	862		
	CDD10.0	283	0	0	0	0	11	58	131	74	8	1	0	0		
	CDD18.3	7	0	0	0	0	0	1	5	1	0	0	0	0		
	CDH23.3	91	0	0	0	0	3	18	59	11	0	0	0	0		
	CDH26.7	11	0	0	0	0	0	1	10	0	0	0	0	0		
(14) Wind	WSAvg	2.2	1.7	1.9	2.6	2.5	2.7	2.7	2.2	1.9	2.2	2.2	1.7	1.9		
(15) Precipitation	PrecAvg	585	36	31	26	28	39	61	89	78	57	50	47	38		
	PrecMax	828	63	50	56	47	69	126	153	160	143	90	106	66		
	PrecMin	446	3	8	9	11	10	14	31	14	24	13	17	7		
	PrecStd	110	15	13	14	11	19	34	38	43	34	22	26	16		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.0	5.2	7.0	14.3	23.0	25.7	28.0	24.7	18.1	11.5	7.1	4.5		
		MCWB	3.7	3.3	3.9	7.2	13.0	15.2	17.9	16.9	13.3	8.9	5.7	3.1		
	2%	DB	2.3	3.5	4.8	10.7	19.6	22.7	24.7	22.6	15.5	9.3	4.8	2.6		
		MCWB	1.3	1.9	2.1	5.4	11.3	14.2	16.3	15.7	11.9	7.5	4.0	1.5		
	5%	DB	0.4	1.4	3.4	8.1	16.2	20.2	22.7	20.3	13.7	7.9	2.6	1.1		
		MCWB	-0.3	0.1	1.3	4.2	9.8	13.0	15.7	15.0	10.9	6.4	1.9	0.3		
	10%	DB	-1.6	-0.6	1.9	6.2	13.3	18.0	20.8	18.1	12.4	6.5	1.3	0.0		
		MCWB	-2.1	-1.5	0.2	3.1	8.3	11.9	14.9	14.1	10.2	5.3	0.8	-0.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	3.5	3.9	7.9	13.5	17.4	19.4	18.3	14.2	9.5	6.3	3.2		
		MCDB	5.1	5.0	6.4	13.3	20.8	22.8	23.7	22.0	16.3	10.4	7.1	4.1		
	2%	WB	1.5	2.0	2.5	6.0	12.2	15.4	17.8	16.8	12.6	7.8	4.0	1.6		
		MCDB	2.2	3.4	4.5	9.7	17.7	20.7	22.9	20.5	14.6	8.9	4.9	2.3		
	5%	WB	-0.4	0.2	1.5	4.5	10.5	13.9	16.7	15.6	11.5	6.6	2.0	0.5		
		MCDB	0.2	1.2	3.2	7.4	16.0	18.5	21.4	19.1	13.2	7.7	2.4	1.0		
	10%	WB	-2.1	-1.5	0.3	3.2	8.7	12.6	15.6	14.4	10.5	5.4	0.8	-0.6		
		MCDB	-1.7	-0.6	1.8	6.0	12.6	17.0	19.4	17.6	12.0	6.4	1.2	-0.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	9.4	10.6	9.3	9.5	9.3	9.5	9.3	8.0	6.0	6.2	7.8		
		MCDBR	8.2	7.9	9.7	12.5	15.5	12.7	13.3	13.5	10.3	7.2	5.5	7.3		
		MCWBR	7.7	7.1	7.7	7.8	8.4	6.2	6.2	7.3	7.0	5.6	5.1	7.0		
		MCDBR	8.2	8.0	9.0	10.9	14.4	11.6	11.4	11.3	8.8	6.5	4.9	7.1		
	5% WB	MCWBR	7.8	7.3	7.3	7.0	8.4	6.3	6.1	6.7	6.5	5.4	4.6	6.9		
(40) Clear-Sky Solar Irradiance	taub		0.179	0.252	0.284	0.314	0.326	0.327	0.339	0.324	0.297	0.277	0.341	0.183		
	taud		1.943	2.178	2.238	2.310	2.484	2.519	2.495	2.523	2.582	2.431	2.783	1.960		
	Ebn at Noon		312	637	790	855	883	888	863	844	797	623	313	65		
	Edh at Noon		19	53	81	97	91	90	90	79	60	42	19	5		
(44) All-Sky Solar Radiation	RadAvg		0.10	0.65	2.09	3.88	4.78	5.19	4.74	3.55	1.98	0.76	0.17	0.02		
	RadStd		0.01	0.11	0.17	0.24	0.50	0.40	0.52	0.38	0.26	0.12	0.03	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page