

MALA-BRANNAN, Sweden

WMO: 021470

Lat: 65.1512N

Lon: 18.5935E

Elev: 363

StdP: 97.04

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.7	-24.5	-30.5	0.2	-27.5	-27.0	0.3	-24.5	8.9	0.6	7.5	0.2	0.3	220	0.683

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	24.2	15.3	22.3	14.8	20.5	14.0	17.1	22.0	16.0	20.0	14.9	18.9	2.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.3	11.4	18.6	14.2	10.5	17.5	13.1	9.8	16.4	49.3	21.9	46.0	20.0	42.8	19.0	21.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.4	5.5	-31.9	26.1	3.4	2.3	-34.4	27.7	-36.4	29.0	-38.3	30.3	-40.7	31.9		
(5)			-31.9	18.3	3.4	1.5	-34.3	19.3	-36.3	20.2	-38.2	21.0	-40.7	22.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.3	-10.6	-9.7	-5.4	0.5	6.5	11.0	14.5	12.4	7.5	0.9	-4.6	-7.8	(6)
(7)		DBStd	9.89	7.07	7.16	5.37	3.82	3.92	3.52	3.11	3.19	3.26	4.12	5.45	6.85	(7)
(8)		HDD10.0	3472	637	551	477	284	124	28	2	12	86	282	439	551	(8)
(9)		HDD18.3	6210	896	784	735	534	368	221	124	187	324	539	689	809	(9)
(10)		CDD10.0	312	0	0	0	0	14	58	142	85	12	1	0	0	(10)
(11)		CDD18.3	9	0	0	0	0	0	1	6	2	0	0	0	0	(11)
(12)		CDH23.3	99	0	0	0	0	2	16	68	13	0	0	0	0	(12)
(13)		CDH26.7	11	0	0	0	0	0	1	10	0	0	0	0	0	(13)
(14)	Wind	WSAvg	2.3	1.8	2.0	2.5	2.4	2.6	2.7	2.3	2.2	2.5	2.3	1.9	2.0	(14)
(15)	Precipitation	PrecAvg	620	42	29	30	30	44	67	97	82	57	53	49	40	(15)
(16)		PrecMax	821	97	68	63	53	76	106	161	181	137	98	111	86	(16)
(17)		PrecMin	450	4	6	10	9	5	22	38	24	17	20	18	6	(17)
(18)		PrecStd	97	19	15	14	14	20	26	33	46	32	22	29	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.7	5.1	7.2	15.2	23.0	25.5	28.0	25.0	18.4	12.3	7.6	4.3	(19)
(20)			MCWB	3.1	3.1	3.6	8.0	12.9	14.5	17.7	16.1	13.2	9.5	6.3	2.7	(20)
(21)		2%	DB	2.3	3.6	5.1	11.2	19.9	22.4	25.1	22.8	15.9	9.4	5.2	2.6	(21)
(22)			MCWB	1.2	1.8	2.2	5.5	11.7	13.7	15.7	15.5	11.9	7.5	4.2	1.4	(22)
(23)		5%	DB	0.4	1.5	3.7	8.9	16.9	20.1	23.1	20.7	14.1	8.0	3.3	1.4	(23)
(24)			MCWB	-0.4	0.2	1.2	4.3	10.3	12.8	15.7	14.9	11.0	6.5	2.5	0.7	(24)
(25)		10%	DB	-1.1	-0.3	2.3	6.9	14.1	18.2	21.2	18.4	12.7	6.7	1.9	0.4	(25)
(26)			MCWB	-1.6	-1.2	0.2	3.2	8.7	11.7	14.7	13.9	10.4	5.5	1.3	-0.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	3.2	3.8	8.1	14.0	15.9	19.4	18.1	14.1	9.6	6.6	3.0	(27)
(28)			MCD B	4.4	4.8	6.6	13.8	20.2	21.0	23.7	22.6	16.2	11.0	7.5	4.1	(28)
(29)		2%	WB	1.5	2.0	2.5	6.2	12.5	14.7	17.7	16.6	12.6	7.8	4.2	1.7	(29)
(30)			MCD B	2.3	3.4	4.9	10.0	18.3	20.3	22.8	20.5	14.8	9.0	5.1	2.4	(30)
(31)		5%	WB	-0.3	0.3	1.5	4.7	10.7	13.6	16.6	15.5	11.6	6.7	2.6	0.7	(31)
(32)			MCD B	0.3	1.3	3.5	7.8	16.2	18.7	21.4	19.1	13.6	7.9	3.2	1.2	(32)
(33)		10%	WB	-1.7	-1.3	0.4	3.3	8.9	12.4	15.6	14.4	10.7	5.6	1.3	-0.2	(33)
(34)			MCD B	-1.2	-0.4	2.0	6.3	13.4	16.8	19.7	17.6	12.3	6.7	1.8	0.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.1	7.5	9.0	8.8	9.6	9.2	9.3	8.7	7.5	5.5	5.0	6.2	(35)
(36)			MCDBR	6.1	6.1	8.2	11.7	14.6	12.3	12.5	12.1	9.4	6.6	4.6	5.7	(36)
(37)			MCWBR	5.7	5.3	6.0	7.1	7.8	5.7	5.5	5.9	6.0	5.0	4.2	5.4	(37)
(38)		5% WB	MCDBR	6.1	6.1	7.8	10.1	13.6	11.4	10.8	8.1	6.0	4.4	5.7	(38)	
(39)			MCWBR	5.7	5.6	5.9	6.4	7.7	5.7	5.6	5.5	5.5	4.9	4.0	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.180	0.255	0.286	0.317	0.327	0.328	0.340	0.326	0.299	0.281	0.336	N/A	(40)	
(41)		taud	1.952	2.193	2.255	2.337	2.489	2.515	2.493	2.521	2.581	2.445	2.760	N/A	(41)	
(42)		Ebn at Noon	343	646	795	856	884	888	864	844	800	631	332	N/A	(42)	
(43)		Edh at Noon	21	54	80	95	91	91	90	80	60	43	20	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.12	0.72	2.26	4.04	4.86	5.22	4.80	3.64	2.11	0.83	0.19	0.03	(44)	
(45)		RadStd	0.01	0.12	0.19	0.25	0.57	0.44	0.53	0.37	0.27	0.14	0.04	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page