

ARVIDSJAUR, Sweden

WMO: 021490

Lat: 65.594N

Lon: 19.264E

Elev: 1260

StdP: 14.04

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.3	-14.9	-27.6	1.2	-21.0	-20.6	1.9	-14.8	22.2	31.3	19.4	26.6	1.7	300	0.721

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	76.4	60.3	72.6	58.7	69.1	57.0	62.8	71.9	60.9	69.1	59.0	66.9	8.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.4	79.1	65.4	57.4	73.8	63.8	55.5	68.7	61.7	28.9	72.0	27.6	69.0	26.3	67.1	68.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	17.9	15.6	DB	-27.0	80.6	6.2	4.7	-31.5	84.0	-35.2	86.8	-38.7	89.4	-43.2	92.8
			WB	-28.1	64.9	5.5	2.2	-32.0	66.5	-35.2	67.8	-38.2	69.0	-42.2	70.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	33.9	11.6	14.0	21.2	32.0	43.3	52.2	58.6	54.4	45.7	33.1	22.4	17.0
	DBStd	18.48	13.43	13.44	10.13	7.17	7.23	6.59	5.50	5.70	6.01	7.79	10.08	12.78
	HDD50	6465	1192	1009	893	539	234	48	2	22	153	523	829	1021
	HDD65	11369	1657	1429	1358	989	674	387	211	333	579	987	1279	1486
	CDD50	590	0	0	0	0	25	114	269	157	24	1	0	0
	CDD65	19	0	0	0	0	0	3	13	3	0	0	0	0
	CDH74	226	0	0	0	0	6	50	141	29	0	0	0	0
	CDH80	29	0	0	0	0	0	6	21	2	0	0	0	0
Wind	WSAvg	6.7	5.3	5.8	7.6	7.2	7.7	8.3	7.1	6.5	7.1	6.5	5.4	5.8
Precipitation	PrecAvg	23.1	1.4	1.1	1.0	1.1	1.7	2.5	3.5	3.0	2.5	2.0	1.9	1.5
	PrecMax	34.4	2.3	2.0	2.1	2.0	3.1	5.1	5.8	5.9	6.1	3.8	4.0	2.2
	PrecMin	17.4	0.6	0.3	0.4	0.4	0.4	0.7	0.7	0.8	0.6	0.6	0.7	0.8
	PrecStd	4.8	0.5	0.5	0.5	0.5	0.8	1.2	1.3	1.7	1.5	1.0	1.0	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	41.8	45.3	58.7	73.7	79.9	82.8	77.5	66.0	53.1	44.9	40.8
		MCWB	38.2	37.6	38.1	46.1	55.7	60.9	63.3	62.5	55.5	48.1	41.9	37.4
	2%	DB	36.6	39.0	41.0	52.0	67.9	73.6	77.9	73.2	61.3	49.2	41.0	37.7
		MCWB	34.1	35.5	35.7	40.9	53.7	57.0	61.1	60.4	53.2	45.3	39.1	35.0
	5%	DB	32.9	35.2	38.6	47.5	62.5	68.9	74.0	69.1	58.0	46.6	37.6	35.3
		MCWB	31.1	32.2	34.2	39.6	50.6	55.1	59.9	59.0	51.8	43.4	35.6	33.3
	10%	DB	29.7	31.8	36.0	43.9	56.9	65.0	70.4	64.9	55.4	44.2	34.9	33.0
		MCWB	28.7	30.1	32.2	37.5	47.2	53.1	58.1	56.7	50.6	41.5	33.6	31.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.1	37.9	38.6	46.2	57.8	62.4	65.7	64.8	57.3	49.0	42.9	37.7
		MCDB	41.2	41.4	43.4	56.9	68.6	74.4	75.9	73.0	61.3	51.3	44.9	40.2
	2%	WB	34.3	35.6	36.3	42.7	54.8	59.5	63.5	62.1	54.9	46.0	39.2	35.4
		MCDB	36.2	38.7	40.4	50.4	65.9	69.9	73.2	69.9	59.2	48.5	41.2	37.1
	5%	WB	31.2	32.3	34.4	40.1	51.5	56.8	61.7	60.3	53.1	43.9	35.8	33.4
		MCDB	32.5	34.3	38.3	46.3	60.8	65.5	70.5	66.7	57.0	46.2	37.2	34.7
	10%	WB	28.6	30.0	32.4	37.8	47.9	54.4	59.8	58.0	51.3	41.9	33.7	31.5
		MCDB	29.7	31.6	35.5	43.5	56.1	62.5	68.2	64.0	54.6	44.0	34.7	32.8
Mean Daily Temperature Range	5% DB	MDBR	13.7	14.6	16.9	15.8	16.6	15.6	15.9	14.9	13.5	10.2	10.4	13.1
		MCDBR	12.9	13.0	15.7	21.2	26.7	22.3	22.2	22.1	17.9	12.6	9.8	12.5
		MCWBR	11.8	11.3	12.2	12.8	14.0	9.4	9.1	10.9	11.4	9.7	9.0	11.6
	5% WB	MCDBR	12.2	12.5	15.1	19.4	24.6	20.2	19.3	18.6	15.3	11.6	9.4	11.9
		MCWBR	11.3	11.2	12.2	12.1	13.9	9.7	9.4	10.1	10.7	9.2	8.7	11.2
Clear-Sky Solar Irradiance	taub	0.179	0.251	0.283	0.313	0.327	0.328	0.340	0.325	0.297	0.277	0.337	N/A	
	taud	1.952	2.182	2.246	2.321	2.484	2.514	2.492	2.522	2.582	2.434	2.773	N/A	
	Ebn at Noon	99	202	251	272	280	281	274	267	253	198	99	N/A	
	Edh at Noon	6	16	25	30	29	29	29	25	19	13	6	N/A	
All-Sky Solar Radiation	RadAvg	34	219	701	1286	1563	1650	1513	1144	652	251	56	8	
	RadStd	3	38	54	70	178	139	163	119	82	42	9	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page