

JOKKMOKK, Sweden

WMO: 021510

Lat: 66.496N

Lon: 20.147E

Elev: 902

StdP: 14.22

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.8	-19.9	-29.7	1.1	-24.8	-24.6	1.4	-19.9	23.4	31.5	21.2	28.1	0.6	280	0.702

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	76.3	61.7	72.5	59.8	69.1	58.2	64.2	72.6	61.9	68.9	59.9	66.5	6.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.2	83.5	67.1	59.1	77.3	64.2	57.0	71.5	62.2	29.8	72.3	28.1	69.1	26.7	66.7	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.6	15.7	13.5	DB	-27.4	79.8	7.5	4.6	-32.8	83.1	-37.1	85.7	-41.3	88.3	-46.7	91.6	(4)
			WB	-27.3	66.1	6.9	3.7	-32.3	68.7	-36.3	70.9	-40.2	72.9	-45.2	75.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.2	9.0	9.5	20.7	31.5	41.8	51.5	58.1	54.0	44.8	32.6	17.0	13.7
	DBStd	19.80	14.80	14.50	10.41	7.61	7.29	6.01	5.02	6.12	6.17	7.90	11.98	14.14
	HDD50	7051	1271	1133	908	555	272	50	2	29	176	540	990	1125
	HDD65	11999	1736	1553	1373	1005	718	407	222	345	605	1005	1440	1590
	CDD50	539	0	0	0	0	19	95	253	152	20	0	0	0
	CDD65	12	0	0	0	0	0	2	7	3	0	0	0	0
	CDH74	204	0	0	0	0	7	40	114	43	0	0	0	0
	CDH80	23	0	0	0	0	0	8	12	3	0	0	0	0
Wind	WSAvg	5.3	4.4	4.4	6.2	5.9	6.2	6.7	5.9	5.2	5.5	4.9	3.6	4.1
Precipitation	PrecAvg	24.8	1.8	1.2	1.3	1.1	1.9	2.8	3.6	3.0	2.2	2.0	2.0	1.8
	PrecMax	34.3	3.4	2.3	2.5	2.6	3.8	4.7	6.1	5.8	8.5	4.5	4.1	6.0
	PrecMin	15.4	0.1	0.2	0.4	0.3	0.3	0.7	0.9	0.9	0.4	0.7	0.5	0.4
	PrecStd	4.9	0.7	0.7	0.6	0.6	0.9	1.1	1.3	1.6	1.7	0.9	1.1	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.5	43.8	46.7	57.3	74.0	79.6	81.7	78.7	65.7	53.5	44.1	42.6
		MCWB	39.5	39.2	39.7	45.7	56.2	62.5	65.0	65.0	56.8	48.5	41.5	38.8
	2%	DB	37.9	39.0	42.1	50.7	67.7	71.8	77.2	74.0	61.1	49.9	39.2	39.3
		MCWB	34.4	35.4	36.9	42.0	54.3	57.3	62.7	61.3	53.9	46.0	36.3	35.8
	5%	DB	33.4	34.6	39.2	47.0	61.0	67.9	73.7	70.3	58.4	47.0	36.0	35.5
		MCWB	31.1	31.7	34.8	40.0	50.7	55.7	60.8	60.2	52.9	43.7	34.0	33.3
	10%	DB	29.8	30.2	36.1	43.4	55.6	63.8	70.1	66.0	55.7	44.0	33.2	32.3
		MCWB	28.3	28.6	32.3	37.7	46.9	53.6	59.2	58.3	51.3	41.3	32.2	31.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.6	39.6	39.9	45.9	58.8	64.2	67.3	67.3	58.1	49.5	41.8	39.2
		MCDB	43.2	43.4	45.2	54.9	70.8	75.0	75.9	75.2	62.6	52.1	43.5	42.3
	2%	WB	34.6	35.6	37.3	42.8	55.1	60.7	65.0	63.7	55.8	46.7	36.8	35.9
		MCDB	37.5	38.8	41.5	49.0	64.9	67.8	73.8	70.6	59.7	49.3	38.4	38.6
	5%	WB	31.4	31.7	35.1	40.3	51.0	57.4	62.7	61.2	54.0	44.3	34.3	33.4
		MCDB	33.1	34.1	38.8	46.1	60.0	64.2	70.0	67.7	56.8	46.5	35.5	35.1
	10%	WB	28.1	28.5	32.5	38.1	47.8	54.9	60.7	58.9	52.2	41.7	32.3	31.2
		MCDB	29.6	30.4	35.5	43.0	54.7	61.8	67.5	65.1	54.9	43.7	33.1	32.4
Mean Daily Temperature Range	5% DB	MDBR	15.0	16.1	17.8	16.5	17.0	15.7	17.2	17.3	14.8	11.6	12.7	14.0
		MCDBR	16.3	18.2	17.3	20.9	27.4	24.1	24.6	24.3	20.1	14.7	14.1	15.3
		MCWBR	14.6	15.6	13.2	13.1	15.3	12.2	11.9	12.7	13.6	11.3	12.5	13.7
	5% WB	MCDBR	14.8	17.4	16.6	19.5	25.6	20.7	21.0	21.3	16.8	13.9	12.8	14.1
		MCWBR	13.4	15.2	12.9	12.6	15.0	11.7	11.4	12.5	12.0	11.3	11.7	12.9
Clear-Sky Solar Irradiance	taub	0.181	0.249	0.284	0.313	0.331	0.334	0.344	0.329	0.298	0.275	0.340	0.185	
	taud	1.943	2.158	2.230	2.291	2.475	2.502	2.486	2.513	2.576	2.407	2.771	1.963	
	Ebn at Noon	75	194	246	269	277	278	271	264	249	189	82	7	
	Edh at Noon	5	16	25	31	29	29	29	25	18	13	5	1	
All-Sky Solar Radiation	RadAvg	24	196	668	1263	1571	1635	1515	1125	629	226	47	2	
	RadStd	2	28	45	60	155	135	156	104	89	37	6	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page