

JOKKMOKK, Sweden

WMO: 021510

Lat: 66.496N

Lon: 20.147E

Elev: 275

StdP: 98.06

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.5	-28.9	-34.3	0.2	-31.5	-31.5	0.2	-28.8	10.5	-0.3	9.5	-2.1	0.3	280	0.702

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	24.6	16.5	22.5	15.5	20.6	14.6	17.9	22.6	16.6	20.5	15.5	19.2	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.2	11.9	19.5	15.1	11.0	17.9	13.9	10.2	16.8	51.5	22.4	47.5	20.6	44.2	19.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.0	6.0	-33.0	26.5	4.1	2.5	-36.0	28.4	-38.4	29.9	-40.7	31.3	-43.7	33.1		
			-32.9	19.0	3.8	2.0	-35.7	20.4	-38.0	21.6	-40.1	22.7	-42.9	24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.1	-12.8	-12.5	-6.3	-0.3	5.5	10.8	14.5	12.2	7.1	0.3	-8.3	-10.2
	DBStd	11.00	8.22	8.06	5.79	4.23	4.05	3.34	2.79	3.40	3.43	4.39	6.65	7.86
	HDD10.0	3917	706	629	504	308	151	28	1	16	98	300	550	625
	HDD18.3	6666	964	863	763	558	399	226	123	192	336	558	800	883
	CDD10.0	299	0	0	0	0	11	53	141	84	11	0	0	0
	CDD18.3	7	0	0	0	0	0	1	4	2	0	0	0	0
	CDH23.3	113	0	0	0	0	4	22	63	24	0	0	0	0
	CDH26.7	13	0	0	0	0	0	4	7	2	0	0	0	0
Wind	WSAvg	2.3	2.0	2.0	2.8	2.6	2.8	3.0	2.7	2.3	2.4	2.2	1.6	1.8
Precipitation	PrecAvg	630	45	31	33	29	48	70	92	77	56	50	51	46
	PrecMax	872	87	58	64	66	96	120	154	147	217	114	105	153
	PrecMin	392	3	4	9	8	8	19	24	22	9	17	12	9
	PrecStd	124	18	17	15	15	22	28	34	40	44	22	27	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	6.6	8.2	14.1	23.4	26.5	27.6	25.9	18.7	12.0	6.7	5.9
		MCWB	4.1	4.0	4.3	7.6	13.4	17.0	18.3	18.3	13.8	9.1	5.3	3.8
	2%	DB	3.3	3.9	5.6	10.4	19.8	22.1	25.1	23.3	16.2	10.0	4.0	4.0
		MCWB	1.3	1.9	2.7	5.5	12.4	14.1	17.0	16.3	12.1	7.8	2.4	2.1
	5%	DB	0.8	1.5	4.0	8.3	16.1	20.0	23.1	21.3	14.7	8.3	2.2	1.9
		MCWB	-0.5	-0.2	1.5	4.4	10.4	13.2	16.0	15.7	11.6	6.5	1.1	0.7
	10%	DB	-1.2	-1.0	2.3	6.3	13.1	17.7	21.2	18.9	13.2	6.7	0.7	0.2
		MCWB	-2.1	-1.9	0.2	3.1	8.3	12.0	15.1	14.6	10.7	5.2	0.1	-0.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	4.2	4.4	7.7	14.9	17.9	19.6	19.6	14.5	9.7	5.4	4.0
		MCDB	6.2	6.4	7.3	12.7	21.5	23.9	24.4	24.0	17.0	11.2	6.4	5.7
	2%	WB	1.5	2.0	2.9	6.0	12.8	15.9	18.3	17.6	13.2	8.2	2.6	2.2
		MCDB	3.1	3.8	5.3	9.5	18.3	19.9	23.2	21.4	15.4	9.6	3.6	3.6
	5%	WB	-0.3	-0.1	1.7	4.6	10.5	14.1	17.1	16.2	12.2	6.8	1.3	0.8
		MCDB	0.6	1.2	3.8	7.9	15.5	17.9	21.1	19.8	13.8	8.1	2.0	1.7
	10%	WB	-2.2	-1.9	0.3	3.4	8.8	12.7	16.0	14.9	11.2	5.4	0.2	-0.4
		MCDB	-1.4	-0.9	2.0	6.1	12.6	16.6	19.7	18.4	12.7	6.5	0.6	0.2
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.9	9.9	9.2	9.5	8.7	9.6	9.6	8.2	6.4	7.1	7.8
		MCDBR	9.1	10.1	9.6	11.6	15.2	13.4	13.7	13.5	11.2	8.1	7.8	8.5
		MCWBR	8.1	8.7	7.3	7.3	8.5	6.8	6.6	7.1	7.5	6.3	7.0	7.6
	5% WB	MCDBR	8.2	9.7	9.2	10.8	14.2	11.5	11.7	11.8	9.3	7.7	7.1	7.9
		MCWBR	7.5	8.4	7.2	7.0	8.3	6.5	6.3	6.9	6.7	6.3	6.5	7.1
Clear-Sky Solar Irradiance	taub	0.181	0.249	0.284	0.313	0.331	0.334	0.344	0.329	0.298	0.275	0.340	0.185	
	taud	1.943	2.158	2.230	2.291	2.475	2.502	2.486	2.513	2.576	2.407	2.771	1.963	
	Ebn at Noon	237	611	777	848	873	877	854	833	785	596	258	22	
	Edh at Noon	15	50	79	97	91	91	90	79	58	40	16	3	
All-Sky Solar Radiation	RadAvg	0.07	0.62	2.11	3.98	4.95	5.15	4.78	3.55	1.98	0.71	0.15	0.01	
	RadStd	0.01	0.09	0.14	0.19	0.49	0.43	0.49	0.33	0.28	0.12	0.02	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page