

VIDSEL, Sweden

WMO: 021540

Lat: 65.875N

Lon: 20.150E

Elev: 182

StdP: 99.16

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -31.5	(c) -28.1	(d) -34.4	(e) 0.1	(f) -31.4	(g) -30.7	(h) 0.2	(i) -28.0	(j) 8.8	(k) 0.9	(l) 7.1	(m) -1.4	(n) 0.6	(o) 280	(p) 0.661

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	25.7	16.4	23.7	15.7	21.7	14.9	18.0	23.4	16.9	21.6	15.8	20.1	3.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	11.7	19.4	15.0	10.9	18.5	13.9	10.1	17.4	51.6	23.5	48.0	21.5	44.8	20.0	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.8	6.4	5.5	-34.7	28.1	3.2	2.4	-36.9	29.9	-38.8	31.3	-40.6	32.6	-42.9	34.4
			-34.8	19.3	3.2	1.4	-37.0	20.3	-38.9	21.1	-40.7	21.8	-43.0	22.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.2	-11.7	-11.0	-5.7	0.7	6.6	12.1	15.3	12.9	7.9	0.9	-5.6	-9.4		
	DBStd	10.88	8.10	8.33	6.14	4.03	4.01	3.68	2.89	3.33	3.56	4.67	6.43	7.92		
	HDD10.0	3608	672	588	487	278	121	18	1	11	82	282	469	601		
	HDD18.3	6284	931	822	745	528	363	190	103	172	313	540	719	859		
	CDD10.0	378	0	0	0	0	16	81	164	99	19	0	0	0		
	CDD18.3	13	0	0	0	0	0	3	8	2	0	0	0	0		
	CDH23.3	209	0	0	0	0	8	52	107	43	0	0	0	0		
	CDH26.7	31	0	0	0	0	0	8	18	4	0	0	0	0		
(14) Wind	WSAvg	2.1	1.5	1.9	2.4	2.3	2.6	2.8	2.3	2.1	2.1	1.9	1.5	1.6		
(15) Precipitation	PrecAvg	641	46	33	32	30	47	78	95	83	61	46	47	43		
	PrecMax	1272	112	87	62	86	161	201	234	175	197	147	86	131		
	PrecMin	369	2	5	5	6	7	19	18	22	11	11	7	7		
	PrecStd	194	22	19	16	19	29	36	43	45	43	27	24	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	6.8	9.0	16.1	24.3	27.6	28.8	27.0	20.6	12.5	8.4	6.1		
		MCWB	3.9	4.2	4.9	9.2	13.6	16.3	18.3	18.0	14.3	9.4	6.2	4.0		
	2%	DB	4.1	4.8	6.5	12.2	21.0	24.6	26.2	24.2	17.6	10.6	5.8	4.2		
		MCWB	2.2	2.5	3.2	6.5	12.8	15.0	17.0	16.4	13.0	8.5	4.4	2.5		
	5%	DB	1.6	2.4	4.9	9.8	17.6	22.0	24.1	22.2	15.7	9.3	3.9	2.5		
		MCWB	0.3	0.7	2.3	5.1	10.6	14.0	16.3	15.8	12.0	7.5	2.8	1.3		
	10%	DB	-0.7	0.3	3.3	7.8	14.6	19.7	22.0	19.8	14.2	7.6	2.4	1.0		
		MCWB	-1.3	-0.8	1.0	3.9	8.9	12.9	15.5	14.6	11.2	6.1	1.5	0.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	4.4	5.1	9.0	15.2	17.7	19.7	19.2	15.2	10.3	6.4	4.1		
		MCDB	6.1	6.6	8.7	15.5	22.0	25.0	24.0	25.3	18.2	11.5	7.9	5.7		
	2%	WB	2.3	2.6	3.4	6.8	13.3	16.2	18.5	17.6	13.9	8.9	4.5	2.6		
		MCDB	3.8	4.5	6.0	11.4	20.0	21.9	23.7	22.3	16.8	10.2	5.6	3.9		
	5%	WB	0.3	0.7	2.4	5.5	11.1	14.9	17.4	16.3	12.7	7.5	2.9	1.4		
		MCDB	1.3	2.2	4.7	9.3	16.4	20.4	22.2	20.5	15.0	9.0	3.8	2.3		
	10%	WB	-1.3	-0.7	1.1	4.2	9.4	13.6	16.3	15.1	11.7	6.2	1.6	0.3		
		MCDB	-0.7	0.3	3.2	7.5	13.9	18.8	20.7	19.0	13.6	7.6	2.3	1.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.9	10.8	10.0	10.2	9.4	9.5	10.1	9.2	6.9	6.6	8.1		
		MCDBR	9.1	9.4	10.2	13.3	16.3	13.9	13.9	14.6	12.0	8.2	6.4	7.7		
		MCWBR	8.0	7.7	7.7	8.3	8.8	6.3	6.2	7.6	7.8	6.3	5.6	7.0		
		MCDBR	8.4	8.9	9.5	12.6	15.0	11.8	11.6	12.2	10.3	7.5	5.8	7.2		
	5% WB	MCWBR	7.5	7.6	7.4	8.0	8.4	5.9	6.0	6.8	7.1	6.0	5.1	6.6		
(40) Clear-Sky Solar Irradiance	taub		0.187	0.258	0.291	0.322	0.336	0.339	0.350	0.334	0.304	0.283	0.338	N/A		
	taud		1.954	2.166	2.232	2.315	2.467	2.492	2.473	2.505	2.569	2.415	2.725	N/A		
	Ebn at Noon		275	615	776	844	870	874	850	830	784	603	281	N/A		
	Edh at Noon		18	52	81	96	92	92	92	80	60	42	18	N/A		
(44) All-Sky Solar Radiation	RadAvg		0.10	0.67	2.19	4.02	4.93	5.25	4.87	3.63	2.06	0.77	0.17	0.02		
	RadStd		0.01	0.10	0.17	0.22	0.51	0.43	0.49	0.35	0.28	0.13	0.03	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page