

RODKALLEN, Sweden

WMO: 021880

Lat: 65.312N

Lon: 22.371E

Elev: 7

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.7	-4.1	-14.3	2.5	-9.8	-8.1	3.6	-4.0	36.8	29.7	34.3	27.7	7.6	350	0.821

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	70.6	65.7	67.8	63.2	65.6	61.8	66.5	69.8	64.2	66.9	62.3	64.9	9.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	92.8	68.8	62.9	85.9	66.2	61.0	80.2	64.3	31.2	69.9	29.4	67.0	28.0	65.0	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.4	29.8	26.7	-13.1	72.8	7.0	4.7	-18.2	76.1	-22.3	78.9	-26.3	81.5	-31.4	84.9		
(5)			-12.0	67.1	6.5	3.2	-16.7	69.4	-20.6	71.3	-24.2	73.2	-29.0	75.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.1	20.7	17.7	22.4	30.8	41.5	52.3	60.5	59.0	51.6	41.3	31.8	26.4	
	DBStd	16.27	10.89	12.48	9.19	5.03	5.31	4.47	4.60	4.26	4.74	5.57	6.91	9.01	
	HDD50	5126	909	903	856	575	269	25	0	1	39	272	545	732	
	HDD65	9829	1374	1323	1321	1025	728	380	157	192	401	736	995	1197	
	CDD50	794	0	0	0	0	6	95	324	280	88	1	0	0	
	CDD65	22	0	0	0	0	0	0	16	6	0	0	0	0	
	CDH74	11	0	0	0	0	0	0	11	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	13.2	13.8	13.4	13.0	11.2	11.4	11.6	11.1	12.9	14.3	15.1	15.2	15.4	
Precipitation	PrecAvg	19.6	1.4	1.1	0.8	1.1	1.4	2.0	2.2	2.1	2.0	2.0	2.0	1.5	
	PrecMax	29.3	3.7	1.9	2.1	2.6	4.1	4.5	5.0	4.9	5.7	5.8	4.1	3.3	
	PrecMin	10.6	0.5	0.2	0.3	0.3	0.3	0.1	0.7	0.4	0.4	0.3	0.5	0.4	
	PrecStd	5.0	0.7	0.4	0.5	0.7	0.8	1.2	1.1	1.2	1.2	1.3	1.0	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.6	38.0	38.9	43.2	59.5	67.3	75.1	71.8	62.4	52.4	45.9	40.8	
		MCWB	35.4	35.2	35.1	38.3	51.7	58.7	68.3	66.7	58.0	49.5	43.7	39.4	
	2%	DB	35.7	36.0	37.1	40.5	54.6	62.8	72.4	69.0	60.2	50.9	43.9	38.9	
		MCWB	34.3	34.0	34.2	37.2	49.0	56.7	67.1	64.9	56.4	48.9	42.7	37.5	
	5%	DB	34.4	34.0	35.3	38.3	51.2	60.4	69.4	66.8	58.9	49.8	41.8	37.5	
		MCWB	33.5	32.9	33.3	35.8	46.9	55.3	64.7	62.8	55.7	48.2	40.5	36.3	
	10%	DB	33.1	32.6	33.8	36.7	48.8	58.5	67.0	65.0	57.8	48.6	40.5	36.3	
		MCWB	32.3	31.8	32.5	34.7	45.1	54.2	62.8	61.3	55.2	46.7	39.3	35.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.0	35.8	35.9	39.4	53.6	59.9	70.0	68.3	59.3	50.7	44.5	39.9
			MCDB	36.7	37.3	37.6	42.3	56.8	64.8	73.9	71.0	61.1	51.2	45.3	40.5
2%		WB	34.6	34.2	34.6	37.6	49.1	58.0	67.8	65.6	57.8	49.7	42.1	37.8	
		MCDB	35.3	35.2	36.1	39.7	52.6	61.4	71.5	68.1	59.1	50.4	42.7	38.4	
5%		WB	33.7	33.1	33.6	36.2	47.2	56.3	65.6	63.5	56.7	48.5	40.4	36.5	
		MCDB	34.4	33.9	34.8	37.8	50.8	59.2	68.9	66.0	58.1	49.6	41.1	37.3	
10%		WB	32.4	32.0	32.7	34.9	45.2	54.8	63.6	61.9	55.8	46.9	39.2	35.3	
		MCDB	33.1	32.7	33.8	36.2	48.2	57.5	66.3	64.3	57.4	48.3	40.2	36.2	
Mean Daily Temperature Range	5% DB	MDBR	8.9	10.5	10.7	8.0	6.7	6.3	5.6	5.1	5.0	4.8	5.8	6.8	
		MCDBR	5.8	8.0	7.6	8.2	11.0	8.9	7.2	6.1	5.5	4.2	4.9	4.7	
		MCWBR	5.6	7.5	6.4	5.9	6.6	5.5	5.0	4.6	4.6	4.2	5.2	4.8	
	5% WB	MCDBR	6.0	7.1	6.9	7.2	9.9	7.9	6.3	5.1	4.0	4.0	4.8	4.8	
		MCWBR	5.9	6.8	6.1	5.4	6.7	5.5	5.0	4.2	3.7	4.2	5.2	4.9	
Clear-Sky Solar Irradiance	taub	N/A	0.274	0.301	0.336	0.344	0.349	0.365	0.351	0.323	0.302	0.340	0.349		
	taud	N/A	2.113	2.166	2.213	2.430	2.498	2.474	2.503	2.552	2.374	2.581	2.602		
	Ebn at Noon	N/A	189	242	262	274	275	266	259	242	185	85	32		
	Edh at Noon	N/A	18	28	34	30	30	30	26	20	15	6	3		
All-Sky Solar Radiation	RadAvg	30	205	697	1267	1637	1841	1685	1240	676	246	48	8		
	RadStd	3	37	67	78	143	143	146	109	85	45	8	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page