

KALIX-STORON, Sweden

WMO: 021910

Lat: 65.697N

Lon: 23.096E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.5	-9.4	-19.5	1.9	-14.4	-13.9	2.6	-9.4	33.3	32.2	29.9	28.8	4.7	320	0.748

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	72.9	67.5	69.9	64.2	67.2	62.0	68.4	72.0	65.5	69.1	62.9	66.4	8.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	99.7	70.6	63.8	88.7	68.5	61.1	80.5	65.3	32.7	72.5	30.4	69.3	28.4	66.5	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.8	26.3	23.3	-20.0	75.6	6.6	3.1	-24.7	77.9	-28.6	79.7	-32.3	81.5	-37.1	83.8		
(5)			-19.5	66.9	5.7	2.7	-23.6	68.8	-27.0	70.4	-30.1	71.9	-34.3	73.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.1	15.7	14.7	21.8	31.7	43.1	53.8	61.0	59.0	50.6	39.2	30.0	23.2
	DBStd	17.89	12.38	12.90	9.20	5.23	6.90	5.28	5.13	4.97	5.26	6.81	8.76	11.29
	HDD50	5560	1062	988	874	550	237	21	1	3	56	337	601	830
	HDD65	10210	1527	1408	1339	1000	679	337	146	196	431	801	1051	1295
	CDD50	858	0	0	0	0	24	135	342	281	75	1	0	0
	CDD65	34	0	0	0	0	1	2	23	8	0	0	0	0
	CDH74	46	0	0	0	0	2	6	36	2	0	0	0	0
	CDH80	2	0	0	0	0	0	1	1	0	0	0	0	0
Wind	WSAvg	10.2	10.2	10.1	9.9	8.7	8.9	9.3	8.6	9.9	11.6	11.4	11.7	12.2
Precipitation	PrecAvg	20.4	1.5	1.3	1.3	1.1	1.4	1.7	2.0	2.1	2.2	2.0	2.0	1.7
	PrecMax	27.6	2.6	3.2	2.3	2.8	2.4	3.5	3.6	6.1	5.8	4.4	3.9	4.8
	PrecMin	13.4	0.4	0.2	0.5	0.3	0.3	0.2	0.4	0.6	0.7	0.7	0.7	0.3
	PrecStd	3.7	0.5	0.7	0.6	0.7	0.6	0.8	0.9	1.3	1.2	0.9	1.0	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.8	38.8	40.4	47.6	69.2	71.3	78.3	73.5	61.7	52.7	46.2	39.6
		MCWB	36.3	35.3	35.8	40.6	56.9	60.7	68.1	68.6	56.3	48.9	43.1	37.4
	2%	DB	35.4	36.4	37.8	43.0	61.4	66.3	74.4	70.8	59.9	50.7	44.3	37.7
		MCWB	33.9	34.1	34.3	37.5	52.3	57.3	68.2	66.4	56.1	48.3	42.7	36.0
	5%	DB	33.5	33.5	35.5	40.3	56.6	63.9	71.9	68.0	58.8	49.5	41.8	36.6
		MCWB	32.5	32.4	32.7	35.9	49.4	57.0	66.3	63.5	55.8	47.5	40.2	35.2
	10%	DB	31.9	31.8	33.7	38.4	52.6	61.5	69.0	65.9	57.9	48.1	40.3	35.5
		MCWB	31.2	31.0	32.0	34.9	47.2	55.5	63.8	61.4	55.1	46.0	38.9	34.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.4	36.0	36.5	41.4	58.4	63.2	72.9	71.4	58.6	50.3	44.3	37.9
		MCDB	38.2	38.2	39.3	46.3	67.1	67.7	74.0	71.6	59.6	51.1	45.1	38.7
	2%	WB	34.1	34.4	34.8	38.5	53.7	60.3	70.2	67.2	57.5	49.0	43.1	36.5
		MCDB	35.0	35.9	36.9	41.6	60.4	63.8	73.3	69.8	58.9	50.2	44.6	37.2
	5%	WB	32.7	32.6	33.3	36.7	50.1	58.2	67.3	64.3	56.7	47.8	40.7	35.5
		MCDB	33.5	33.6	34.8	39.4	55.0	62.4	71.4	67.4	58.3	49.2	41.8	36.2
	10%	WB	31.1	30.9	32.4	35.4	47.6	56.5	64.7	62.1	55.5	46.3	39.1	34.5
		MCDB	32.0	31.8	33.6	37.6	52.1	60.4	68.6	65.1	57.5	48.0	40.2	35.4
Mean Daily Temperature Range	5% DB	MDBR	11.5	13.3	13.2	10.5	9.0	8.1	7.9	7.1	6.7	6.7	7.3	9.1
		MCDBR	8.0	11.3	12.6	12.6	15.1	11.4	10.7	8.5	5.7	5.2	5.8	6.0
		MCWBR	7.7	10.3	10.2	8.7	8.5	6.6	7.5	5.9	4.6	4.7	5.6	5.7
	5% WB	MCDBR	8.3	11.2	10.0	11.5	13.1	9.3	8.9	6.9	4.7	4.6	5.6	5.8
		MCWBR	8.1	10.4	8.6	8.3	8.3	6.3	7.7	5.5	4.2	4.4	5.5	5.7
Clear-Sky Solar Irradiance	taub	0.203	0.270	0.299	0.334	0.343	0.348	0.363	0.349	0.322	0.300	0.341	0.352	
	taud	1.946	2.094	2.144	2.183	2.415	2.496	2.472	2.500	2.549	2.368	2.593	2.620	
	Ebn at Noon	81	186	240	261	273	275	266	259	241	182	79	26	
	Edh at Noon	6	18	28	35	31	29	29	26	20	14	6	3	
All-Sky Solar Radiation	RadAvg	27	197	685	1259	1615	1809	1666	1218	657	238	45	5	
	RadStd	3	35	63	70	144	139	145	106	86	44	7	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page