

KALIX-STORON, Sweden

WMO: 021910

Lat: 65.697N

Lon: 23.096E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-25.8	-23.0	-28.6	0.3	-25.8	-25.5	0.4	-23.0	14.9	0.1	13.4	-1.8	2.1	320	0.748

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	22.7	19.7	21.0	17.9	19.6	16.7	20.2	22.2	18.6	20.6	17.2	19.1	3.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.2	21.4	17.7	12.7	20.3	16.2	11.5	18.5	58.2	22.5	52.8	20.7	48.3	19.2	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	11.8	10.4	DB	-28.9	24.2	3.7	1.7	-31.5	25.5	-33.7	26.5	-35.7	27.5	-38.4	28.8	(4)
(5)			WB	-28.6	19.4	3.2	1.5	-30.9	20.5	-32.8	21.3	-34.5	22.2	-36.8	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.8	-9.0	-9.6	-5.7	-0.2	6.2	12.1	16.1	15.0	10.4	4.0	-1.1	-4.9	(6)	
	DBStd	9.94	6.88	7.17	5.11	2.91	3.84	2.94	2.85	2.76	2.92	3.78	4.87	6.27	(7)	
	HDD10.0	3089	590	549	486	306	132	12	1	2	31	187	334	461	(8)	
	HDD18.3	5672	848	782	744	556	377	187	81	109	239	445	584	719	(9)	
	CDD10.0	477	0	0	0	0	13	75	190	156	42	1	0	0	(10)	
	CDD18.3	19	0	0	0	0	1	1	13	4	0	0	0	0	(11)	
	CDH23.3	26	0	0	0	0	1	3	20	1	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	1	1	0	0	0	0	0	(13)	
(14) Wind	WSAvg	4.6	4.6	4.5	4.4	3.9	4.0	4.2	3.8	4.4	5.2	5.1	5.2	5.5	(14)	
(15) Precipitation	PrecAvg	517	38	32	33	29	35	43	50	54	57	52	52	44	(15)	
	PrecMax	700	65	81	59	72	62	88	92	156	148	111	99	123	(16)	
	PrecMin	340	9	5	12	8	8	6	9	15	19	17	18	8	(17)	
	PrecStd	94	13	18	14	17	15	20	23	33	31	23	26	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.8	3.8	4.7	8.7	20.7	21.8	25.7	23.1	16.5	11.5	7.9	4.2	(19)	
		MCWB	2.4	1.8	2.1	4.8	13.8	15.9	20.1	20.3	13.5	9.4	6.2	3.0	(20)	
	2%	DB	1.9	2.5	3.2	6.1	16.4	19.0	23.5	21.5	15.5	10.4	6.9	3.2	(21)	
		MCWB	1.0	1.2	1.3	3.0	11.3	14.0	20.1	19.1	13.4	9.1	6.0	2.2	(22)	
	5%	DB	0.9	0.8	1.9	4.6	13.6	17.7	22.2	20.0	14.9	9.7	5.5	2.5	(23)	
		MCWB	0.3	0.2	0.4	2.2	9.6	13.9	19.0	17.5	13.2	8.6	4.5	1.8	(24)	
	10%	DB	0.0	-0.1	0.9	3.6	11.4	16.4	20.6	18.9	14.4	8.9	4.6	2.0	(25)	
		MCWB	-0.5	-0.6	0.0	1.6	8.4	13.1	17.7	16.4	12.8	7.8	3.8	1.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	2.2	2.5	5.2	14.6	17.4	22.7	21.9	14.8	10.2	6.8	3.3	(27)	
		MCDB	3.4	3.4	4.1	7.9	19.5	19.8	23.3	22.0	15.4	10.6	7.3	3.7	(28)	
	2%	WB	1.2	1.3	1.5	3.6	12.1	15.7	21.2	19.5	14.2	9.4	6.2	2.5	(29)	
		MCDB	1.7	2.2	2.7	5.3	15.8	17.7	22.9	21.0	14.9	10.1	7.0	2.9	(30)	
	5%	WB	0.4	0.3	0.7	2.6	10.0	14.6	19.6	18.0	13.7	8.8	4.8	1.9	(31)	
		MCDB	0.8	0.9	1.6	4.1	12.8	16.9	21.9	19.7	14.6	9.6	5.4	2.3	(32)	
	10%	WB	-0.5	-0.6	0.2	1.9	8.6	13.6	18.2	16.7	13.1	8.0	3.9	1.4	(33)	
		MCDB	0.0	-0.1	0.9	3.1	11.2	15.8	20.3	18.4	14.2	8.9	4.6	1.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	7.4	7.4	5.9	5.0	4.5	4.4	3.9	3.7	3.7	4.1	5.1	(35)	
		MCDBR	4.5	6.3	7.0	7.0	8.4	6.4	6.0	4.7	3.2	2.9	3.2	3.3	(36)	
	5% WB	MCWBR	4.3	5.7	5.7	4.8	4.7	3.7	4.2	3.3	2.6	2.6	3.1	3.2	(37)	
		MCWBR	4.6	6.2	5.5	6.4	7.3	5.2	4.9	3.8	2.6	2.5	3.1	3.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.203	0.270	0.299	0.334	0.343	0.348	0.363	0.349	0.322	0.300	0.341	0.352	(40)	
		taud	1.946	2.094	2.144	2.183	2.415	2.496	2.472	2.500	2.549	2.368	2.593	2.620	(41)	
	Edn at Noon	Edn at Noon	256	586	758	824	861	866	837	815	761	574	249	83	(42)	
		Edh at Noon	20	57	89	110	97	92	92	81	62	45	19	10	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.08	0.62	2.16	3.97	5.09	5.70	5.25	3.84	2.07	0.75	0.14	0.02	(44)	
	RadStd	RadStd	0.01	0.11	0.20	0.22	0.45	0.44	0.46	0.34	0.27	0.14	0.02	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page