

HAPARANDA, Sweden

WMO: 021970

Lat: 65.824N

Lon: 24.111E

Elev: 52

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.9	-10.9	-21.0	1.7	-15.9	-15.5	2.4	-10.9	21.3	27.6	16.8	26.2	3.3	0	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	76.1	63.4	72.5	61.7	69.5	60.4	66.2	72.9	63.9	69.9	61.9	67.3	5.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.7	88.3	69.1	61.3	81.2	66.4	59.5	76.0	64.6	30.9	72.7	29.2	70.4	27.8	67.3	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.4	12.3	-22.2	81.1	4.7	5.2	-25.6	84.9	-28.4	87.9	-31.0	90.9	-34.5	94.6		
(5)			-22.6	68.4	4.6	3.1	-25.9	70.6	-28.5	72.4	-31.1	74.1	-34.4	76.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.0	14.3	14.3	22.5	32.8	44.0	53.7	60.6	57.1	48.2	36.6	26.9	19.9		
	DBStd	18.18	12.92	13.05	9.12	5.85	7.02	5.75	5.48	5.32	6.03	7.74	9.72	11.86		
	HDD50	5870	1107	1000	851	517	215	26	1	9	104	416	692	932		
	HDD65	10596	1572	1420	1316	967	651	340	158	250	503	880	1142	1397		
	CDD50	778	0	0	0	0	30	138	329	229	51	1	0	0		
	CDD65	29	0	0	0	0	1	3	20	5	0	0	0	0		
	CDH74	219	0	0	0	0	14	29	156	20	0	0	0	0		
	CDH80	35	0	0	0	0	1	6	27	1	0	0	0	0		
	WSAvg	5.9	5.9	5.9	6.1	5.6	6.1	6.2	5.6	5.7	5.9	5.9	5.9	5.9		
	PrecAvg	22.7	1.9	1.4	1.4	1.2	1.3	1.7	2.2	2.4	2.5	2.4	2.4	1.8		
	PrecMax	34.4	3.6	3.3	3.5	3.5	2.9	3.7	5.3	5.4	5.0	5.0	4.5	5.7		
	PrecMin	17.1	0.4	0.2	0.1	0.1	0.1	0.1	0.4	0.3	0.7	0.4	0.6	0.4		
	PrecStd	3.7	0.9	0.8	0.8	0.7	0.7	1.0	1.1	1.3	1.1	1.1	1.0	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.9	40.6	44.1	53.8	75.4	77.9	83.3	76.8	64.9	53.2	45.3	39.9		
		MCWB	35.7	36.0	36.7	42.9	58.1	62.3	66.9	64.4	55.8	50.0	43.2	38.2		
	2%	DB	35.0	36.4	40.2	48.7	66.7	72.1	77.7	71.7	61.8	51.0	43.1	37.5		
		MCWB	33.7	34.1	35.0	40.5	53.5	59.2	65.0	62.1	55.6	48.9	41.9	36.4		
	5%	DB	33.1	33.6	36.6	45.1	60.7	68.3	74.5	69.0	59.6	49.4	40.5	35.8		
		MCWB	32.4	32.8	33.2	38.5	50.2	56.9	63.4	61.1	55.1	47.3	39.4	34.9		
	10%	DB	31.7	32.0	34.2	42.0	55.9	65.1	71.4	66.7	57.7	47.2	38.7	34.3		
		MCWB	31.1	31.4	32.2	36.3	47.5	55.3	61.9	59.9	54.2	45.3	37.8	33.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.0	36.8	37.9	44.7	59.1	64.9	70.0	66.9	59.3	51.3	44.0	38.8		
		MCDB	38.1	39.7	42.7	49.5	72.2	74.1	76.1	72.9	61.7	52.1	44.7	39.2		
	2%	WB	34.1	34.4	35.6	41.2	54.8	61.4	67.5	64.6	57.5	49.4	41.9	36.7		
		MCDB	34.9	35.7	38.6	47.9	64.8	68.7	74.4	69.3	59.9	50.7	42.7	37.2		
	5%	WB	32.6	32.9	34.0	38.9	51.4	59.1	65.4	62.5	56.2	47.6	39.7	35.2		
		MCDB	33.1	33.7	35.8	44.1	58.7	65.3	72.4	66.8	58.5	48.9	40.4	35.8		
	10%	WB	30.9	31.4	32.7	37.1	48.6	57.0	63.3	60.9	54.8	45.6	37.9	33.7		
		MCDB	31.5	32.1	34.2	40.8	54.7	62.8	69.6	65.1	57.2	47.0	38.6	34.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	13.5	15.4	14.8	15.7	15.4	16.0	15.0	12.9	10.0	9.3	11.1		
		MCDBR	10.3	10.8	14.6	19.6	23.9	20.4	21.3	17.9	14.6	10.3	8.2	7.7		
		MCWBR	10.0	9.5	11.0	12.4	12.2	9.6	10.2	9.6	9.8	8.2	7.9	7.5		
	5% WB	MCDBR	10.4	10.2	11.9	17.6	21.2	16.0	18.0	14.2	11.6	8.3	8.0	7.7		
		MCWBR	10.2	9.2	9.6	11.7	11.7	9.1	9.9	8.7	8.5	7.3	7.9	7.6		
(40) Clear-Sky Solar Irradiance	taub		0.206	0.272	0.302	0.337	0.345	0.348	0.365	0.349	0.325	0.301	0.343	0.355		
	taud		1.947	2.099	2.159	2.221	2.425	2.481	2.454	2.485	2.533	2.351	2.582	2.614		
	Ebn at Noon		77	184	239	260	273	274	265	258	239	179	75	23		
	Edh at Noon		6	18	28	34	30	30	30	26	20	14	6	3		
(44) All-Sky Solar Radiation	RadAvg		26	185	657	1213	1572	1756	1630	1190	638	229	44	5		
	RadStd		2	35	65	86	143	134	144	106	74	41	7	0		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page