

YLINENJARVI, Sweden

WMO: 021990

Lat: 66.622N

Lon: 23.463E

Elev: 132

StdP: 99.75

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.5	-28.6	-35.3	0.1	-31.4	-31.9	0.2	-28.5	9.7	-3.7	8.4	-4.0	0.3	300	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	25.3	17.1	23.3	15.9	21.3	15.2	18.5	23.4	17.3	21.6	16.1	19.7	3.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.7	12.1	20.3	15.5	11.2	18.9	14.5	10.4	17.7	52.8	23.4	49.1	21.5	45.6	19.8	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.7	5.9	DB	-35.2	26.9	2.8	-37.2	28.6	-38.8	30.0	-40.4	31.3	-42.4	33.0		
(5)			WB	-35.1	20.3	2.7	-37.1	21.3	-38.7	22.1	-40.2	22.8	-42.2	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.5	-13.2	-12.2	-6.8	-0.1	6.5	11.4	14.8	12.3	7.4	0.2	-5.6	-9.3		
	DBStd	10.93	7.78	7.84	5.85	4.08	4.04	3.54	3.16	3.33	3.62	4.94	6.31	7.36		
	HDD10.0	3795	718	622	521	303	124	24	2	16	94	303	468	598		
	HDD18.3	6509	976	856	779	553	367	208	117	188	328	561	718	857		
	CDD10.0	337	0	0	0	0	16	68	151	87	16	0	0	0		
	CDD18.3	9	0	0	0	0	0	1	7	1	0	0	0	0		
	CDH23.3	166	0	0	0	0	7	23	113	22	0	0	0	0		
	CDH26.7	19	0	0	0	0	0	2	16	1	0	0	0	0		
(14) Wind	WSAvg	2.4	1.9	2.2	2.6	2.6	2.8	2.8	2.5	2.3	2.4	2.2	2.1	2.2		
(15) Precipitation	PrecAvg	539	37	29	33	27	36	52	73	64	50	49	47	40		
	PrecMax	721	68	64	63	70	59	89	127	138	117	94	89	103		
	PrecMin	412	9	4	8	9	2	4	23	16	15	20	23	8		
	PrecStd	88	13	15	15	16	15	22	31	26	27	21	19	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.9	5.4	7.9	15.0	24.4	26.0	28.8	25.7	18.2	11.5	6.7	3.9		
		MCWB	2.8	2.7	3.5	7.8	13.3	16.9	18.7	18.2	13.2	9.0	5.5	2.7		
	2%	DB	0.8	2.2	5.6	11.2	21.4	23.2	26.2	23.2	16.5	9.8	5.0	2.1		
		MCWB	0.2	0.8	2.1	5.6	13.3	14.5	18.0	16.4	12.5	8.0	4.1	1.5		
	5%	DB	-0.4	0.2	3.4	9.1	17.6	20.9	24.3	21.1	15.0	8.5	3.1	1.0		
		MCWB	-0.7	-0.4	0.7	4.6	10.8	13.5	17.0	15.9	12.1	7.1	2.6	0.5		
	10%	DB	-2.2	-1.2	1.4	6.9	14.7	18.8	22.2	18.9	13.5	7.0	1.8	0.2		
		MCWB	-2.5	-1.8	-0.3	3.0	9.1	12.8	16.1	14.9	11.3	5.9	1.5	-0.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.8	3.1	4.0	8.5	15.2	18.1	20.5	19.5	14.7	9.7	5.9	2.9		
		MCDB	3.9	5.2	7.6	14.4	21.7	24.7	25.7	24.2	16.3	10.8	6.2	3.5		
	2%	WB	0.3	0.8	2.3	6.2	13.5	16.2	19.0	17.9	13.5	8.3	4.0	1.6		
		MCDB	0.6	1.8	5.0	10.3	20.4	21.0	24.4	21.5	15.3	9.5	4.9	2.0		
	5%	WB	-0.8	-0.3	1.0	4.7	11.3	14.6	17.9	16.5	12.7	7.2	2.6	0.6		
		MCDB	-0.5	0.3	2.7	8.6	16.6	18.7	22.6	19.4	14.4	8.3	3.1	0.8		
	10%	WB	-2.5	-1.8	0.1	3.3	9.5	13.5	16.9	15.3	11.7	5.8	1.4	-0.1		
		MCDB	-2.2	-1.2	1.2	6.6	14.1	17.6	21.2	18.1	13.4	6.8	1.8	0.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	10.1	11.5	10.2	10.3	10.0	10.8	10.5	8.9	6.9	6.5	8.1		
		MCDBR	7.2	7.6	11.5	13.2	16.6	13.7	15.0	14.6	11.5	7.8	4.8	6.2		
		MCWBR	7.1	6.7	8.7	8.3	9.0	6.6	7.7	8.8	8.0	6.4	4.5	6.1		
		MCWBR	7.3	7.1	9.7	12.4	15.1	11.3	12.7	11.6	8.9	7.2	4.7	6.1		
(40) Clear-Sky Solar Irradiance	taub		0.195	0.262	0.294	0.327	0.340	0.343	0.355	0.338	0.311	0.285	0.343	N/A		
		taud	1.937	2.119	2.195	2.268	2.456	2.474	2.457	2.488	2.545	2.365	2.677	N/A		
	Ebn at Noon		202	577	758	829	862	866	841	820	764	568	221	0		
		Edh at Noon	15	52	82	100	93	93	92	81	60	42	16	0		
(44) All-Sky Solar Radiation	RadAvg		0.07	0.59	2.08	3.84	4.83	5.19	4.89	3.58	1.95	0.70	0.13	0.00		
	RadStd		0.01	0.09	0.20	0.23	0.50	0.41	0.46	0.29	0.26	0.13	0.02	0.00		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page