

GADDEDE 2, Sweden

WMO: 022190

Lat: 64.5044N

Lon: 14.2207E

Elev: 553

StdP: 94.86

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.0	(c) -19.6	(d) -24.3	(e) 0.4	(f) -21.9	(g) -21.9	(h) 0.6	(i) -19.4	(j) 10.3	(k) -6.6	(l) 9.4	(m) -6.9	(n) 1.7	(o) 100	(p) 0.727

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	23.2	14.8	20.8	14.2	18.7	13.4	16.3	20.7	15.2	19.5	14.1	17.9	2.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	11.1	17.7	13.5	10.3	16.4	12.3	9.5	15.5	47.5	20.9	44.3	19.6	41.2	17.8	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.3	(b) 7.3	(c) 6.4	(e) -25.2	(f) 25.5	(g) 1.7	(h) 2.5	(i) -26.5	(j) 27.4	(k) -27.5	(l) 28.9	(m) -28.4	(n) 30.3	(o) -29.7	(p) 32.1		
(a) 8.3	(b) 7.3	(c) 6.4	(e) -25.2	(f) 18.1	(g) 1.9	(h) 1.3	(i) -26.5	(j) 19.0	(k) -27.7	(l) 19.8	(m) -28.7	(n) 20.5	(o) -30.1	(p) 21.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.6	-7.8	-7.4	-4.9	0.1	5.3	9.4	12.9	11.1	7.3	1.4	-3.1	-5.7
	DBStd	8.34	5.63	5.71	4.55	3.68	4.35	3.71	3.63	2.81	2.93	3.19	4.73	5.28
	HDD10.0	3282	552	487	463	297	158	56	12	20	89	267	393	487
	HDD18.3	6114	811	721	722	547	403	270	173	225	331	524	643	746
	CDD10.0	214	0	0	0	0	14	37	101	54	8	1	0	0
	CDD18.3	6	0	0	0	0	0	1	4	1	0	0	0	0
	CDH23.3	59	0	0	0	0	2	9	46	2	0	0	0	0
	CDH26.7	4	0	0	0	0	0	0	4	0	0	0	0	0
(14) Wind	WSAvg	3.1	3.4	3.3	3.4	2.9	3.0	3.1	2.8	2.7	3.0	3.1	3.1	3.2
(15) Precipitation	PrecAvg	881	94	77	68	46	44	67	90	82	80	77	71	84
	PrecMax	1266	204	236	148	98	92	110	202	194	187	142	163	188
	PrecMin	625	10	9	7	15	9	7	30	35	25	22	15	18
	PrecStd	149	49	55	40	21	21	25	40	38	41	27	41	46
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	4.1	5.0	14.0	22.4	24.9	27.1	22.4	17.5	11.5	7.0	4.0
		MCWB	1.8	2.9	1.4	7.6	12.7	14.5	16.7	15.0	12.8	10.0	6.8	3.5
	2%	DB	1.7	2.2	3.2	10.4	19.0	21.4	24.5	20.0	15.1	8.3	4.9	2.8
		MCWB	1.2	1.6	1.7	4.9	11.2	13.6	15.9	14.1	11.5	7.1	4.4	2.3
	5%	DB	0.7	1.2	2.2	7.7	16.0	18.2	22.1	18.1	13.3	7.0	3.3	1.5
		MCWB	0.5	0.7	1.1	3.6	9.8	12.0	15.1	14.0	11.0	6.0	3.0	0.9
	10%	DB	-0.6	0.0	1.2	5.4	13.0	15.9	19.6	16.4	11.8	5.7	2.1	0.4
		MCWB	-0.8	-0.5	0.4	2.4	8.8	10.6	14.1	13.2	10.0	4.9	1.7	-0.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	3.1	2.9	7.5	13.6	15.8	18.9	17.1	13.8	9.9	6.8	3.8
		MCDB	2.7	3.8	3.4	13.3	20.7	21.4	23.9	20.7	16.2	11.1	7.0	3.9
	2%	WB	1.2	1.7	2.2	5.7	12.2	14.4	17.1	15.6	12.3	7.6	4.6	2.2
		MCDB	1.3	2.1	2.8	9.5	17.0	19.7	21.8	18.4	14.1	8.1	4.9	2.4
	5%	WB	0.3	0.9	1.3	4.1	10.8	13.2	15.8	14.5	11.1	6.1	3.3	0.9
		MCDB	0.5	1.2	2.0	7.1	15.5	17.7	20.9	17.2	12.9	6.8	3.5	1.2
	10%	WB	-0.9	-0.4	0.4	2.8	9.2	11.6	14.7	13.4	10.0	5.1	1.8	-0.1
		MCDB	-0.7	-0.1	1.2	4.7	13.5	15.1	19.3	16.1	11.4	5.8	2.0	0.2
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.7	7.1	7.4	8.3	8.5	8.9	8.1	6.2	4.4	4.2	5.2
		MCDBR	4.3	4.7	6.4	10.6	13.7	12.2	12.5	10.7	9.1	5.7	4.5	4.8
		MCWBR	4.2	4.3	5.2	6.2	7.2	6.1	5.6	5.8	5.7	4.4	4.1	4.5
	5% WB	MCDWR	4.4	4.7	5.4	9.1	12.2	10.6	11.2	9.1	7.8	5.2	4.5	4.6
		MCWBR	4.4	4.4	4.6	5.5	6.9	5.8	5.6	5.4	5.4	4.5	4.2	4.4
(40) Clear-Sky Solar Irradiance	taub		0.186	0.256	0.286	0.318	0.326	0.324	0.334	0.322	0.299	0.280	0.348	0.185
	taud		1.942	2.173	2.222	2.288	2.454	2.509	2.494	2.515	2.569	2.430	2.769	1.944
	Ebn at Noon		371	657	798	856	886	895	873	852	804	645	355	129
	Edh at Noon		25	57	85	101	95	92	91	81	62	45	22	9
(44) All-Sky Solar Radiation	RadAvg		0.12	0.60	1.92	3.75	4.66	5.02	4.67	3.50	1.94	0.78	0.20	0.05
	RadStd		0.01	0.11	0.25	0.33	0.35	0.45	0.56	0.36	0.23	0.09	0.03	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page