

KORSVATTNET, Sweden

WMO: 022210

Lat: 63.839N

Lon: 13.501E

Elev: 2352

StdP: 13.49

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.5	(c) -2.7	(d) -12.8	(e) 3.0	(f) -6.6	(g) -8.1	(h) 3.9	(i) -1.6	(j) 34.6	(k) 27.7	(l) 31.0	(m) 27.3	(n) 7.6	(o) 30	(p) 0.790

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	71.3	58.1	67.4	56.4	63.7	54.9	60.4	68.0	58.2	64.8	56.1	62.1	7.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	76.6	63.5	55.2	70.7	61.2	53.1	65.5	58.9	27.8	68.3	26.2	64.8	24.8	62.4	67.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.9	24.7	21.0	-14.7	76.2	4.1	4.3	-17.6	79.3	-20.0	81.8	-22.3	84.2	-25.3	87.3		
			-15.3	62.3	4.7	3.0	-18.7	64.5	-21.4	66.2	-24.1	67.9	-27.5	70.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.6	18.2	18.4	20.8	29.3	38.2	47.4	53.7	51.0	44.1	33.8	25.7	21.0		
	DBStd	14.68	9.61	9.96	8.66	6.55	6.81	6.92	6.46	5.65	5.66	6.15	7.41	9.08		
	HDD50	6309	985	885	905	620	373	130	34	54	191	503	730	899		
	HDD65	11479	1450	1305	1370	1070	831	527	353	433	628	968	1180	1364		
	CDD50	310	0	0	0	0	7	53	150	87	13	0	0	0		
	CDD65	4	0	0	0	0	0	0	4	0	0	0	0	0		
	CDH74	40	0	0	0	0	0	3	36	1	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
	WSAvg	9.0	10.0	10.2	11.2	9.7	9.0	9.3	7.7	7.3	8.0	8.1	7.7	9.3		
	PrecAvg	33.2	2.8	2.3	2.3	1.7	1.9	2.6	3.5	3.0	3.4	3.1	2.9	3.1		
(15) Precipitation	PrecMax	42.2	5.0	6.9	5.6	3.5	4.7	4.0	6.7	5.5	7.2	5.2	5.5	5.7		
	PrecMin	27.5	1.0	0.2	0.4	0.9	0.8	0.3	0.9	1.5	1.5	1.3	0.7	1.5		
	PrecStd	4.3	1.3	1.4	1.1	0.6	0.9	0.9	1.4	1.2	1.4	1.0	1.4	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.0	37.9	37.9	47.4	67.0	72.9	78.5	72.9	63.7	51.9	44.1	39.6		
		MCWB	35.0	35.3	34.9	40.3	51.3	56.7	62.5	60.3	54.6	47.0	42.3	38.4		
	2%	DB	34.7	34.9	35.8	42.8	59.5	68.0	73.2	68.3	58.9	47.1	40.3	36.6		
		MCWB	33.5	33.4	34.0	37.9	48.6	53.8	59.9	58.0	51.6	44.6	39.0	35.2		
	5%	DB	32.6	33.2	34.1	40.2	53.1	63.5	68.9	64.3	55.1	44.3	37.0	34.4		
		MCWB	31.6	32.3	32.6	36.4	45.2	52.4	57.9	56.6	50.6	42.3	35.9	33.2		
	10%	DB	30.5	31.0	32.2	38.1	48.3	59.5	64.9	60.6	52.0	42.2	34.8	32.4		
		MCWB	29.7	30.1	31.1	35.2	42.6	50.7	56.3	55.1	49.0	40.5	33.8	31.5		
	0.4%	WB	35.4	36.0	36.0	41.0	53.0	59.1	64.1	62.3	55.8	49.1	42.7	38.8		
		MCDB	36.3	36.8	36.9	45.8	63.0	67.2	74.2	69.5	60.9	50.3	43.5	39.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	33.5	33.9	34.3	38.7	49.2	56.1	61.8	59.7	53.2	45.0	39.0	35.6		
		MCDB	34.3	34.6	35.4	41.9	57.4	65.1	70.2	65.5	57.1	46.5	40.3	36.2		
	5%	WB	31.7	32.3	32.7	37.0	45.9	53.6	59.3	57.6	51.3	42.8	36.1	33.3		
		MCDB	32.5	33.2	33.8	39.5	52.3	60.9	67.0	62.8	54.2	44.2	36.9	34.2		
	10%	WB	29.6	30.0	31.2	35.5	43.1	51.4	57.1	55.5	49.3	40.5	33.9	31.5		
		MCDB	30.2	30.8	32.2	37.7	47.7	58.3	63.3	60.3	51.8	42.0	34.6	32.3		
	5% DB	MDBR	9.3	9.9	10.9	10.3	11.5	13.5	13.9	12.7	9.9	7.2	7.5	9.4		
		MCDBR	7.9	8.9	10.2	12.1	19.7	21.4	20.7	18.7	16.0	10.4	8.4	9.2		
		MCWBR	7.8	8.1	9.1	8.6	11.4	11.0	9.8	10.2	9.7	7.8	7.7	8.9		
		MCWBR	8.1	8.0	9.4	10.1	18.1	19.2	18.5	16.5	13.7	9.7	8.2	9.1		
(35) Mean Daily Temperature Range	5% WB	MCWBR	8.0	7.6	8.7	7.4	11.2	10.8	9.6	9.6	9.3	7.7	7.7	8.9		
	Clear-Sky Solar Irradiance	taub	0.185	0.248	0.277	0.305	0.315	0.314	0.324	0.313	0.291	0.272	0.191	0.176		
		taud	1.987	2.227	2.277	2.338	2.469	2.533	2.517	2.536	2.588	2.474	2.050	1.955		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	137	221	262	278	286	288	281	275	261	216	131	63		
		Edh at Noon	9	18	26	31	30	29	28	25	20	14	8	4		
(44) All-Sky Solar Radiation	RadStd		47	205	623	1207	1461	1530	1479	1121	646	272	73	21		
			5	30	81	102	103	156	173	115	62	29	9	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (46 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-256	-320	N/A	N/A

Nomenclature: See separate page