

GADDEDE 1, Sweden

WMO: 022220

Lat: 64.500N

Lon: 14.167E

Elev: 1083

StdP: 14.13

Time Zone: 1.00 (EUC)

Period: 90-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-13.5	-7.1	-16.7	2.3	-13.4	-10.1	3.3	-7.0	23.3	25.3	22.7	24.6	0.6	0	0.703

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	75.0	60.5	70.9	58.4	66.8	56.5	61.9	71.7	59.8	68.0	57.8	64.9	6.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.2	75.2	64.3	56.2	70.0	62.5	54.3	65.3	60.8	28.2	71.3	26.7	67.6	25.4	65.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	16.7	15.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.7	20.3	18.5	25.2	32.6	42.0	50.0	55.3	53.4	44.8	35.5	26.7	23.4
	DBStd	15.03	11.10	13.95	8.83	7.01	5.88	5.87	5.47	5.59	5.42	7.23	7.66	10.04
	HDD50	5611	920	883	769	522	262	72	12	25	172	451	698	825
	HDD65	10684	1385	1303	1234	972	713	449	305	363	606	916	1148	1290
	CDD50	407	0	0	0	0	14	73	175	129	16	0	0	0
	CDD65	5	0	0	0	0	0	0	3	2	0	0	0	0
	CDH74	125	0	0	0	0	1	23	58	43	0	0	0	0
	CDH80	6	0	0	0	0	0	1	4	1	0	0	0	0
Wind	WSAvg	4.6	4.6	4.4	4.9	4.6	5.0	5.2	5.0	4.7	3.9	4.3	3.6	4.5
Precipitation	PrecAvg	31.8	3.1	2.4	2.0	1.6	1.6	3.0	4.1	3.2	2.6	2.6	2.4	2.7
	PrecMax	40.8	6.4	7.3	4.5	3.3	2.8	5.2	8.2	5.5	4.6	3.9	5.3	5.5
	PrecMin	23.5	0.4	0.2	0.5	0.4	0.5	0.4	1.3	1.5	0.8	1.3	0.7	1.0
	PrecStd	4.8	1.5	1.6	1.1	0.7	0.7	1.1	1.7	1.2	1.1	0.7	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	41.1	43.1	54.9	71.3	77.3	79.9	79.2	63.9	53.9	45.4	41.6
		MCWB	38.0	38.3	37.4	44.1	55.8	60.2	63.3	63.5	54.1	50.5	43.6	40.4
	2%	DB	37.8	38.9	40.3	50.2	64.5	71.7	75.6	73.8	59.1	49.8	41.6	38.4
		MCWB	36.1	37.4	36.7	41.4	51.8	57.0	60.7	61.2	52.1	47.5	39.4	36.9
	5%	DB	35.6	36.9	38.2	46.1	58.3	67.2	71.5	68.5	55.8	47.1	39.4	36.5
		MCWB	34.3	35.3	35.4	39.2	47.7	54.6	59.2	58.7	51.3	44.2	37.8	35.2
	10%	DB	33.4	34.7	36.4	42.8	53.2	62.0	67.3	63.1	53.5	44.5	36.9	34.8
		MCWB	32.2	33.3	34.2	37.8	45.2	52.4	57.3	56.6	49.3	42.2	35.6	33.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.7	39.4	39.1	44.4	55.9	61.1	64.9	63.8	55.9	50.8	44.0	40.8
		MCDB	39.6	40.2	41.1	53.2	70.3	74.6	75.1	76.2	60.0	53.2	45.5	41.5
	2%	WB	36.0	37.5	37.4	42.0	52.1	58.0	62.5	61.9	53.7	47.6	39.8	37.0
		MCDB	37.2	38.7	39.4	48.0	63.2	68.5	71.2	72.6	57.3	49.5	41.2	37.9
	5%	WB	34.4	35.4	36.0	40.0	48.9	55.7	60.3	59.8	51.9	44.7	37.9	35.3
		MCDB	35.5	36.5	37.8	44.8	56.7	64.6	67.9	66.7	55.5	46.2	39.2	36.2
	10%	WB	32.3	33.5	34.3	38.4	45.9	53.6	58.4	57.3	50.0	42.3	35.7	33.8
		MCDB	33.3	34.7	36.2	42.1	52.2	61.0	66.2	62.7	52.6	44.0	36.7	34.8
Mean Daily Temperature Range	5% DB	MDBR	10.4	11.1	12.5	14.9	16.1	15.7	15.3	13.5	12.3	7.8	7.1	8.4
		MCDBR	10.1	8.8	11.1	20.1	27.0	26.9	25.7	23.8	15.8	9.8	7.9	8.2
		MCWBR	9.6	7.9	8.2	12.1	15.1	13.7	11.9	12.0	9.5	7.5	7.2	7.5
	5% WB	MCDBR	9.6	8.7	9.9	17.3	25.3	23.5	20.4	20.9	13.2	8.6	7.8	7.7
		MCWBR	9.4	8.2	7.8	10.8	14.4	13.1	10.7	11.1	8.4	7.4	7.2	7.3
Clear-Sky Solar Irradiance	taub	0.195	0.265	0.297	0.330	0.338	0.335	0.346	0.334	0.309	0.289	0.350	0.195	
	taud	1.943	2.154	2.196	2.259	2.427	2.486	2.474	2.496	2.554	2.412	2.713	1.947	
	Ebn at Noon	112	203	248	267	277	280	273	266	251	199	107	37	
	Edh at Noon	8	18	28	33	31	30	30	26	20	15	7	3	
All-Sky Solar Radiation	RadAvg	39	189	607	1187	1479	1587	1478	1110	615	247	62	16	
	RadStd	4	36	81	104	111	146	177	114	73	29	9	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page