

GADDEDE 1, Sweden

WMO: 022220

Lat: 64.500N

Lon: 14.167E

Elev: 330

StdP: 97.42

Time Zone: 1.00 (EUC)

Period: 90-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-25.3	-21.7	-27.1	0.3	-25.2	-23.4	0.5	-21.7	10.4	-3.7	10.2	-4.1	0.3	0	0.703

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	23.9	15.8	21.6	14.7	19.3	13.6	16.6	22.1	15.5	20.0	14.3	18.3	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	10.7	17.9	13.4	10.0	16.9	12.4	9.3	16.0	47.7	21.8	44.3	19.8	41.1	18.5	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	7.4	6.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.1	-6.5	-7.5	-3.8	0.3	5.6	10.0	12.9	11.9	7.1	1.9	-2.9	-4.8
	DBStd	8.35	6.17	7.75	4.91	3.89	3.26	3.26	3.04	3.10	3.01	4.02	4.26	5.58
	HDD10.0	3117	511	491	427	290	146	40	7	14	96	251	388	458
	HDD18.3	5936	769	724	686	540	396	249	169	202	337	509	638	717
	CDD10.0	226	0	0	0	0	8	41	97	72	9	0	0	0
	CDD18.3	3	0	0	0	0	0	0	2	1	0	0	0	0
	CDH23.3	69	0	0	0	0	1	13	32	24	0	0	0	0
	CDH26.7	3	0	0	0	0	0	1	2	1	0	0	0	0
Wind	WSAvg	2.0	2.1	2.0	2.2	2.0	2.2	2.3	2.2	2.1	1.7	1.9	1.6	2.0
Precipitation	PrecAvg	807	79	62	52	40	40	75	103	82	67	67	62	69
	PrecMax	1037	163	186	114	83	70	131	209	139	118	99	134	140
	PrecMin	598	11	5	12	11	13	11	34	39	21	33	17	25
	PrecStd	122	37	41	28	17	17	27	44	31	28	19	33	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	5.1	6.2	12.7	21.8	25.2	26.6	26.2	17.7	12.2	7.5	5.3
		MCWB	3.3	3.5	3.0	6.7	13.2	15.7	17.4	17.5	12.3	10.3	6.5	4.7
	2%	DB	3.2	3.8	4.6	10.1	18.1	22.1	24.2	23.2	15.0	9.9	5.3	3.6
		MCWB	2.3	3.0	2.6	5.2	11.0	13.9	15.9	16.2	11.2	8.6	4.1	2.7
	5%	DB	2.0	2.7	3.4	7.8	14.6	19.5	21.9	20.3	13.2	8.4	4.1	2.5
		MCWB	1.3	1.8	1.9	4.0	8.7	12.6	15.1	14.9	10.7	6.8	3.2	1.8
	10%	DB	0.8	1.5	2.4	6.0	11.8	16.6	19.6	17.3	11.9	6.9	2.7	1.5
		MCWB	0.1	0.7	1.2	3.2	7.3	11.4	14.1	13.7	9.6	5.7	2.0	1.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	4.1	4.0	6.9	13.3	16.2	18.3	17.7	13.3	10.5	6.7	4.9
		MCDB	4.2	4.6	5.1	11.8	21.3	23.7	23.9	24.6	15.6	11.8	7.5	5.3
	2%	WB	2.2	3.1	3.0	5.6	11.2	14.4	16.9	16.6	12.0	8.7	4.3	2.8
		MCDB	2.9	3.7	4.1	8.9	17.3	20.3	21.8	22.5	14.0	9.7	5.1	3.3
	5%	WB	1.3	1.9	2.2	4.5	9.4	13.2	15.7	15.4	11.1	7.1	3.3	1.8
		MCDB	1.9	2.5	3.2	7.1	13.7	18.1	20.0	19.3	13.0	7.9	4.0	2.3
	10%	WB	0.2	0.8	1.3	3.5	7.7	12.0	14.7	14.1	10.0	5.7	2.1	1.0
		MCDB	0.7	1.5	2.3	5.6	11.2	16.1	19.0	17.0	11.5	6.7	2.6	1.5
Mean Daily Temperature Range	5% DB	MDBR	5.8	6.2	7.0	8.3	8.9	8.7	8.5	7.5	6.8	4.4	4.0	4.7
		MCDBR	5.6	4.9	6.2	11.2	15.0	14.9	14.3	13.2	8.8	5.4	4.4	4.5
		MCWBR	5.4	4.4	4.6	6.7	8.4	7.6	6.6	6.7	5.3	4.2	4.0	4.2
	5% WB	MCDBR	5.3	4.8	5.5	9.6	14.0	13.1	11.3	11.6	7.3	4.8	4.3	4.3
		MCWBR	5.2	4.5	4.4	6.0	8.0	7.3	5.9	6.2	4.7	4.1	4.0	4.0
Clear-Sky Solar Irradiance	taub	0.195	0.265	0.297	0.330	0.338	0.335	0.346	0.334	0.309	0.289	0.350	0.195	
	taud	1.943	2.154	2.196	2.259	2.427	2.486	2.474	2.496	2.554	2.412	2.713	1.947	
	Ebn at Noon	352	639	781	841	872	883	860	839	790	628	336	118	
	Edh at Noon	25	58	87	104	97	94	93	83	63	46	22	10	
All-Sky Solar Radiation	RadAvg	0.12	0.59	1.91	3.74	4.66	5.00	4.66	3.50	1.94	0.78	0.20	0.05	
	RadStd	0.01	0.11	0.25	0.33	0.35	0.46	0.56	0.36	0.23	0.09	0.03	0.00	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page