

GUBBHOGEN, Sweden

WMO: 022300

Lat: 64.2172N

Lon: 15.5529E

Elev: 310

StdP: 97.66

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.0	-21.9	-28.0	0.3	-24.9	-24.7	0.4	-21.8	8.4	0.9	7.3	0.4	0.7	290	0.659

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	24.8	16.3	22.7	15.7	20.7	14.8	17.8	22.6	16.6	21.2	15.5	19.5	2.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.9	11.7	19.4	14.8	10.9	18.5	13.7	10.1	17.4	51.3	22.7	47.8	21.2	44.4	19.7	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.1	5.2	DB	-29.2	26.8	3.0	1.9	-31.3	28.2	-33.1	29.3	-34.7	30.3	-36.9	31.7	(4)
(5)			WB	-29.4	19.0	2.9	1.2	-31.5	19.8	-33.2	20.5	-34.9	21.1	-37.0	22.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-8.5	-7.9	-4.0	1.8	7.3	11.5	14.6	12.8	8.1	2.3	-2.6	-6.0	(6)
(7)		DBStd	9.20	6.84	6.72	5.08	3.36	3.77	3.45	3.20	2.94	2.96	3.65	4.67	6.49	(7)
(8)		HDD10.0	3071	573	502	433	246	103	21	2	7	69	240	378	497	(8)
(9)		HDD18.3	5787	831	736	692	496	342	206	124	174	306	498	628	755	(9)
(10)		CDD10.0	336	0	0	0	0	19	67	143	93	13	1	0	0	(10)
(11)		CDD18.3	10	0	0	0	0	0	1	7	2	0	0	0	0	(11)
(12)		CDH23.3	128	0	0	0	0	4	29	79	14	0	0	0	0	(12)
(13)		CDH26.7	12	0	0	0	0	0	1	11	1	0	0	0	0	(13)
(14)	Wind	WSAvg	2.2	1.9	2.0	2.5	2.4	2.6	2.7	2.2	2.0	2.1	2.1	1.9	1.9	(14)
(15)	Precipitation	PrecAvg	607	40	30	27	32	45	64	87	79	61	54	48	42	(15)
(16)		PrecMax	785	73	56	41	53	89	115	154	151	163	147	101	90	(16)
(17)		PrecMin	425	9	9	7	10	15	13	17	24	18	23	23	17	(17)
(18)		PrecStd	113	16	13	10	11	24	25	39	42	34	32	23	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.5	5.9	7.5	16.5	23.7	26.2	28.4	25.2	18.1	13.1	9.2	5.7	(19)
(20)			MCWB	3.5	3.8	4.0	8.9	13.8	15.5	18.6	17.0	13.9	9.8	7.8	4.1	(20)
(21)		2%	DB	4.0	4.5	5.7	12.6	20.4	23.7	25.5	22.9	15.9	10.0	6.2	4.2	(21)
(22)			MCWB	2.5	2.7	3.0	6.8	12.0	14.8	17.2	16.4	12.6	8.2	4.9	2.7	(22)
(23)		5%	DB	2.3	2.9	4.4	9.7	17.8	20.8	23.4	20.6	14.3	8.8	4.3	3.0	(23)
(24)			MCWB	1.1	1.5	2.2	5.0	10.8	13.7	16.5	15.6	11.6	7.5	3.4	1.8	(24)
(25)		10%	DB	0.3	0.8	3.3	7.5	14.7	18.3	21.3	18.5	12.9	7.7	2.9	1.6	(25)
(26)			MCWB	-0.5	-0.4	1.3	3.9	9.3	12.4	15.7	14.7	10.7	6.4	2.2	0.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	3.9	4.7	9.2	14.6	17.5	19.8	18.7	14.7	10.4	7.9	4.3	(27)
(28)			MCDWB	5.4	5.6	6.7	15.7	21.4	22.9	24.7	22.2	16.9	12.1	9.2	5.5	(28)
(29)		2%	WB	2.6	2.8	3.4	7.2	13.0	15.7	18.3	17.2	13.2	8.7	5.2	2.8	(29)
(30)			MCDWB	3.9	4.3	5.3	12.0	18.4	21.4	23.2	21.1	15.2	9.7	6.0	3.9	(30)
(31)		5%	WB	1.1	1.6	2.4	5.6	11.5	14.4	17.2	16.2	12.1	7.7	3.5	1.8	(31)
(32)			MCDWB	2.2	2.9	4.2	8.9	16.8	19.6	22.4	19.7	13.9	8.7	4.2	2.8	(32)
(33)		10%	WB	-0.4	-0.2	1.3	4.3	9.7	13.1	16.1	14.9	11.1	6.5	2.2	0.7	(33)
(34)			MCDWB	0.2	0.8	3.0	7.1	14.3	17.4	20.5	18.2	12.5	7.5	2.8	1.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.9	8.3	8.4	9.6	9.5	9.7	9.1	7.3	5.4	4.3	5.7	(35)
(36)			MCDBR	6.7	6.6	7.9	12.8	14.9	13.2	13.2	12.5	9.6	6.8	5.1	5.5	(36)
(37)			MCWBR	5.9	5.8	5.9	7.5	7.9	6.6	6.4	7.0	6.6	5.4	4.6	4.9	(37)
(38)		5% WB	MCDBR	6.6	6.5	7.5	11.4	13.4	12.0	11.7	11.0	8.4	6.4	5.1	5.5	(38)
(39)			MCWBR	5.9	5.7	5.9	7.1	7.6	6.6	6.3	6.5	6.2	5.3	4.6	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.194	0.263	0.292	0.327	0.332	0.329	0.342	0.331	0.304	0.287	0.345	N/A	(40)	
(41)		taud	1.988	2.214	2.287	2.374	2.479	2.515	2.493	2.512	2.574	2.461	2.770	N/A	(41)	
(42)		Ebn at Noon	386	660	800	852	882	891	866	844	801	647	371	N/A	(42)	
(43)		Edh at Noon	26	56	80	94	93	92	91	82	62	45	23	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.14	0.65	2.00	3.77	4.67	5.19	4.79	3.57	2.02	0.82	0.21	0.06	(44)	
(45)		RadStd	0.01	0.11	0.23	0.32	0.40	0.39	0.55	0.34	0.23	0.11	0.03	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page