

HOTING, Sweden

WMO: 022420

Lat: 64.088N

Lon: 16.236E

Elev: 791

StdP: 14.28

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.7	-14.9	-26.5	1.3	-20.6	-20.1	1.9	-14.9	15.5	34.2	13.2	30.3	0.5	110	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	78.2	61.8	74.6	60.6	70.8	59.0	64.7	73.6	62.7	71.0	60.7	68.3	4.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.3	83.4	67.6	59.3	77.6	65.9	57.3	72.2	64.3	30.1	73.6	28.6	71.1	27.2	68.3	70.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.7	11.7	10.0	-25.8	81.9	5.5	3.6	-29.8	84.4	-33.0	86.5	-36.0	88.5	-40.0	91.1		
			-26.0	67.0	5.0	2.6	-29.6	68.9	-32.6	70.4	-35.4	71.9	-39.0	73.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.4	14.2	16.1	23.8	35.3	45.9	53.9	59.9	56.2	47.6	36.5	26.8	19.1		
	DBStd	18.04	13.92	13.15	10.60	6.18	6.61	5.90	5.62	5.13	5.37	6.77	9.14	13.09		
	HDD50	5690	1111	950	812	441	163	24	1	7	106	420	696	959		
	HDD65	10471	1576	1370	1277	891	592	337	178	275	521	884	1146	1424		
	CDD50	720	0	0	0	0	37	140	307	200	35	1	0	0		
	CDD65	27	0	0	0	0	0	3	20	4	0	0	0	0		
	CDH74	360	0	0	0	0	14	83	219	44	0	0	0	0		
	CDH80	43	0	0	0	0	0	6	35	2	0	0	0	0		
	WSAvg	4.2	3.3	3.5	4.5	4.4	5.1	5.4	4.5	4.1	4.1	4.1	3.6	3.5		
	PrecAvg	24.8	1.9	1.1	1.1	1.3	1.7	2.7	3.7	3.3	2.2	2.1	2.0	1.7		
Precipitation	PrecMax	32.2	3.8	2.2	2.1	3.0	3.7	5.5	7.4	6.8	5.7	5.8	4.4	3.2		
	PrecMin	18.1	0.4	0.2	0.3	0.4	0.5	0.6	0.9	1.0	0.7	0.8	0.8	0.3		
	PrecStd	4.4	0.8	0.6	0.4	0.6	0.9	1.2	1.7	1.8	1.1	1.1	1.0	0.7		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.8	43.5	46.5	63.2	75.9	80.8	84.3	78.7	66.6	56.6	48.6	42.2		
		MCWB	38.5	39.1	39.9	48.4	57.3	59.9	65.0	63.3	57.7	50.6	46.3	38.9		
	2%	DB	38.7	40.6	43.1	55.4	70.2	76.4	79.6	74.6	62.2	51.0	43.1	39.4		
		MCWB	36.2	37.0	37.7	44.2	54.6	59.0	63.2	62.0	55.6	48.0	41.3	36.9		
	5%	DB	35.5	37.0	40.7	50.6	65.3	70.7	75.9	70.4	59.1	48.8	39.9	36.9		
		MCWB	33.6	34.4	36.3	41.8	52.0	56.6	62.1	60.6	53.5	46.4	38.3	35.1		
	10%	DB	32.3	33.4	38.3	46.5	59.7	66.6	72.0	66.6	56.5	46.6	37.5	34.5		
		MCWB	31.4	31.7	34.6	39.5	49.5	54.8	60.3	58.8	52.2	44.3	36.1	33.2		
	0.4%	WB	38.7	39.5	40.8	49.1	59.1	63.6	67.9	66.2	59.2	51.4	46.6	39.4		
		MCDB	41.1	42.9	45.2	60.9	71.4	74.3	76.3	74.1	64.2	54.6	48.8	41.7		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.4	37.2	38.5	45.6	56.3	60.6	65.6	63.7	56.6	48.7	41.8	37.0		
		MCDB	38.5	40.1	42.2	53.9	67.1	71.5	74.9	71.0	60.7	50.4	43.1	38.9		
	5%	WB	33.7	34.8	36.7	42.8	53.4	58.3	63.8	61.7	54.6	46.8	38.7	35.3		
		MCDB	35.1	36.9	40.2	48.8	63.6	68.5	73.0	68.4	57.9	48.8	39.7	36.8		
	10%	WB	31.5	31.7	34.7	40.1	50.4	56.1	61.9	59.6	53.0	44.4	36.3	33.3		
		MCDB	32.6	33.3	37.9	45.6	58.7	64.5	70.4	65.7	55.8	46.3	37.3	34.3		
Mean Daily Temperature Range	5% DB	MDBR	14.6	16.3	19.0	17.4	19.0	17.8	17.5	16.3	13.9	10.3	8.9	12.6		
		MCDBR	14.3	13.2	16.6	26.5	29.6	25.8	24.5	23.5	18.0	13.4	9.4	12.9		
		MCWBR	12.9	11.3	12.0	15.8	15.2	11.6	10.6	12.2	11.8	10.2	8.3	11.6		
	5% WB	MCDBR	14.2	12.8	16.0	23.3	26.7	22.9	21.0	20.0	15.8	12.8	9.0	12.4		
		MCWBR	12.9	11.2	12.1	14.6	15.0	11.4	10.2	11.1	11.0	10.2	8.3	11.1		
Clear-Sky Solar Irradiance	taub		0.202	0.270	0.298	0.334	0.338	0.336	0.349	0.338	0.310	0.293	0.348	0.352		
	taud		1.996	2.204	2.276	2.363	2.466	2.498	2.476	2.497	2.563	2.450	2.743	2.731		
	Ebn at Noon		121	206	252	268	278	280	272	266	252	203	116	64		
	Edh at Noon		8	18	26	30	30	30	30	26	20	15	7	5		
All-Sky Solar Radiation	RadAvg		47	231	673	1209	1494	1678	1537	1154	672	281	71	20		
	RadStd		5	36	73	98	163	126	170	111	78	44	13	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (45 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-247	N/A	N/A	N/A

Nomenclature: See separate page