

JUNSELE, Sweden

WMO: 022430

Lat: 63.6839N

Lon: 16.9500E

Elev: 219

StdP: 98.72

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.6	-25.6	-31.2	0.2	-28.6	-28.0	0.3	-25.6	6.8	-0.9	5.4	-1.5	0.5	80	0.628

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	25.9	16.5	23.9	15.8	21.9	14.8	18.0	23.4	16.8	21.8	15.8	20.2	2.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	11.8	19.0	15.0	10.9	18.0	14.0	10.2	17.2	51.5	23.3	48.0	21.8	45.0	20.0	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.8	3.8	DB	-31.7	28.2	3.1	1.9	-34.0	29.6	-35.8	30.7	-37.6	31.8	-39.8	33.2	(4)
(5)			WB	-31.9	19.4	3.1	1.5	-34.1	20.4	-35.9	21.3	-37.6	22.1	-39.9	23.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-9.9	-8.4	-3.6	2.0	7.6	12.3	15.2	13.6	8.9	2.5	-3.1	-7.5		
	DBStd	9.94	7.64	7.18	5.37	3.49	3.84	3.18	2.99	2.99	3.17	3.75	5.32	7.12		
	HDD10.0	3135	618	514	423	241	94	12	1	4	58	233	394	542		
	HDD18.3	5786	877	748	681	491	332	184	105	150	284	491	644	800		
	CDD10.0	404	0	0	0	0	22	80	163	116	24	1	0	0		
	CDD18.3	13	0	0	0	0	0	1	9	3	0	0	0	0		
	CDH23.3	224	0	0	0	0	12	45	129	38	1	0	0	0		
	CDH26.7	30	0	0	0	0	0	6	23	2	0	0	0	0		
(14) Wind	WSAvg	1.6	1.4	1.5	1.8	1.8	2.0	1.9	1.7	1.5	1.6	1.5	1.4	1.4		
(15) Precipitation	PrecAvg	574	39	28	29	32	39	57	86	67	55	50	49	42		
	PrecMax	766	84	66	61	79	82	150	169	169	141	118	112	102		
	PrecMin	412	4	4	3	6	10	12	21	10	16	17	12	8		
	PrecStd	93	19	14	14	19	19	29	40	38	25	25	24	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	6.4	8.9	16.7	25.1	27.4	29.4	26.5	20.4	13.3	9.4	5.3		
		MCWB	3.0	3.6	4.7	9.2	14.2	16.1	17.9	17.3	14.5	10.1	7.7	3.6		
	2%	DB	2.8	4.6	6.8	13.1	21.7	24.5	26.6	24.3	18.1	11.1	6.6	3.8		
		MCWB	1.7	2.5	3.3	7.0	12.9	15.0	17.2	16.5	13.3	9.3	6.0	2.7		
	5%	DB	1.0	2.6	5.3	10.7	18.8	21.6	24.5	22.3	16.2	9.6	4.6	2.4		
		MCWB	0.4	1.3	2.4	5.6	11.5	13.6	16.4	15.7	12.4	8.2	3.9	1.7		
	10%	DB	-0.1	0.9	3.8	8.6	15.8	19.5	22.3	20.1	14.6	8.3	3.1	1.1		
		MCWB	-0.5	0.0	1.5	4.5	9.9	12.7	15.5	14.9	11.7	7.0	2.5	0.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	3.9	5.2	9.7	15.4	17.3	19.9	19.1	15.6	11.2	8.0	4.1		
		MCDB	4.2	6.0	8.2	15.5	21.6	24.2	24.3	23.2	18.9	12.3	8.9	4.9		
	2%	WB	1.8	2.8	3.8	7.5	13.8	15.8	18.4	17.6	14.2	9.8	5.8	2.8		
		MCDB	2.6	4.3	6.3	12.1	20.5	22.1	23.8	22.1	16.8	10.8	6.4	3.6		
	5%	WB	0.5	1.4	2.7	6.1	12.0	14.6	17.4	16.4	13.1	8.5	4.0	1.7		
		MCDB	1.0	2.4	4.8	9.8	18.3	19.9	22.8	20.5	15.6	9.5	4.4	2.2		
	10%	WB	-0.6	0.1	1.7	4.8	10.3	13.5	16.3	15.4	12.1	7.0	2.6	0.6		
		MCDB	-0.1	0.8	3.7	8.0	15.2	18.3	21.0	19.2	14.1	8.2	3.0	1.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	8.7	10.3	10.1	11.2	10.6	10.5	10.3	9.0	6.7	5.4	7.2		
		MCDBR	7.3	8.0	9.9	14.4	17.2	15.0	14.9	14.2	11.8	8.5	5.7	6.8		
		MCWBR	6.8	6.4	6.8	8.8	9.1	7.1	6.6	6.9	7.3	6.5	5.1	6.2		
		MCDBR	7.3	7.3	9.2	12.9	16.1	13.0	12.6	11.4	10.3	7.7	5.6	6.5		
	5% WB	MCWBR	6.9	6.1	6.7	8.2	8.8	6.6	6.3	6.2	6.9	6.3	5.1	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.208	0.273	0.299	0.336	0.339	0.337	0.351	0.340	0.311	0.295	0.355	0.348		
	taud		2.027	2.217	2.290	2.376	2.465	2.496	2.473	2.495	2.563	2.460	2.768	2.718		
	Ebn at Noon		402	658	797	845	876	884	859	836	797	647	384	226		
	Edh at Noon		28	58	82	95	95	94	94	84	64	47	25	16		
(44) All-Sky Solar Radiation	RadAvg		0.16	0.79	2.22	3.85	4.74	5.38	4.90	3.71	2.22	0.94	0.25	0.07		
	RadStd		0.02	0.12	0.24	0.30	0.54	0.39	0.53	0.34	0.25	0.15	0.05	0.01		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-134	N/A	N/A	N/A

Nomenclature: See separate page