

IDVATTNET, Sweden

WMO: 022520

Lat: 64.450N

Lon: 17.083E

Elev: 1158

StdP: 14.09

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.6	-23.0	-33.2	0.9	-28.5	-27.7	1.2	-23.0	33.1	36.4	27.1	31.9	0.8	230	0.744

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 17.0	(c) 74.0	(d) 58.0	(e) 70.2	(f) 56.5	(g) 66.8	(h) 55.1	(i) 60.3	(j) 70.7	(k) 58.2	(l) 66.8	(m) 56.2	(n) 64.2	(o) 8.3	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.2	70.2	62.1	54.0	64.6	61.1	52.2	60.5	59.6	27.1	71.0	25.7	67.0	24.4	64.1	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	16.6	15.6	DB	-31.9	79.9	6.1	4.1	-36.3	82.8	-39.9	85.2	-43.3	87.5	-47.8	90.5
			WB	-32.1	62.4	6.1	3.0	-36.5	64.6	-40.1	66.3	-43.5	68.0	-47.9	70.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.4	8.9	14.5	22.6	29.9	42.2	51.6	55.4	50.3	42.1	32.7	22.0	14.8		
	DBStd	18.41	17.22	14.65	10.28	8.24	6.79	6.13	5.05	5.37	5.53	9.50	11.46	13.92		
	HDD50	6815	1275	993	850	604	262	51	9	61	243	536	839	1092		
	HDD65	11924	1740	1413	1315	1054	706	405	302	455	687	1001	1289	1557		
	CDD50	372	0	0	0	0	21	98	176	71	6	0	0	0		
	CDD65	6	0	0	0	0	0	2	3	1	0	0	0	0		
	CDH74	107	0	0	0	0	12	43	42	10	0	0	0	0		
	CDH80	6	0	0	0	0	0	3	3	0	0	0	0	0		
(14) Wind	WSAvg	6.2	5.4	5.7	6.3	6.4	7.0	7.2	6.9	6.3	6.1	6.3	5.5	5.5		
(15) Precipitation	PrecAvg	24.1	1.8	1.1	1.1	1.2	1.7	2.6	3.5	3.3	2.2	2.0	1.9	1.7		
	PrecMax	32.5	3.4	2.4	2.0	2.6	2.9	4.7	6.7	6.4	5.6	5.4	3.9	3.1		
	PrecMin	16.5	0.2	0.2	0.5	0.2	0.4	0.5	0.9	1.1	0.6	0.7	0.8	0.2		
	PrecStd	4.0	0.7	0.6	0.4	0.6	0.8	1.1	1.4	1.8	1.1	1.0	1.0	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.5	41.4	43.9	56.4	75.8	79.7	79.1	75.9	62.8	52.6	42.2	39.8		
		MCWB	37.7	36.8	37.5	44.9	56.5	62.1	61.4	60.8	51.0	48.0	38.7	36.3		
	2%	DB	36.3	38.6	40.5	49.9	68.5	73.1	73.8	67.9	57.8	49.4	39.6	37.2		
		MCWB	33.2	34.5	35.5	41.3	53.1	56.5	58.8	57.0	50.7	45.2	36.6	34.8		
	5%	DB	32.7	35.4	37.8	45.8	61.9	69.0	70.7	63.9	54.8	47.2	37.7	35.4		
		MCWB	30.7	32.2	33.7	38.3	49.5	55.1	57.5	54.2	48.9	43.3	35.4	33.1		
	10%	DB	30.0	32.6	35.4	42.4	55.5	65.2	67.2	61.0	51.7	44.9	35.5	33.0		
		MCWB	28.2	30.3	31.8	36.1	46.0	53.6	56.2	53.1	46.8	41.5	33.7	31.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.7	37.5	38.6	46.1	56.6	62.3	64.5	61.7	54.0	48.9	39.2	36.8		
		MCDB	41.4	41.5	42.5	55.1	72.2	77.7	70.5	72.2	58.6	51.6	41.7	38.5		
	2%	WB	33.6	34.9	36.3	42.0	53.2	58.7	60.8	59.0	51.7	46.2	37.2	35.3		
		MCDB	35.5	38.1	39.8	48.8	67.6	67.9	71.1	66.3	56.6	48.5	39.4	37.2		
	5%	WB	30.9	32.5	34.1	39.1	50.1	56.4	58.8	55.9	49.4	43.7	35.4	33.3		
		MCDB	32.8	34.9	37.4	44.7	60.6	66.3	68.0	61.5	53.7	46.6	37.1	35.0		
	10%	WB	28.2	30.4	32.2	37.0	46.6	54.5	57.1	53.9	47.5	41.7	33.9	31.3		
		MCDB	29.9	32.6	34.8	41.5	54.3	64.3	64.8	59.1	51.3	44.6	35.5	33.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	16.6	16.9	17.7	18.3	17.3	17.0	15.6	15.3	11.9	11.6	15.9		
		MCDBR	12.9	12.5	15.1	22.1	30.4	26.2	25.7	21.6	19.1	13.4	7.9	12.8		
	5% WB	MCWBR	12.4	10.7	11.1	14.0	17.1	12.7	12.3	11.2	12.6	10.5	7.1	12.2		
		MCWBR	13.2	11.4	13.3	18.2	29.3	22.7	20.0	17.8	16.0	11.0	8.5	12.6		
(40) Clear-Sky Solar Irradiance	taub		0.190	0.261	0.290	0.323	0.330	0.330	0.342	0.330	0.303	0.285	0.339	N/A		
	taud		1.974	2.200	2.260	2.323	2.477	2.506	2.483	2.506	2.570	2.450	2.749	N/A		
	Ebn at Noon		119	208	253	270	280	282	274	268	254	204	114	N/A		
	Edh at Noon		8	18	26	31	30	29	29	26	20	14	7	N/A		
(44) All-Sky Solar Radiation	RadAvg		43	227	668	1210	1496	1670	1526	1145	658	273	66	17		
	RadStd		3	34	70	99	178	129	170	118	80	44	13	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page