

IDVATTNET, Sweden

WMO: 022520

Lat: 64.450N

Lon: 17.083E

Elev: 353

StdP: 97.16

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.7	-30.6	-36.2	0.1	-33.6	-33.2	0.2	-30.5	14.8	2.4	12.1	-0.1	0.4	230	0.744

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	23.3	14.5	21.2	13.6	19.3	12.8	15.7	21.5	14.6	19.3	13.5	17.9	3.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.4	10.0	16.7	12.2	9.2	16.1	11.2	8.6	15.3	45.2	21.7	41.9	19.5	38.9	17.8	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	7.4	7.0	-35.5	26.6	3.4	2.3	-38.0	28.2	-39.9	29.6	-41.8	30.9	-44.3	32.5		
(5)			-35.6	16.9	3.4	1.7	-38.1	18.1	-40.0	19.1	-41.9	20.0	-44.4	21.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.2	-12.8	-9.7	-5.2	-1.2	5.7	10.9	13.0	10.2	5.6	0.4	-5.5	-9.6	(6)
(7)		DBStd	10.23	9.57	8.14	5.71	4.58	3.77	3.40	2.81	2.99	3.07	5.28	6.37	7.73	(7)
(8)		HDD10.0	3786	708	552	472	336	146	28	5	34	135	298	466	607	(8)
(9)		HDD18.3	6624	967	785	731	586	392	225	168	253	382	556	716	865	(9)
(10)		CDD10.0	207	0	0	0	0	12	54	98	39	3	0	0	0	(10)
(11)		CDD18.3	3	0	0	0	0	0	1	2	1	0	0	0	0	(11)
(12)		CDH23.3	59	0	0	0	0	7	24	23	6	0	0	0	0	(12)
(13)		CDH26.7	3	0	0	0	0	0	2	2	0	0	0	0	0	(13)
(14)	Wind	WSAvg	2.8	2.4	2.6	2.8	2.9	3.1	3.2	3.1	2.8	2.7	2.8	2.5	2.5	(14)
(15)	Precipitation	PrecAvg	612	45	29	28	30	43	65	90	84	55	52	49	42	(15)
(16)		PrecMax	825	87	60	52	65	73	120	170	162	143	136	100	79	(16)
(17)		PrecMin	419	5	4	13	6	10	13	24	28	16	18	21	6	(17)
(18)		PrecStd	102	17	14	10	15	20	28	35	45	29	25	25	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	5.2	6.6	13.6	24.3	26.5	26.1	24.4	17.1	11.4	5.7	4.3	(19)
(20)			MCWB	3.2	2.7	3.0	7.2	13.6	16.7	16.3	16.0	10.6	8.9	3.7	2.4	(20)
(21)		2%	DB	2.4	3.7	4.7	10.0	20.3	22.8	23.2	19.9	14.3	9.7	4.2	2.9	(21)
(22)			MCWB	0.6	1.4	1.9	5.2	11.7	13.6	14.9	13.9	10.4	7.3	2.6	1.6	(22)
(23)		5%	DB	0.4	1.9	3.2	7.7	16.6	20.5	21.5	17.7	12.7	8.4	3.2	1.9	(23)
(24)			MCWB	-0.7	0.1	0.9	3.5	9.7	12.8	14.2	12.4	9.4	6.3	1.9	0.6	(24)
(25)		10%	DB	-1.1	0.3	1.9	5.8	13.1	18.5	19.5	16.1	11.0	7.2	2.0	0.5	(25)
(26)			MCWB	-2.1	-0.9	-0.1	2.3	7.8	12.0	13.4	11.7	8.2	5.3	1.0	-0.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	3.1	3.6	7.8	13.7	16.9	18.1	16.5	12.2	9.4	4.0	2.7	(27)
(28)			MCDWB	5.2	5.3	5.8	12.8	22.3	25.4	21.4	22.3	14.8	10.9	5.4	3.6	(28)
(29)		2%	WB	0.9	1.6	2.4	5.6	11.8	14.8	16.0	15.0	10.9	7.9	2.9	1.8	(29)
(30)			MCDWB	1.9	3.4	4.3	9.3	19.8	19.9	21.7	19.1	13.7	9.2	4.1	2.9	(30)
(31)		5%	WB	-0.6	0.3	1.2	3.9	10.1	13.5	14.9	13.3	9.7	6.5	1.9	0.7	(31)
(32)			MCDWB	0.5	1.6	3.0	7.0	15.9	19.1	20.0	16.4	12.0	8.1	2.8	1.7	(32)
(33)		10%	WB	-2.1	-0.9	0.1	2.8	8.1	12.5	14.0	12.2	8.6	5.4	1.1	-0.4	(33)
(34)			MCDWB	-1.2	0.3	1.5	5.3	12.4	18.0	18.2	15.0	10.7	7.0	1.9	0.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	9.2	9.4	9.8	10.2	9.6	9.4	8.7	8.5	6.6	6.4	8.9	(35)
(36)			MCDBR	7.1	6.9	8.4	12.3	16.9	14.6	14.3	12.0	10.6	7.4	4.4	7.1	(36)
(37)			MCWBR	6.9	5.9	6.2	7.8	9.5	7.1	6.8	6.2	7.0	5.8	3.9	6.8	(37)
(38)		5% WB	MCDBR	7.3	6.3	7.4	10.1	16.3	12.6	11.1	9.9	8.9	6.1	4.7	7.0	(38)
(39)			MCWBR	7.1	5.6	5.7	6.6	9.4	6.6	6.1	5.9	6.1	5.3	4.4	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.190	0.261	0.290	0.323	0.330	0.330	0.342	0.330	0.303	0.285	0.339	N/A	(40)	
(41)		taud	1.974	2.200	2.260	2.323	2.477	2.506	2.483	2.506	2.570	2.450	2.749	N/A	(41)	
(42)		Ebn at Noon	376	655	798	852	883	889	865	844	800	642	360	N/A	(42)	
(43)		Edh at Noon	25	56	82	98	93	92	92	82	62	45	22	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.14	0.72	2.11	3.81	4.72	5.26	4.81	3.61	2.08	0.86	0.21	0.05	(44)	
(45)		RadStd	0.01	0.11	0.22	0.31	0.56	0.41	0.54	0.37	0.25	0.14	0.04	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page