

RISTRASK V, Sweden

WMO: 022560

Lat: 64.7343N

Lon: 17.4034E

Elev: 1886

StdP: 13.72

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	-2.5	-10.6	3.3	-3.4	-7.1	4.0	-0.3	14.5	24.4	13.0	22.4	3.9	50	0.703

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	73.6	57.1	70.1	56.0	66.4	53.8	61.0	67.7	58.6	63.8	56.5	61.9	5.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.3	77.8	62.6	56.3	72.5	60.6	54.3	67.3	58.8	27.9	67.7	26.3	63.9	24.9	62.0	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	12.6	11.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-9.6	60.7	4.3	2.8	-12.6	62.7	-15.2	64.3	-17.6	65.9	-20.7	67.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.4	16.5	17.1	23.6	32.7	41.1	50.1	55.6	53.3	43.8	33.1	25.3	19.4
	DBStd	15.64	9.45	10.11	8.12	6.51	6.22	7.31	5.66	6.03	6.21	7.10	7.73	9.54
	HDD50	6131	1038	921	819	519	286	87	11	32	201	525	742	950
	HDD65	11180	1503	1341	1284	969	741	450	295	363	637	990	1192	1415
	CDD50	434	0	0	0	0	10	90	185	135	14	0	0	0
	CDD65	8	0	0	0	0	0	3	4	1	0	0	0	0
	CDH74	61	0	0	0	0	0	29	28	4	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.5	4.0	5.0	6.5	6.4	6.6	6.3	5.6	5.1	5.8	6.0	4.7	4.3
Precipitation	PrecAvg	25.3	1.8	1.2	1.2	1.2	1.7	2.7	3.9	3.5	2.2	2.2	2.0	1.7
	PrecMax	35.1	3.7	2.6	2.1	2.3	3.1	4.7	6.5	6.9	5.8	5.5	4.1	3.3
	PrecMin	17.9	0.2	0.2	0.5	0.3	0.4	0.7	1.3	1.3	0.7	0.8	0.8	0.3
	PrecStd	4.1	0.7	0.6	0.5	0.6	0.8	1.1	1.3	1.9	1.1	1.0	1.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.9	38.7	46.0	56.3	65.4	77.2	77.3	74.4	63.8	50.2	44.9	36.5
		MCWB	35.1	35.2	37.4	42.2	47.9	54.2	62.2	59.0	52.8	44.4	43.6	33.5
	2%	DB	34.1	35.9	39.9	49.2	60.2	73.4	73.6	71.6	59.0	47.0	40.4	34.6
		MCWB	33.1	34.1	34.7	38.6	45.6	53.1	58.4	57.4	51.6	44.4	38.4	32.9
	5%	DB	31.6	32.6	37.1	46.1	55.6	67.7	70.2	68.0	55.6	45.2	37.7	32.9
		MCWB	30.8	31.1	33.0	37.2	43.5	50.8	56.7	56.4	50.7	43.2	36.1	31.9
	10%	DB	28.9	30.3	34.9	42.8	51.3	63.0	66.6	64.0	52.8	43.1	34.8	31.3
		MCWB	28.3	28.9	31.7	35.8	41.1	49.1	54.7	54.3	48.7	41.5	34.0	30.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.7	36.2	38.1	44.4	51.5	56.5	64.5	62.6	56.2	47.1	43.8	35.0
		MCDB	36.9	38.0	41.8	51.7	59.8	68.9	75.1	70.4	59.7	48.0	45.0	35.6
	2%	WB	33.2	34.2	35.7	40.5	48.2	54.4	62.0	60.4	53.8	45.2	39.2	33.6
		MCDB	33.9	35.7	39.2	47.1	55.7	68.1	69.4	67.1	56.2	46.4	39.7	34.2
	5%	WB	30.9	31.5	33.9	38.4	45.3	52.7	59.8	58.3	51.8	43.5	36.4	32.1
		MCDB	31.4	32.4	36.6	44.3	51.9	65.1	65.5	63.3	54.2	44.8	37.2	32.7
	10%	WB	28.3	29.2	32.1	36.4	43.2	50.6	57.4	56.5	49.9	41.7	33.9	30.5
		MCDB	28.8	30.2	34.2	41.6	49.5	61.6	62.5	61.4	51.9	42.9	34.5	31.2
Mean Daily Temperature Range	5% DB	MDBR	8.6	9.5	11.4	12.6	13.5	15.5	14.5	14.0	11.6	8.2	6.9	7.7
		MCDBR	8.3	9.3	12.3	15.5	19.4	21.2	18.8	19.1	15.1	9.8	7.4	8.4
		MCWBR	8.3	8.3	8.7	8.3	10.3	9.9	8.7	9.2	9.0	7.3	7.1	8.1
	5% WB	MCDBR	8.4	9.0	11.8	13.6	15.7	18.9	16.7	16.4	13.0	9.0	7.4	8.4
		MCWBR	8.5	8.6	9.2	8.4	9.7	9.6	10.1	9.4	9.6	7.4	7.3	8.3
Clear-Sky Solar Irradiance	taub	0.178	0.251	0.280	0.311	0.320	0.320	0.331	0.318	0.293	0.275	0.336	N/A	
	taud	1.956	2.207	2.270	2.343	2.499	2.526	2.526	2.502	2.526	2.584	2.458	2.796	N/A
	Ebn at Noon	120	211	257	274	284	285	278	272	258	207	115	N/A	
	Edh at Noon	7	17	25	30	29	29	29	25	19	14	7	N/A	
All-Sky Solar Radiation	RadAvg	40	220	660	1207	1494	1663	1518	1137	646	264	63	14	
	RadStd	3	34	66	94	171	128	170	119	80	42	11	1	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page