

LYCKSELE, Sweden

WMO: 022610

Lat: 64.5481N

Lon: 18.7130E

Elev: 692

StdP: 14.33

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.3	-18.5	-30.1	1.0	-24.3	-23.7	1.5	-18.3	18.7	26.0	16.7	25.4	0.7	310	0.672

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	79.5	61.3	75.7	60.4	72.1	58.6	64.7	74.0	62.6	71.2	60.7	68.7	7.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.6	83.9	67.2	59.4	77.5	65.0	57.4	72.1	63.0	30.1	74.5	28.6	71.3	27.2	68.7	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.6	15.0	13.2	-30.2	84.5	5.8	4.0	-34.4	87.3	-37.7	89.7	-41.0	91.9	-45.2	94.8		
(5)			-30.4	67.1	5.7	2.6	-34.5	69.0	-37.9	70.5	-41.1	72.0	-45.3	73.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.2	11.8	14.5	23.0	34.4	45.1	53.4	59.4	55.5	46.9	35.1	24.6	17.5		
	DBStd	18.86	14.79	14.45	11.12	6.78	7.07	6.18	5.42	5.75	6.17	7.67	10.72	13.95		
	HDD50	6081	1185	994	836	469	186	32	1	15	130	463	761	1009		
	HDD65	10892	1650	1414	1301	919	616	351	189	298	542	927	1211	1474		
	CDD50	688	0	0	0	0	35	134	294	186	38	1	0	0		
	CDD65	25	0	0	0	0	0	4	16	5	0	0	0	0		
	CDH74	511	0	0	0	0	25	105	285	96	0	0	0	0		
	CDH80	86	0	0	0	0	1	22	55	8	0	0	0	0		
	WSAvg	5.2	4.1	4.6	5.7	5.7	6.4	6.7	5.6	5.0	5.1	4.7	4.2	4.2		
	PrecAvg	23.6	1.5	1.0	1.1	1.1	1.7	2.6	3.8	3.2	2.2	1.9	1.8	1.6		
(15) Precipitation	PrecMax	30.9	3.1	2.6	2.1	2.0	3.0	4.1	6.4	7.9	5.4	4.2	3.7	3.5		
	PrecMin	17.4	0.2	0.2	0.4	0.2	0.3	1.3	1.4	0.9	0.5	0.7	0.6	0.9		
	PrecStd	3.5	0.6	0.6	0.5	0.6	0.8	0.9	1.4	1.8	1.2	0.9	0.9	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.9	44.4	48.7	64.3	77.5	83.1	86.0	80.7	68.9	56.8	48.8	42.5		
		MCWB	39.1	39.6	41.0	49.1	56.6	60.2	65.2	62.9	58.0	50.4	46.3	38.9		
	2%	DB	38.8	41.3	44.6	56.6	71.9	76.8	80.4	76.9	64.5	52.0	43.6	39.5		
		MCWB	35.9	37.1	38.0	44.9	54.9	58.8	61.9	61.9	55.8	47.9	41.6	36.6		
	5%	DB	35.0	37.7	41.9	51.5	66.7	71.6	77.0	72.7	60.9	49.4	40.2	37.1		
		MCWB	33.0	34.3	36.3	42.1	52.5	56.4	60.9	60.7	53.9	46.2	38.1	35.1		
	10%	DB	32.1	33.8	39.2	47.4	61.1	67.6	73.2	68.1	58.0	46.8	37.4	34.6		
		MCWB	31.2	31.9	34.6	39.5	49.3	54.3	59.9	58.8	52.8	44.4	36.1	33.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.0	39.6	41.3	49.6	59.7	63.4	68.5	66.7	59.5	52.2	46.6	39.4		
		MCDB	42.4	43.7	47.2	62.2	70.8	76.7	76.6	75.5	64.8	54.9	48.8	42.0		
	2%	WB	36.1	37.5	38.8	45.2	56.4	60.2	65.6	63.9	57.4	48.8	41.9	37.0		
		MCDB	38.5	41.1	43.8	54.2	69.4	71.9	74.3	72.2	62.1	51.2	43.6	38.9		
	5%	WB	33.3	34.6	36.8	42.4	53.3	58.1	63.7	62.0	55.5	46.6	38.5	35.0		
		MCDB	34.4	37.0	41.3	50.0	65.5	67.9	72.9	69.5	59.6	48.9	39.8	36.4		
	10%	WB	31.2	31.8	34.7	39.9	50.2	56.0	61.8	60.0	53.7	44.4	36.2	33.3		
		MCDB	32.2	33.3	38.4	46.3	59.3	64.6	70.0	66.5	57.1	46.6	37.2	34.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.6	18.5	20.6	19.7	22.0	20.4	20.6	20.1	18.0	13.5	11.8	15.1		
		MCDBR	16.1	17.3	20.3	28.0	32.9	28.4	28.0	28.7	22.6	17.5	12.2	15.4		
		MCWBR	14.7	14.5	14.7	16.9	17.4	12.3	12.1	15.2	14.7	13.1	10.7	14.2		
		MCDBR	15.5	16.3	18.9	25.5	31.0	24.6	23.8	22.9	19.6	15.9	11.7	14.5		
	5% WB	MCWBR	14.4	14.0	14.2	16.2	17.1	11.8	11.9	12.9	13.3	12.6	10.4	13.5		
(40) Clear-Sky Solar Irradiance	taub		0.194	0.267	0.297	0.331	0.337	0.338	0.350	0.338	0.308	0.291	0.336	0.352		
	taud		1.971	2.186	2.248	2.338	2.467	2.491	2.471	2.496	2.565	2.440	2.695	2.735		
	Ebn at Noon		115	203	249	267	277	279	271	264	251	200	109	56		
	Edh at Noon		8	18	26	31	30	30	30	26	20	14	7	4		
(44) All-Sky Solar Radiation	RadAvg		45	243	731	1266	1506	1663	1536	1167	696	281	68	16		
	RadStd		4	38	64	91	185	139	176	116	87	49	13	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page