

HEMLING, Sweden

WMO: 022650

Lat: 63.6503N

Lon: 18.5466E

Elev: 600

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.8	-8.7	-19.7	1.9	-14.7	-13.1	2.8	-8.5	17.7	31.7	15.8	31.0	1.1	340	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	77.6	63.0	74.0	61.4	70.8	59.8	65.5	73.4	63.4	71.2	61.4	68.2	6.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	87.3	68.1	60.3	80.0	65.9	58.4	74.5	63.8	30.6	73.1	29.1	71.6	27.6	68.2	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.7	13.5	11.8	DB	-20.1	82.1	5.6	3.8	-24.1	84.8	-27.4	87.0	-30.5	89.1	-34.6	91.9	
			WB	-20.7	68.1	5.4	2.4	-24.6	69.9	-27.7	71.3	-30.7	72.6	-34.7	74.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.6	16.3	17.7	24.9	35.0	45.5	53.0	58.7	55.4	47.1	36.0	27.5	20.6
	DBStd	16.73	11.84	12.04	9.20	6.15	6.58	5.50	4.96	5.25	5.54	6.86	8.55	11.37
	HDD50	5537	1045	906	779	451	173	30	1	13	118	435	675	911
	HDD65	10387	1510	1326	1244	901	605	361	203	300	537	899	1125	1376
	CDD50	637	0	0	0	0	32	120	272	181	31	1	0	0
	CDD65	12	0	0	0	0	0	1	9	2	0	0	0	0
	CDH74	310	0	0	0	0	13	63	185	49	0	0	0	0
	CDH80	36	0	0	0	0	0	7	27	2	0	0	0	0
Wind	WSAvg	4.8	4.3	4.3	5.3	5.1	5.6	5.8	4.9	4.4	4.6	4.4	4.3	4.2
Precipitation	PrecAvg	25.7	1.9	1.2	1.2	1.3	1.6	2.0	3.5	3.7	2.5	2.4	2.2	2.0
	PrecMax	37.0	3.5	2.9	3.4	2.9	2.8	4.4	8.5	7.0	6.3	6.4	5.6	4.9
	PrecMin	16.6	0.2	0.2	0.3	0.2	0.2	0.8	0.1	0.7	0.5	0.7	0.7	0.2
	PrecStd	4.8	0.8	0.6	0.6	0.8	0.7	0.8	1.9	1.9	1.6	1.3	1.4	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.7	43.4	48.5	64.6	75.9	80.7	83.7	79.0	67.7	55.2	47.6	41.6
		MCWB	38.3	38.2	41.0	49.2	58.1	61.5	66.0	65.5	58.9	49.7	46.1	38.9
	2%	DB	37.6	41.0	44.5	56.8	70.2	74.7	78.9	74.7	63.7	51.8	43.5	39.2
		MCWB	35.6	37.0	38.3	46.4	55.3	59.5	64.3	63.1	56.0	48.7	42.6	36.8
	5%	DB	34.9	36.8	41.7	51.4	65.4	70.1	75.2	71.1	60.3	49.3	40.6	36.7
		MCWB	33.3	34.1	36.3	42.5	52.9	57.0	62.8	61.2	54.0	47.0	39.5	35.3
	10%	DB	32.4	33.5	38.5	47.3	60.5	66.6	72.0	67.2	57.8	47.2	38.6	34.8
		MCWB	31.6	32.0	34.4	39.8	50.2	55.6	61.4	59.6	53.3	45.2	37.5	33.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.5	39.0	41.7	50.9	60.1	63.8	68.5	67.8	60.1	51.5	46.4	39.6
		MCDB	41.2	42.2	47.9	62.9	70.6	75.9	76.7	74.9	65.3	53.1	47.1	41.1
	2%	WB	35.8	37.2	39.0	46.6	57.1	60.9	66.3	64.9	57.5	49.4	42.9	37.2
		MCDB	37.4	40.6	43.7	56.4	69.0	71.5	74.2	71.4	61.3	51.1	43.6	38.4
	5%	WB	33.5	34.5	36.8	43.0	53.5	58.9	64.5	62.6	55.7	47.5	39.8	35.4
		MCDB	34.5	36.4	40.8	50.1	63.7	67.2	73.1	68.8	58.7	49.1	40.4	36.5
	10%	WB	31.7	32.1	34.7	40.4	50.8	56.6	62.6	60.5	54.0	45.3	37.6	33.8
		MCDB	32.6	33.2	38.0	46.3	59.3	64.4	70.2	65.6	56.9	46.9	38.3	34.6
Mean Daily Temperature Range	5% DB	MDBR	14.3	16.3	18.1	18.8	20.9	20.3	20.3	19.4	17.5	13.5	9.8	13.1
		MCDBR	14.9	15.1	19.9	27.8	31.0	27.5	27.3	26.8	22.3	17.3	10.3	12.4
		MCWBR	13.9	12.8	14.4	17.2	17.5	14.3	14.2	15.6	15.3	13.7	9.3	11.6
	5% WB	MCDBR	14.1	14.3	18.4	26.1	29.0	25.1	23.6	22.9	18.8	15.7	10.0	11.9
		MCWBR	13.4	12.4	13.8	16.6	16.9	13.9	13.4	14.2	13.9	13.2	9.3	11.1
Clear-Sky Solar Irradiance	taub		0.214	0.278	0.305	0.343	0.344	0.342	0.358	0.347	0.316	0.301	0.360	0.350
	taud		2.022	2.191	2.266	2.338	2.450	2.483	2.457	2.479	2.555	2.434	2.726	2.673
	Ebn at Noon		123	205	250	265	276	279	270	263	251	201	117	68
	Edh at Noon		9	19	27	31	30	30	30	27	21	15	8	5
All-Sky Solar Radiation	RadAvg		49	239	711	1198	1551	1755	1614	1224	744	302	77	23
	RadStd		6	43	75	107	176	121	166	108	84	54	16	2

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-229	N/A	N/A	N/A	

Nomenclature: See separate page