

ORNSKOLDSVIK, Sweden

WMO: 022670

Lat: 63.412N

Lon: 18.980E

Elev: 108

StdP: 100.04

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.1	-18.2	-23.9	0.4	-21.0	-20.8	0.6	-17.9	11.7	1.8	10.2	1.8	1.9	310	0.675

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	25.0	16.8	23.1	15.8	21.3	15.1	18.3	23.1	17.1	21.4	16.0	19.8	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	12.0	19.7	15.3	11.0	18.3	14.2	10.3	17.5	52.2	22.9	48.3	21.3	45.2	19.8	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.3	-25.4	27.7	3.0	2.7	-27.5	29.7	-29.2	31.2	-30.9	32.8	-33.1	34.7		
(5)			-25.6	19.6	2.9	1.2	-27.7	20.4	-29.4	21.1	-31.1	21.8	-33.2	22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.9	-6.3	-6.5	-2.8	2.5	7.8	12.3	15.7	14.0	9.7	3.8	-0.6	-3.5	(6)
(7)		DBStd	8.63	5.34	6.16	4.75	3.21	3.94	2.96	2.83	2.77	2.91	3.32	4.13	4.93	(7)
(8)		HDD10.0	2669	505	463	398	225	92	11	0	3	40	193	318	420	(8)
(9)		HDD18.3	5285	763	696	656	475	326	182	92	138	259	451	568	678	(9)
(10)		CDD10.0	441	0	0	0	0	24	81	177	127	31	1	0	0	(10)
(11)		CDD18.3	14	0	0	0	0	0	1	11	3	0	0	0	0	(11)
(12)		CDH23.3	156	0	0	0	0	4	22	113	17	0	0	0	0	(12)
(13)		CDH26.7	23	0	0	0	0	0	4	18	1	0	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.3	3.2	3.5	3.1	3.3	3.5	3.0	2.9	3.1	3.2	3.2	3.4	(14)
(15)	Precipitation	PrecAvg	663	52	33	34	34	37	51	87	87	65	67	64	52	(15)
(16)		PrecMax	1044	107	75	87	88	64	115	195	154	156	184	183	113	(16)
(17)		PrecMin	446	7	5	8	5	3	19	8	16	17	17	17	4	(17)
(18)		PrecStd	127	24	17	17	21	17	21	46	43	39	38	44	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.0	6.2	9.8	17.3	23.7	26.0	28.8	25.2	19.9	13.4	9.3	6.2	(19)
(20)			MCWB	3.2	3.4	5.1	9.6	13.8	15.8	18.3	18.2	14.5	9.6	7.6	4.5	(20)
(21)		2%	DB	3.1	5.0	7.1	14.1	21.0	22.7	26.3	23.1	17.9	11.6	7.2	4.9	(21)
(22)			MCWB	1.9	2.8	3.4	7.8	13.2	14.1	17.5	16.6	13.2	9.2	6.4	3.4	(22)
(23)		5%	DB	2.1	3.0	5.4	11.0	18.2	20.6	24.2	21.4	16.5	10.1	6.0	3.7	(23)
(24)			MCWB	1.3	1.5	2.4	5.6	11.6	13.6	16.8	15.6	12.6	8.4	5.2	2.8	(24)
(25)		10%	DB	1.0	1.1	3.9	8.8	15.7	18.9	22.2	19.8	15.1	9.1	5.0	2.8	(25)
(26)			MCWB	0.4	0.3	1.4	4.4	9.7	12.5	16.0	15.1	12.2	7.7	4.2	2.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	3.8	5.4	10.1	15.2	16.9	20.4	20.0	15.6	10.8	8.0	4.7	(27)
(28)			MCDWB	4.2	5.6	8.9	16.3	21.4	22.7	23.7	22.5	18.0	12.0	8.7	5.4	(28)
(29)		2%	WB	2.1	2.9	3.8	7.9	13.6	15.6	18.9	17.9	14.4	9.7	6.4	3.6	(29)
(30)			MCDWB	2.7	4.7	6.6	13.5	20.0	20.9	23.9	21.4	16.6	10.8	7.0	4.1	(30)
(31)		5%	WB	1.3	1.5	2.6	6.0	11.8	14.4	17.7	16.6	13.6	8.7	5.4	2.7	(31)
(32)			MCDWB	1.9	2.6	4.9	10.2	17.6	19.1	22.8	19.7	15.5	10.0	5.8	3.3	(32)
(33)		10%	WB	0.4	0.4	1.6	4.6	10.2	13.3	16.7	15.6	12.8	7.7	4.3	1.8	(33)
(34)			MCDWB	0.9	0.9	3.4	8.2	14.9	17.2	21.2	18.4	14.6	8.8	4.8	2.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	7.3	8.3	9.2	10.1	9.9	9.6	9.2	8.5	6.5	5.1	6.0	(35)
(36)			MCDBR	6.5	6.9	9.5	13.9	14.5	13.4	13.0	12.1	10.9	8.2	5.3	6.3	(36)
(37)			MCWBR	6.1	5.7	6.7	8.5	7.9	6.9	6.3	6.6	7.0	6.3	4.8	5.8	(37)
(38)		5% WB	MCDBR	6.1	5.8	8.8	13.0	13.5	11.4	11.2	10.0	8.9	7.2	5.1	5.9	(38)
(39)			MCWBR	5.8	4.8	6.5	8.4	7.8	6.5	6.3	5.9	6.4	5.9	4.9	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.223	0.283	0.307	0.345	0.346	0.344	0.361	0.351	0.320	0.305	0.367	0.348	(40)	
(41)		taud	2.048	2.202	2.282	2.348	2.457	2.495	2.466	2.488	2.558	2.432	2.721	2.647	(41)	
(42)		Ebn at Noon	394	645	789	835	869	878	849	826	788	634	370	221	(42)	
(43)		Edh at Noon	29	60	83	98	96	94	95	85	65	49	26	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.15	0.74	2.23	3.75	4.96	5.63	5.18	3.92	2.39	0.97	0.25	0.08	(44)	
(45)		RadStd	0.02	0.14	0.25	0.35	0.54	0.37	0.51	0.34	0.26	0.17	0.05	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-127	N/A	N/A	N/A

Nomenclature: See separate page