

SKAGSUDD, Sweden

WMO: 022690

Lat: 63.1881N

Lon: 19.0161E

Elev: 31

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.1	4.3	-5.6	4.1	0.1	-0.7	5.3	5.8	34.5	31.4	31.8	31.2	9.3	320	0.725

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	71.0	65.1	68.9	63.1	66.7	61.4	66.4	69.5	64.4	67.3	62.4	65.1	9.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.0	92.6	68.7	63.0	86.1	66.4	61.1	80.4	64.3	31.1	69.8	29.5	67.4	28.1	65.2	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.7	27.0	23.4	-3.5	74.6	7.1	3.3	-8.7	77.0	-12.8	79.0	-16.8	80.8	-22.0	83.3		
			-3.3	66.4	6.8	2.6	-8.2	68.3	-12.1	69.9	-16.0	71.3	-20.9	73.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.9	25.0	24.3	28.9	35.9	44.9	53.6	60.8	59.2	52.2	42.1	34.3	28.8
	DBStd	14.35	9.67	10.10	7.38	4.86	5.61	4.67	4.12	4.20	4.86	5.64	7.29	8.91
	HDD50	4179	775	721	653	424	179	17	0	1	33	248	470	658
	HDD65	8803	1240	1141	1118	874	623	343	143	186	383	709	920	1123
	CDD50	872	0	0	0	0	20	125	336	286	101	4	0	0
	CDD65	21	0	0	0	0	0	1	14	6	0	0	0	0
	CDH74	13	0	0	0	0	1	0	11	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.6	12.2	11.7	10.6	9.0	9.0	9.3	8.8	9.8	10.5	11.6	12.4	12.9
Precipitation	PrecAvg	21.9	1.5	0.9	1.1	1.1	1.5	1.9	2.8	3.0	2.3	2.4	2.0	1.5
	PrecMax	33.3	3.4	2.0	2.6	3.0	3.1	3.5	6.9	6.2	5.8	6.8	5.2	3.3
	PrecMin	15.2	0.3	0.2	0.3	0.2	0.2	1.0	0.6	0.7	0.7	0.7	0.4	0.2
	PrecStd	3.6	0.7	0.5	0.6	0.7	0.7	0.6	1.5	1.6	1.3	1.3	1.3	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	43.5	47.7	52.9	63.8	69.8	75.4	72.1	64.8	55.0	50.1	44.7
		MCWB	38.5	38.6	40.9	44.0	53.4	57.9	65.9	66.2	57.1	51.0	45.2	41.5
	2%	DB	39.3	40.2	43.3	48.1	58.9	65.7	72.2	70.1	62.4	52.9	46.6	42.2
		MCWB	36.7	36.5	37.4	40.8	50.0	57.2	65.6	64.5	58.0	50.6	44.6	40.0
	5%	DB	37.7	37.5	40.2	45.0	55.6	63.0	70.0	68.1	60.8	51.7	45.0	40.5
		MCWB	35.9	34.8	35.7	39.4	47.9	55.8	64.2	63.5	57.0	49.8	43.2	38.8
	10%	DB	36.4	35.5	37.5	42.4	53.0	60.4	67.9	66.0	59.2	50.1	43.3	39.2
		MCWB	34.9	33.9	34.1	38.4	46.7	54.5	62.5	61.4	56.0	48.0	41.7	37.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.1	39.0	41.7	45.2	54.5	62.7	69.5	68.3	61.2	52.6	46.4	42.3
		MCDB	41.1	43.1	47.4	51.3	60.7	66.2	72.5	71.2	62.5	53.2	47.9	43.5
	2%	WB	37.5	37.1	38.2	42.2	51.1	59.2	67.2	66.1	59.7	51.4	44.9	40.6
		MCDB	38.8	39.7	42.2	46.6	56.0	63.2	70.3	68.8	61.1	52.3	46.1	41.8
	5%	WB	36.3	35.5	36.2	40.3	49.1	57.3	65.1	64.4	58.2	49.9	43.4	39.1
		MCDB	37.5	36.9	39.2	43.8	53.2	60.8	68.4	67.1	59.8	51.3	44.4	40.3
	10%	WB	34.9	34.1	34.9	38.8	47.1	55.9	63.1	62.5	56.7	48.1	41.9	37.8
		MCDB	36.2	35.3	37.1	41.8	51.1	59.3	66.1	64.9	58.5	49.8	43.0	39.1
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.7	9.0	7.9	8.3	8.0	7.3	7.7	7.6	7.0	6.5	7.7
		MCDBR	7.5	8.7	11.4	12.6	12.6	11.9	9.9	9.5	9.0	7.1	5.7	7.2
		MCWBR	6.8	7.2	7.5	7.6	7.1	6.7	6.4	6.4	6.3	5.8	5.5	6.6
	5% WB	MCDBR	6.9	8.0	10.1	11.5	10.9	9.2	7.9	7.3	6.8	5.6	5.3	6.6
		MCWBR	6.4	6.9	6.9	7.6	7.1	6.4	6.2	5.7	5.7	5.4	5.5	6.3
Clear-Sky Solar Irradiance	taub	0.233	0.291	0.313	0.352	0.352	0.348	0.367	0.358	0.327	0.312	0.373	0.346	
	taud	2.074	2.214	2.295	2.350	2.453	2.498	2.467	2.486	2.554	2.424	2.701	2.605	
	Ebn at Noon	125	203	249	263	274	277	268	260	248	199	117	71	
	Edh at Noon	10	19	26	31	30	30	30	27	21	16	9	5	
All-Sky Solar Radiation	RadAvg	49	230	702	1195	1604	1827	1677	1273	770	312	79	25	
	RadStd	7	45	80	113	168	116	162	104	82	56	17	2	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	-209	N/A	N/A	N/A

Nomenclature: See separate page