

NORSJO, Sweden

WMO: 022710

Lat: 64.9253N

Lon: 19.3744E

Elev: 1017

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -17.9	(c) -11.7	(d) -24.3	(e) 1.5	(f) -18.0	(g) -16.5	(h) 2.3	(i) -11.6	(j) 16.0	(k) 27.1	(l) 14.4	(m) 24.7	(n) 0.7	(o) 330	(p) 0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	76.2	60.7	72.6	59.6	69.2	58.0	63.6	71.6	61.5	69.4	59.6	66.7	6.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.4	81.3	65.9	58.4	75.7	64.2	56.6	70.8	62.4	29.4	71.9	27.9	69.2	26.6	66.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.5	(b) 13.0	(c) 11.7	(e) -24.7	(f) 79.6	(g) 7.2	(h) 4.5	(i) -29.9	(j) 82.8	(k) -34.1	(l) 85.5	(m) -38.2	(n) 88.0	(o) -43.4	(p) 91.3		
(4) 14.5	(5) 13.0	(6) 11.7	(7) -24.8	(8) 65.4	(9) 6.9	(10) 2.3	(11) -29.8	(12) 67.1	(13) -33.8	(14) 68.4	(15) -37.7	(16) 69.7	(17) -42.8	(18) 71.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.4	14.1	14.9	23.1	33.7	44.6	52.9	58.7	55.2	46.3	34.9	25.2	19.3
	DBStd	17.64	12.54	12.88	9.56	6.62	7.11	6.44	5.21	5.77	5.53	7.13	9.00	11.62
	HDD50	5978	1114	981	834	489	200	39	2	17	136	468	745	953
	HDD65	10841	1579	1401	1299	939	633	366	208	308	562	933	1195	1418
	CDD50	631	0	0	0	0	32	126	270	178	24	1	0	0
	CDD65	19	0	0	0	0	0	4	11	4	0	0	0	0
	CDH74	207	0	0	0	0	4	57	110	36	0	0	0	0
	CDH80	24	0	0	0	0	0	7	15	2	0	0	0	0
Wind	WSAvg	5.4	4.9	5.1	6.0	5.8	5.9	6.0	5.2	5.0	5.3	5.7	5.0	5.1
Precipitation	PrecAvg	24.1	1.5	1.2	1.3	1.3	1.6	2.4	3.9	2.9	2.2	2.0	2.0	1.7
	PrecMax	31.7	2.8	3.1	2.5	2.3	2.9	4.0	7.4	6.2	5.0	3.7	4.0	4.0
	PrecMin	18.3	0.1	0.2	0.5	0.4	0.5	0.9	1.0	0.8	0.7	0.7	0.8	0.4
	PrecStd	3.6	0.6	0.7	0.6	0.6	0.7	0.8	1.5	1.5	1.1	0.8	0.9	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	42.0	46.2	60.5	73.5	80.1	81.9	78.1	65.2	54.0	46.0	39.9
		MCWB	37.4	37.8	39.6	47.1	55.6	60.6	64.3	63.8	56.1	49.1	43.9	37.4
	2%	DB	36.2	39.0	42.1	53.0	68.5	74.1	76.8	73.8	60.9	49.7	42.2	37.1
		MCWB	34.2	35.5	36.5	43.2	54.1	58.0	61.1	61.1	54.3	46.6	40.6	35.2
	5%	DB	33.3	35.2	39.4	48.5	63.2	69.2	73.5	70.0	57.7	47.2	38.6	34.9
		MCWB	31.8	32.5	34.7	40.3	50.8	56.4	60.5	60.0	52.1	44.5	37.3	33.6
	10%	DB	30.5	31.8	36.6	44.8	57.9	65.5	69.9	65.8	55.2	45.0	36.1	33.2
		MCWB	29.6	30.2	32.8	37.7	47.8	53.9	59.0	58.1	50.9	42.9	35.0	32.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.5	38.2	39.8	47.7	58.0	62.8	67.5	65.9	57.9	49.9	44.6	37.5
		MCDB	40.4	41.5	45.1	58.6	69.3	75.7	76.3	74.2	61.5	52.0	46.3	38.9
	2%	WB	34.4	35.7	37.1	44.1	55.0	60.0	64.3	63.1	55.5	47.1	40.8	35.5
		MCDB	36.1	38.6	41.2	52.2	66.2	70.4	71.6	70.3	59.6	49.1	42.0	36.6
	5%	WB	31.9	32.9	35.1	41.1	51.9	57.7	62.3	61.1	53.5	45.0	37.6	33.8
		MCDB	33.1	34.8	38.8	46.7	61.7	66.8	70.4	67.6	56.3	46.7	38.5	34.6
	10%	WB	29.6	30.2	33.0	38.6	48.6	55.3	60.4	59.0	51.7	43.0	35.1	32.2
		MCDB	30.5	31.7	36.0	44.0	56.5	63.2	67.8	64.3	54.4	44.9	35.9	33.0
Mean Daily Temperature Range	5% DB	MDBR	12.9	13.7	15.6	15.2	16.8	16.2	16.1	14.9	13.0	9.1	8.4	11.4
		MCDBR	11.7	11.8	15.9	21.2	26.1	22.4	21.6	21.3	16.5	11.9	8.3	10.1
		MCWBR	10.9	10.2	11.6	12.8	13.9	10.6	9.9	10.6	10.6	9.1	7.4	9.5
	5% WB	MCDBR	11.8	11.3	15.2	19.7	24.8	20.8	19.2	18.1	14.2	10.9	7.9	9.9
		MCWBR	11.1	10.1	11.5	12.5	14.0	10.4	9.9	9.9	9.9	8.7	7.3	9.4
Clear-Sky Solar Irradiance	taub	0.184	0.260	0.289	0.321	0.330	0.332	0.344	0.331	0.302	0.285	0.335	0.351	
	taud	1.957	2.197	2.258	2.348	2.486	2.505	2.486	2.513	2.577	2.444	2.735	2.771	
	Ebn at Noon	112	204	251	271	279	281	273	266	253	200	107	52	
	Edh at Noon	7	17	26	30	29	29	29	26	19	14	6	4	
All-Sky Solar Radiation	RadAvg	41	235	722	1276	1529	1659	1528	1159	680	270	64	13	
	RadStd	4	38	61	83	184	139	171	117	85	46	12	1	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page