

HELSINGE SODERHAMN, Sweden

WMO: 022861

Lat: 61.262N

Lon: 17.098E

Elev: 36

StdP: 100.89

Time Zone: 1.00 (EUC)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.1	-16.8	-21.2	0.6	-18.6	-19.2	0.7	-16.3	9.9	0.1	8.7	-0.3	2.8	300	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	26.2	18.1	24.0	17.4	22.0	16.3	19.2	24.0	18.2	22.0	17.4	20.8	4.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	12.8	20.2	16.9	12.1	19.6	16.0	11.4	18.9	54.7	23.8	51.3	21.7	48.9	21.0	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.6	6.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-22.3	20.3	2.5	1.3	-24.1	21.3	-25.5	22.0	-26.9	22.8	-28.8	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-4.2	-5.3	-1.2	4.0	7.6	12.9	16.2	15.4	10.8	5.9	0.6	-2.9	(6)
(7)		DBStd	8.46	5.64	5.89	4.44	3.39	3.53	3.03	3.19	2.74	2.94	3.55	4.51	5.68	(7)
(8)		HDD10.0	2338	441	429	347	184	92	7	0	1	24	133	282	399	(8)
(9)		HDD18.3	4874	699	663	605	431	332	165	82	98	226	386	531	658	(9)
(10)		CDD10.0	531	0	0	0	3	18	93	193	168	49	6	0	0	(10)
(11)		CDD18.3	26	0	0	0	0	0	2	17	7	0	0	0	0	(11)
(12)		CDH23.3	281	0	0	0	0	0	39	182	58	1	0	0	0	(12)
(13)		CDH26.7	64	0	0	0	0	0	8	47	9	0	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.5	3.0	3.2	3.1	3.2	3.1	3.1	2.9	3.0	3.0	3.2	3.3	(14)
(15)	Precipitation	PrecAvg	594	41	31	29	37	42	56	66	73	56	64	55	46	(15)
(16)		PrecMax	853	85	60	64	97	88	129	157	141	134	149	161	88	(16)
(17)		PrecMin	443	4	7	3	5	8	8	19	18	13	2	20	3	(17)
(18)		PrecStd	100	22	13	16	25	22	27	34	34	31	40	34	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	7.1	12.9	20.1	22.1	27.8	31.4	27.9	22.8	16.2	12.0	9.0	(19)
(20)			MCWB	5.8	4.6	7.6	12.0	14.5	17.1	19.6	17.9	17.2	12.8	10.4	6.5	(20)
(21)		2%	DB	6.2	5.2	9.0	16.0	18.8	23.8	27.6	24.9	19.4	14.0	9.9	7.0	(21)
(22)			MCWB	4.2	3.0	4.7	10.2	12.0	16.2	18.5	18.2	15.2	11.2	8.6	5.5	(22)
(23)		5%	DB	5.0	3.8	6.9	13.0	16.9	21.2	25.1	22.2	17.8	12.8	8.1	5.3	(23)
(24)			MCWB	3.4	1.9	3.7	8.5	11.2	15.3	17.6	17.3	14.1	10.3	7.2	4.1	(24)
(25)		10%	DB	3.0	2.2	5.0	11.0	14.9	19.5	23.0	20.7	16.1	11.2	6.8	4.0	(25)
(26)			MCWB	1.7	1.1	2.4	6.7	9.8	13.9	16.8	16.8	13.4	9.2	6.1	3.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.2	5.1	7.6	12.9	15.1	18.5	20.9	20.2	17.6	13.2	10.7	7.1	(27)
(28)			MCDB	7.6	6.7	12.3	18.1	20.8	23.8	27.4	23.9	21.7	15.1	11.9	8.1	(28)
(29)		2%	WB	4.4	3.4	5.4	10.7	13.0	16.9	19.7	19.0	15.9	11.8	8.7	5.6	(29)
(30)			MCDB	5.8	4.7	8.1	15.3	17.3	22.6	25.5	22.8	18.6	13.6	9.5	6.4	(30)
(31)		5%	WB	3.3	2.1	3.8	8.6	11.5	15.7	18.4	18.1	14.8	10.7	7.2	4.2	(31)
(32)			MCDB	4.8	3.1	6.4	12.6	15.9	20.2	23.6	20.8	17.0	12.3	7.8	5.0	(32)
(33)		10%	WB	1.7	1.1	2.6	7.0	10.3	14.5	17.4	17.5	13.8	9.7	6.0	3.1	(33)
(34)			MCDB	2.8	2.1	4.7	10.4	14.1	18.8	21.9	20.0	15.8	11.0	6.4	3.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	7.4	8.1	9.5	9.5	9.7	9.6	9.0	8.8	7.3	5.6	5.7	(35)
(36)			MCDBR	6.7	6.6	10.1	14.3	13.3	13.4	13.4	11.7	10.5	8.4	6.7	5.8	(36)
(37)			MCWBR	5.6	5.3	7.1	9.2	7.4	7.1	6.1	6.2	6.8	6.1	5.9	5.2	(37)
(38)		5% WB	MCDBR	6.6	6.0	9.4	13.6	12.5	12.4	12.1	9.5	9.8	8.0	6.3	5.5	(38)
(39)			MCWBR	5.9	5.1	6.7	9.0	7.4	7.3	6.3	5.8	6.8	6.1	5.7	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.253	0.302	0.323	0.358	0.359	0.353	0.374	0.366	0.333	0.319	0.274	0.350	(40)	
(41)		taud	2.182	2.292	2.371	2.377	2.436	2.489	2.450	2.464	2.541	2.450	2.229	2.630	(41)	
(42)		Ebn at Noon	482	679	799	836	864	876	845	821	791	662	443	326	(42)	
(43)		Edh at Noon	36	63	81	98	100	97	98	90	70	54	34	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.24	0.88	2.39	3.87	4.93	5.55	5.19	3.97	2.54	1.15	0.34	0.15	(44)	
(45)		RadStd	0.04	0.16	0.27	0.34	0.52	0.38	0.53	0.37	0.32	0.19	0.07	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page