

HOLMOGADDS FYR, SwedenWMO: **022880**Lat: **63.594N**Lon: **20.752E**Elev: **20**StdP: **14.69**Time Zone: **1.00 (EUC)**Period: **94-07**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.8	4.8	-3.7	4.5	1.2	0.3	5.6	5.2	39.5	31.2	34.6	30.0	8.0	0	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	70.1	63.3	68.0	62.6	65.9	61.1	65.2	68.5	63.6	66.8	62.0	65.1	7.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.8	88.7	67.3	62.1	83.5	65.8	60.4	78.6	64.0	30.2	68.8	29.0	66.8	27.8	65.3	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.7	27.6	24.5	-1.7	73.3	6.6	2.1	-6.5	74.8	-10.3	76.0	-14.0	77.2	-18.8	78.7		
(5)			-1.9	66.5	6.3	2.1	-6.4	68.0	-10.2	69.2	-13.7	70.3	-18.3	71.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.2	25.7	22.3	25.9	34.2	42.0	52.2	59.9	59.9	52.0	42.8	34.3	29.4
	DBStd	14.26	8.95	9.55	7.28	4.04	4.01	4.47	3.97	4.25	4.55	5.40	6.06	7.76
	HDD50	4390	752	777	746	473	249	26	0	0	31	226	470	640
	HDD65	9081	1217	1197	1211	923	712	384	165	168	391	688	920	1105
	CDD50	802	0	0	0	0	2	92	307	308	90	3	0	0
	CDD65	17	0	0	0	0	0	0	7	10	0	0	0	0
	CDH74	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	11.5	13.5	12.9	11.1	10.0	9.4	9.5	8.9	9.9	11.5	13.3	14.5	13.4
Precipitation	PrecAvg	22.5	1.9	1.4	1.5	1.2	1.5	1.5	1.9	2.5	2.4	2.2	2.6	2.0
	PrecMax	31.0	4.9	3.3	4.0	3.3	3.5	4.2	4.3	7.4	5.6	4.4	5.2	5.2
	PrecMin	15.7	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.4	0.4	0.7	0.5	0.7
	PrecStd	3.8	1.0	0.9	0.8	0.8	0.8	0.9	1.1	1.4	1.1	0.9	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.4	37.9	39.4	47.0	56.5	68.5	72.9	73.1	63.7	53.6	47.0	43.4
		MCWB	36.5	34.6	35.2	40.5	47.4	58.3	64.0	65.6	58.9	51.9	44.8	42.0
	2%	DB	37.2	36.1	36.7	43.1	52.3	63.8	70.2	70.6	61.7	52.3	45.5	41.3
		MCWB	35.3	33.6	33.9	38.7	45.3	55.2	62.6	64.4	57.4	50.8	43.9	39.9
	5%	DB	36.3	34.7	35.5	41.2	49.5	61.4	68.2	68.6	60.2	51.2	44.4	40.1
		MCWB	34.6	32.9	33.4	37.7	44.2	54.3	62.1	63.6	56.7	49.8	42.9	38.8
	10%	DB	35.1	33.5	34.1	39.4	47.7	59.3	66.2	66.4	58.6	50.0	43.1	38.7
		MCWB	33.8	32.3	32.4	36.6	43.4	53.6	61.3	62.0	55.5	48.4	41.6	37.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.4	35.3	36.0	41.7	49.1	60.3	66.2	67.4	60.5	52.6	45.9	42.5
		MCDB	37.6	36.6	37.5	45.6	53.5	65.5	69.7	70.8	62.2	52.9	46.4	43.4
	2%	WB	35.8	34.2	34.7	39.6	46.8	57.0	64.6	66.1	58.7	51.2	44.5	40.4
		MCDB	36.6	35.2	36.0	42.0	50.0	61.0	68.2	69.5	60.5	51.9	45.2	41.0
	5%	WB	34.8	33.4	33.7	38.2	45.4	55.7	63.4	64.5	57.6	50.0	43.2	39.0
		MCDB	35.8	34.2	34.9	40.4	48.2	59.5	67.0	67.3	59.6	51.1	44.2	39.8
	10%	WB	33.9	32.5	32.8	36.9	44.3	54.6	62.0	62.9	56.0	48.6	41.6	37.6
		MCDB	35.0	33.4	33.9	38.9	47.0	58.3	65.4	65.7	57.9	49.9	42.9	38.5
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.6	7.6	6.2	7.1	7.3	6.7	6.5	5.5	4.5	5.2	5.8
		MCDBR	5.4	7.2	6.0	8.6	9.7	10.7	9.0	7.6	6.6	4.0	3.8	4.7
		MCWBR	5.2	6.7	4.8	5.4	5.5	6.1	5.3	4.8	5.4	3.8	4.3	4.4
	5% WB	MCDBR	5.0	6.4	5.3	7.7	7.9	8.8	7.8	7.1	5.5	3.7	4.0	4.6
		MCWBR	5.1	6.2	4.5	5.1	5.3	5.8	5.1	5.4	5.1	3.7	4.6	4.6
Clear-Sky Solar Irradiance	taub	0.230	0.288	0.312	0.350	0.351	0.350	0.369	0.358	0.331	0.314	0.367	0.351	
	taud	2.033	2.161	2.230	2.297	2.451	2.497	2.467	2.493	2.547	2.390	2.640	2.581	
	Ebn at Noon	116	199	246	262	274	276	266	259	245	194	108	60	
	Edh at Noon	9	20	28	32	30	30	30	27	21	16	8	5	
All-Sky Solar Radiation	RadAvg	42	223	704	1217	1647	1864	1702	1289	751	282	67	20	
	RadStd	4	45	82	116	153	147	153	114	74	54	13	2	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page